

**Table 13.9.: Requirements for Fuel Dispensing Facilities**

ITEM	REQUIREMENTS
<b>8. OTHER APPLICABLE CODES FOR ENCLOSED AREAS OF FUEL DISPENSING FACILITIES AND INDOOR FUEL DISPENSING FACILITIES</b>	<ul style="list-style-type: none"> <li>i. Fire Detection and Alarm System shall be provided in accordance with <b>Chapter 8. Fire Detection and Alarm System.</b></li> <li>ii. Repair garages used for repair of vehicle engine fuel systems fueled by non-odorized gases, such as Hydrogen and non-odorized LNG/CNG, shall be provided with approved gas detection system in accordance with manufacturer's specifications.</li> <li>iii. Fire Protection System shall be provided in accordance with <b>Chapter 9. Fire Protection Systems.</b></li> <li>iv. Means of Egress shall comply with <b>Chapter 3. Means of Egress.</b></li> <li>v. Fire extinguishers shall be provided throughout in accordance with <b>Chapter 4. Fire Extinguishers.</b></li> <li>vi. For fuel dispensing areas, extinguishers shall be provided as required by the extra high hazard requirements for Class B hazards (80:B:C), trolley mounted, with maximum travel distance not exceeding 30 m.</li> <li>vii. Warning Signs and Exit Signs shall be provided in accordance with <b>Chapter 5. Exit Signs.</b></li> <li>viii. Emergency Lighting shall comply with <b>Chapter 6. Emergency Lighting.</b></li> <li>ix. Where LPG systems are required for restaurant kitchens, it shall comply with <b>Chapter 11. Liquid Petroleum Gas Systems.</b></li> </ul>