

2.3. Fire Access Roadways for Fire Vehicles

- 2.3.1. Civil Defence Fire access Roadways shall be provided to every facility, every structure and every under construction buildings, except detached retail units, kiosks, store rooms, snack bars, rest rooms which are less than 100 m² and are remotely located from predominant occupancy.
- 2.3.2. Civil Defence Fire department access roads shall consist of Roadways, Fire Lanes, Parking lot lanes, or a combination thereof. Such Fire Accessway shall comply with **Table 2.1.** specifications.
- 2.3.3. Fire access road shall be of concrete, asphalt or such solid surface acceptable to Civil Defence
- 2.3.4. When a bridge is required to be used as part of a fire department access road, it shall be constructed and maintained in accordance with Municipality and Road Transport Authority's recognized standards.
- 2.3.5. The bridge shall be designed for a live load sufficient to carry the imposed loads of fire Vehicle, as per **Table 2.1.**
- 2.3.6. Vehicle load limits shall be posted at both entrances to bridges.

