

## 4. Application of Accessibility Features

**4.1.** Application of accessible features in a building , site or structure shall be as per Table 15.7.

Table 15.7.: Application of Accessible Features in a Building		
ITEMS	REQUIREMENTS	EXCEPTIONS
AS PER TABLE 15.1. AND ICC ANSI 117.1	1. SITE AND SITE ARRIAVAL POINTS  i. Accessible Routes shall be provided within a site, from public transportation stops, accessible parking, accessible passenger loading zones, public streets and sidewalks to accessible building entrance.  ii. At least one accessible route shall connect accessible buildings, accessible facilities, accessible elements and accessible spaces that are on the same site.  2. CONNECTED SPACES	<ul> <li>i. Other than in buildings or facilities containing or serving Type B units, an accessible route shall not be required between site arrival points and the building or facility entrance if the only means of access between them is a vehicular way not providing for pedestrian access.</li> <li>ii. An accessible route is not required between accessible buildings, accessible facilities, accessible elements and accessible spaces that have, as the only means of access between them, a vehicular way not providing for pedestrian access.</li> </ul>
	i. When a building or portion of a building is required to be accessible, an accessible route shall be provided to each portion of the building, to accessible building entrances connecting accessible pedestrian walkways and the public way.	<ul> <li>i. In ASSEMBLY areas with fixed seating, an accessible route shall not be required to serve levels where wheelchair spaces are not provided.</li> <li>ii. In HEALTHCARE facilities, doors to sleeping units shall be exempted from the requirements for maneuvering clearance at the room side provided the door is a minimum of 1118 mm in width.</li> </ul>
	3. EMPLOYEE WORK AREA  i. Common circulation areas in employee work space shall have accessible routes.  4. PRESS BOXES	<ul> <li>i. Accessible routes shall not be required in employee work spaces which are less than 27.9 m² in area.</li> <li>ii. Accessible routes shall not be required in exterior, open to sky workplaces and at common circulation paths that are integral component of equipment.</li> </ul>
	i. Press boxes in assembly areas shall have accessible routes.  Output  Description:	<ul> <li>i. An accessible route shall not be required to press boxes in bleachers that have points of entry at only</li> <li>ii. one level, provided that the aggregate area of all press boxes is 46 m² maximum.</li> <li>iii. An accessible route shall not be required to free-standing press boxes that are elevated above grade 3660 mm minimum provided that the aggregate area of all press boxes is 46 m² maximum.</li> </ul>

