



4.8.3. Specific Requirements

- 4.8.3.1.** PEWFS shall be certified and listed by a third party independent Testing and Certification body, approved by Civil Defence.
- 4.8.3.2.** PEWFS shall be Marked/labeled to verify its certification mark from accredited certification body.
- 4.8.3.3.** The entire assembly including ornaments, trims and moldings with intended thickness, joints, seams, fasteners and wall arrangement shall be tested in accordance with **Table 1.16.a.**

4.8.4. Test Certifications

- 4.8.4.1.** PEWFS panels and facade systems on non-fire resistance rated and non load bearing exterior wall coverings shall comply with **Table 1.16.a.**
- 4.8.4.2.** EIFS and ETICS panels and facade systems on fire resistance rated exterior wall assembly coverings shall comply with **Table 1.16.b.**

4.8.5. Application

- 4.8.5.1.** The occupancies and type of buildings that are allowed to have PEWFS shall be in accordance with **Table 1.16.a.** and **Table 1.16.b.**