

**Table 13.4.e.: Dike Sub-Division Criteria (Minimum One Dike Subdivision Requirement)**

TANK CAPACITY IN GALLONS	STABLE LIQUID	CLASS I AND UNSTABLE LIQUID
<b>1. INDIVIDUAL TANK</b>	<b>INDIVIDUAL CAPACITY</b>	
1.1. WEAK SEAM ROOF TANK	OVER 420,000 Gal. (1,590 m <sup>3</sup> )	Irrespective of capacity
1.2. VERTICAL CONE ROOF TANK	OVER 100,000 Gal. (380 m <sup>3</sup> )	Irrespective of capacity
1.3. HORIZONTAL TANK, OVER	OVER 100,000 Gal. (380 m <sup>3</sup> )	Irrespective of capacity
<b>2. GROUP OF TANKS</b>	<b>AGGREGATE CAPACITY</b>	
2.1. WEAK SEAM ROOF TANK	OVER 630,000 Gal. (2,390 m <sup>3</sup> )	Irrespective of capacity
2.2. VERTICAL CONE ROOF TANK	OVER 150,000 Gal. (570 m <sup>3</sup> )	Irrespective of capacity
2.3. HORIZONTAL TANK, OVER	OVER 150,000 Gal. (570 m <sup>3</sup> )	Irrespective of capacity