

3.2. Specific Requirements for Fuel Dispensing Facilities

- 3.2.1.** The specific requirements for motor fuel dispensing facilities storing liquid fuels and related materials such as oils, greases, cleaning solvents, windshield cleaning solvents etc., shall comply with **Table 13.9.**

Table 13.9.: Requirements for Fuel Dispensing Facilities

ITEM	REQUIREMENTS
1. ABOVEGROUND TANK SEPARATION DISTANCES	<ul style="list-style-type: none"> i. Minimum distances of separation required for aboveground tanks at Motor fuel dispensing facilities shall be in accordance with Table 13.9.a. ii. The maximum individual tank capacity of 12,000 Gal indicated in Table 13.9.a., shall be permitted to be increased to 20,000 Gal. for Class II and Class III liquids stored at fleet vehicle motor fuel dispensing facility and aggregate capacity shall be allowed to be 80,000 Gal. iii. At fleet vehicle motor fuel dispensing facilities, no minimum separation shall be required between the dispensing device and a tank in a vault, a protected tank, or a fire-resistant tank.

Table 13.9.a.: Separation of Aboveground Tanks at Motor Fuel Dispensing Facilities

TYPE OF THE TANK	INDIVIDUAL TANK CAPACITY	BETWEEN TANKS	FROM ANY STRUCTURE	FROM FUEL DISPENSING DEVICE	FROM BOUNDARY LINE	FROM NEAREST PUBLIC WAY
1. TANKS IN VAULT	0- 15,000 Gal	Separate compartments	0 m	0 m	0 m	0 m
2. PROTECTED ABOVE GROUND TANKS	0- 6000 Gal	1.5 m	1.5 m	0	4.6 m	1.5 m
	6001—12,000 Gal	1.5 m	4.6 m	0	7.6 m	4.6 m
3. FIRE RESISTANT TANKS	0-12,000 Gal	1.5 m	7.6 m	7.6 m	15 m	7.6 m
4. OTHER APPROVED TANKS	0-12,000 Gal	1.5 m	15 m	15 m	30 m	15 m

