



2. CONSTRUCTION

Table A.1.2: FAQ-Construction

QUESTION	ANSWER
32. What is the type of construction for exit staircase shaft based on the height of the building	<ul style="list-style-type: none">i. Exit stairs serving Highrise buildings, Midrise buildings, High depth Underground buildings and buildings connecting four or more stories shall be constructed of RCC (Reinforced Concrete) with a minimum of 2 hour fire rating.ii. Exit Stairs serving Lowrise buildings, Lowdepth Underground buildings and buildings connecting Three or less stories shall be with 2 hour fire rated construction.