



**Table 1.9.: Fire Resistance Separation and other requirement of incidental accessory /Occupancies.**

INCIDENTAL ACCESSORY ROOMS AND OCCUPANCIES	REQUIRED SEPARATION WITH AUTOMATIC FIXED FIRE PROTECTION SYSTEM	REQUIRED SEPARATION WITHOUT AUTOMATIC FIXED FIRE PROTECTION SYSTEM	OTHER CONSTRUCTION AND PROTECTION REQUIREMENTS (See Chapter 9 for Fire Protection requirements Chapter 10 for smoke control requirements)
50. TENTS AND MARQUEES	0 Hour	0 Hour	<ul style="list-style-type: none"> <li>i. Minimum horizontal separation between Tents and other occupancies, including other tents shall not be less than 3m.</li> <li>ii. Such separation distance between tents shall not be required if tent area is less than 110m<sup>2</sup>.</li> <li>iii. Maximum height shall not exceed 2.8 m.</li> <li>iv. The finished ground level enclosed by the structure, and the surrounding finished ground level not less than 3 m outside of the structure, shall be cleared of all flammable or combustible material and vegetation.</li> <li>v. Flammable and combustible storage shall not be allowed.</li> <li>vi. See <b>section 7.1.42.</b> for material requirements.</li> </ul>
51. GRANDSTANDS AND BLEACHERS	0 Hour	0 Hour	<ul style="list-style-type: none"> <li>i. Grandstands shall be erected to withstand structural loads and only where load carrying capacities exist to support loads. manufacturer, supplier and designer shall submit undertaking letter to Civil Defence stating that design and equipment comply to withstand load.</li> <li>ii. Grandstands can be of unlimited area when of Type I or Type II construction as per <b>Table 1.7.</b></li> <li>iii. Outdoor Grandstand shall not be erected within 3 m of any building which has no 1 hour fire resistance rated exterior wall.</li> <li>iv. Outdoor grandstands constructed of Type III, Type IV or Type V shall not exceed 930 m<sup>2</sup> in area per unit or 61 m in length.</li> <li>v. Such outdoor grandstand units (iv) shall not be located within 6 m apart from each other. And not more than 3 units are allowed to be erected in one group.</li> <li>vi. Such groups (v) of less than 3 units shall be separated by either 2 hour fire rated construction extending 610 mm above the seating or shall be located 15 m apart.</li> <li>vii. Highest level of seat platforms shall not exceed 6 m from the finished ground level in front of the grandstand.</li> <li>viii. See <b>Chapter 3</b> for egress requirements.</li> </ul>