



2.8.5. Table 1.4. shall be applicable to all occupancies except Mercantile, Industrial Group A, Industrial Group B, Storage Group A, Storage Group B, Private Villas.

Table 1.4: Maximum percentage area (%) of exterior wall per storey openings allowed based on Separation distance

SEPARATION DISTANCE	% ALLOWED FOR BUILDINGS NON-SPRINKLERED AND NOT PROTECTED AS PER 2.8.4.b.	% ALLOWED FOR SPRINKLERED BUILDINGS AS PER CHAPTER 9 AND NOT PROTECTED AS PER 2.8.4.b.	% ALLOWED FOR PROTECTED OPENINGS AS PER 2.8.4.b.
0 m – Less than 1 m	NO OPENINGS ALLOWED	NO OPENINGS ALLOWED	NO OPENINGS ALLOWED
1 m – Less than 1.5 m	NO OPENINGS ALLOWED	15 %	15 %
1.5 m – Less than 3 m	10 %	25 %	25 %
3 m – Less than 4.5 m	15 %	UNLIMITED ALLOWED	45 %
4.5 m – Less than 6 m	25 %	UNLIMITED ALLOWED	75 %
6 m – Less than 7.5 m	45 %	UNLIMITED ALLOWED	UNLIMITED ALLOWED
7.5 m – Less than 9 m	70 %	UNLIMITED ALLOWED	UNLIMITED ALLOWED
9 m or More	UNLIMITED ALLOWED	UNLIMITED ALLOWED	UNLIMITED ALLOWED

2.8.6. Table 1.5. shall be applicable to Mercantile, Industrial Group A, Industrial Group B, Storage Group A, Storage Group B.

Table 1.5: Maximum percentage area (%) of exterior wall per storey openings allowed Group A, B occupancies

SEPARATION DISTANCE	% ALLOWED FOR BUILDINGS NON-SPRINKLERED AND NOT PROTECTED AS PER 2.8.4.b.	% ALLOWED FOR SPRINKLERED BUILDINGS AS PER CHAPTER 9 AND NOT PROTECTED AS PER 2.8.4.b.	% ALLOWED FOR PROTECTED OPENINGS AS PER 2.8.4.b.
0 m – Less than 1 m	NO OPENINGS ALLOWED	NO OPENINGS ALLOWED	NO OPENINGS ALLOWED
1 m – Less than 1.5 m	NO OPENINGS ALLOWED	NO OPENINGS ALLOWED	NO OPENINGS ALLOWED
1.5 m – Less than 3 m	4%	8%	8%
3 m – Less than 4.5 m	4%	8%	8%
4.5 m – Less than 6 m	4%	8%	8%
6 m – Less than 7.5 m	5%	10%	10%
7.5 m – Less than 9 m	5%	10%	10%
9 m or More	UNLIMITED ALLOWED	UNLIMITED ALLOWED	UNLIMITED ALLOWED