

**Table 9.32.: Fire Pump Testing, Inspection and Maintenance**

ITEM	REQUIREMENTS
<b>4. ANNUAL TESTING</b>	<ul style="list-style-type: none"> <li>i. Annually, each pump set shall be tested by qualified and Civil Defence approved personnel, for no flow (churn), rated flow and 150% of pump rated flow along with water discharge through hose and other approved test devices.</li> <li>ii. Any parts that needs to be repaired or replaced shall be handled through Civil Defence approved fire contractor.</li> </ul>