

Table 6.6: Applicability of Emergency Lighting Luminaire

OCCUPANCY	REQUIREMENTS
<ol style="list-style-type: none"> 1. INSIDE FIRE PUMP ROOM, EPS ROOM AND LARGE PLANT ROOMS 2. INSIDE AND OUTSIDE EMERGENCY COMMAND CENTER 3. INSIDE AND OUTSIDE STAIRWAYS 4. INSIDE LIFT LOBBY 5. INSIDE FIRE FIGHTERS LIFT LOBBY 6. IN EXIT CORRIDORS 7. INSIDE EXIT ACCESS CORRIDORS 8. INSIDE EXIT PASSAGEWAYS 9. INSIDE TUNNELS 10. ALL AREAS OF ENCLOSED BASEMENTS AND RAMPS 11. IN SERVICE CORRIDORS 12. OUTSIDE EXIT DISCHARGE 13. RECEPTION 14. LOCATION OF FACP 15. LOCATION OF FIRE HOSE CABINET 16. LOCATION OF FIRE EXTINGUISHER 17. LOCATION OF FIRST AID KIT 18. LOCATION OF SMOKE CONTROL PANEL 19. LPG TANK LOCATION 20. INSIDE HOTEL GUEST ROOM 21. ASSEMBLY SEATING AREAS 22. INSIDE COMMERCIAL KITCHEN 23. KITCHEN DELIVERY AREAS 24. INDOOR LOADING AND UNLOADING AREAS 25. INSIDE LV ROOM 26. INSIDE TRANSFORMER ROOM 27. INSIDE WASH ROOMS 	<p>i. Emergency Lighting Luminaire is mandatory.</p>
<ol style="list-style-type: none"> 28. SCHOOL CLASS ROOMS 29. INSIDE PATIENT SLEEPING ROOMS 30. INSIDE PRISON CELLS 31. SCHOOL OPEN CORRIDORS 32. OFFICES LESS THAN 60 m² 33. INSIDE GARBAGE ROOMS 34. INSIDE TYPICAL FLOOR ELECTRICAL ROOMS 35. INSIDE TYPICAL FLOOR TELEPHONE ROOMS 	<p>i. Emergency Lighting Luminaire is NOT mandatory.</p>