



2.4. Mixed Occupancies

- 2.4.1.** Mixed Occupancy is a multiple occupancy where two or more various occupancies are intermingled without fire resistive assembly separation between them.
- 2.4.2.** Each part of such mixed occupancy shall be classified according to the specific usage as defined by **Table 1.1. Types of Occupancies**.
- 2.4.3.** In Multiple Occupancies, where exit access from an occupancy traverses another occupancy, the multiple occupancy shall be treated (or protected) as a mixed occupancy.
- 2.4.4.** Mixed Occupancies shall be provided with most restrictive Fire Safety requirements of the occupancy involved, including the egress and protection provisions.

2.5. Separated Occupancies

- 2.5.1.** Separated Occupancy is a multiple occupancy where two or more various occupancies shall be compartmented by fire resistive assembly separation between them as per **Table 1.2**.
- 2.5.2.** Such Occupancy separations shall be vertical, horizontal, or both or, when necessary, of such other form as required to provide complete separation between occupancy divisions in the building.
- 2.5.3.** Each part of such separated occupancy shall be classified according to the specific usage as defined by **Table 1.1. Types of Occupancies**.

Table 1.2: Fire rating of fire resistant assemblies to achieve Separation in multiple occupancies

MULTIPLE OCCUPANCIES	WITH SPRINKLERS	WITHOUT SPRINKLERS
1. BETWEEN—Assembly, Residential Apartments, Business, Educational, Day Care, Health care Group B or Group C, Villas, Hotel, Industrial Group C, Storage Group C, Covered Mall	1 Hour	2 Hour
2. BETWEEN—Healthcare Group A and any other occupancies	2 Hour	2 Hour
3. BETWEEN—Detention and Correction and any other occupancies	2 Hour	2 Hour
4. BETWEEN—Mercantile and any other occupancies	1 Hour	2 Hour
5. BETWEEN— Commercial villa and commercial villa (Townhouses)	2 Hour	2 Hour
6. BETWEEN—Industrial Group B or Industrial Group C and any other occupancies	1 Hour	2 Hour
7. BETWEEN—Industrial Group A and any other occupancies	2 Hour	3 Hour
8. BETWEEN—Storage Group B or Storage Group C and any other occupancies	1 Hour	2 Hour
9. BETWEEN—Storage and Storage occupancies	1 Hour	1 Hour
10. BETWEEN—Industrial and Industrial occupancies	1 Hour	1 Hour