

A2. Drawing Submission Requirements

A2.2. General requirements

ANNEXURE 2

·	
Table A2.1: DRAWING SUBMISSION-General Requirements	
ITEM	REQUIREMENTS
5. REASONS FOR REJECTION OF APPLICATIONS	 i. Drawings submitted to Civil Defence will be rejected without review, comments or suggestions if any of the following is true. a. Without required number of files b. Without appropriate file names as per this chapter c. Without coek marking (On e-engineering/online submissions) e. Without coverpage f. Without coolour coding and format in accordance with this chapter h. Without clarifying letter of LPG/Natural gas usage. j. Without clarifying letter of LPG/Natural gas usage. j. Without highlighting exact scope of work in modification/ adjustment/refurbishment jobs with yellow cloud for as approved and red cloud for as revised. k. Submissions with product catalogues, product brochures, company and product licenses. ii. Architecture/Life safety drawings submitted to Civil Defence will be rejected without review, comments or suggestions if any of the following is true. a. Without fire access road layouts. b. Without sections with dimensions. c. Without all floor plans d. Without 1/3 of building diagonal distance between stairs in sprinklered buildings. e. Without 1/2 of building diagonal distance between stairs in nonsprinklered buildings. f. Without separation at discharge level stair between typical floor discharge and lower level or basement discharges. g. Without direct discharge through protected corridor for half the number of building stairs. h. Without fire lift in dedicated shaft for highrise buildings. j. Without fire lift lobby for Superhighrise buildings. j. Without generator room in highrise and Superhighrise buildings. l. Without pump room and water tank locations, sections and details. m. With underground pump room having hatch entry, cat ladder and spiral stair access. n. Without required fire rating of corridors, stairs, LV room, substations, generator rooms, plant rooms, hazardous st

