



2.14. Interior wall or ceiling finish

- 2.14.1.** The tests required for the classifications mentioned in the **Table 2.12.** shall be as per **Section 7** of this chapter.
- 2.14.2.** Interior finish of internal walls and partitions for various occupancies shall be as per **Table 1.12.**
- 2.14.3.** External Fire retardant coatings to achieve the ratings of **Table 1.12.** are not acceptable unless it is existing building. Materials have to achieve the **Table 1.12.** ratings through tests mentioned in **Section 7.**
- 2.14.4.** Where an approved automatic sprinkler system is provided, Class C/Class III interior wall and ceiling finish materials shall be permitted in any location where Class B/ Class II is required, and Class B/ Class II interior wall and ceiling finish materials shall be permitted in any location where Class A/ Class I is required.

Table 1.12: Interior finish of internal walls and partitions.

OCCUPANCY	EXITS	CORRIDORS	OTHER SPACES	CEILINGS	FLOORING
1. ASSEMBLY EDUCATION HEALTHCARE RESIDENTIAL HOTEL DAY CARE	Class A Class 1 Class 2 Class I	Class A Class B Class 1 Class 2 Class I Class II	Class A Class B Class 1 Class 2 Class I Class II	Class A Class B Class 1 Class 2 Class I Class II	Class I Class II
2. BUSINESS DETENTION MERCANTILE	Class A Class B Class 1 Class 2 Class I Class II	Class A Class B Class 1 Class 2 Class I Class II	Class A Class B Class C Class 1 Class 2 Class I Class II Class III	Class A Class B Class 1 Class 2 Class I Class II	Class I Class II
3. PRIVATE VILLA COMMERCIAL VILLA	Class A Class B Class C Class 1 Class 2 Class I Class II Class III	Class A Class B Class C Class 1 Class 2 Class I Class II Class III	Class A Class B Class C Class 1 Class 2 Class I Class II Class III	Class A Class B Class C Class 1 Class 2 Class I Class II Class III	Class I Class II
4. INDUSTRIAL STORAGE	Class A Class B Class 1 Class 2 Class I Class II	Class A Class B Class C Class 1 Class 2 Class I Class II Class III	Class A Class B Class C Class 1 Class 2 Class I Class II Class III	Class A Class B Class C Class 1 Class 2 Class I Class II Class III	Class I Class II