

Table 3.13.: Occupant Load Factors and Exit Capacity Factors

OCCUPANCY	OCCUPANT LOAD FACTOR PER PERSON	STAIR WIDTH PER PERSON	RAMP WIDTH PER PERSON
1. ASSEMBLY, GROUP A,B,C.			
i. Concentrated (Ballroom, Dance floor, Prayer rooms etc.)	0.65 m ² , net 0.9 m ² , net for prayer rooms	7.6 mm	5 mm
ii. Less Concentrated, Outdoors etc. (Meeting rooms, Restaurant, Outdoors etc.)	1.4 m ² , net	7.6 mm	5 mm
iii. Bench Seatings,	455 mm linear	7.6 mm	5 mm
iv. Fixed Seatings	Number of fixed seats	7.6 mm	5 mm
v. Waiting Spaces in theaters, similar spaces	0.28 m ²	7.6 mm	5 mm
vi. Kitchens	9.3 m ²	7.6 mm	5 mm
vii. Library Stacks area	9.3 m ²	7.6 mm	5 mm
viii. Library Reading rooms	4.6 m ² , net	7.6 mm	5 mm
ix. Swimming Pool	4.6 m ² Water surface	7.6 mm	5 mm
x. Swimming Pool Decks	2.8 m ²	7.6 mm	5 mm
xi. Exercise Room with Equipment	4.6 m ²	7.6 mm	5 mm
xii. Exercise Room without Equipment	1.4 m ²	7.6 mm	5 mm
xiii. Stages	1.4, net	7.6 mm	5 mm
xiv. Lighting and Access Catwalks	9.3, net	7.6 mm	5 mm
xv. Casinos and Gaming areas	1 m ²	7.6 mm	5 mm
xvi. Skating Rinks	4.6 m ²	7.6 mm	5 mm
xvii. Food Court Seating areas	1.4 m ²	7.6 mm	5 mm
xviii. Airport Concourse	9.3 m ²	7.6 mm	5 mm
xix. Airport Waiting areas	1.4 m ²	7.6 mm	5 mm
xx. Airport Baggage Claim	1.9 m ²	7.6 mm	5 mm
xxi. Airport Baggage Handling	27.9 m ²	7.6 mm	5 mm
xxii. Theater-Type Seating	Number of fixed seats	7.6 AB See Table 1.17.3.	5.6 C See Table 1.17.3.
xxiii. Museum	5.0 m ²	7.6 mm	5 mm
2. BUSINESS, GROUP A,B,C.			
i. Regular Office areas	9.3 m ²	7.6 mm	5 mm
ii. Concentrated Office areas	4.6 m ²	7.6 mm	5 mm
iii. Air Traffic Control observation levels	3.7 m ²	7.6 mm	5 mm
3. EDUCATIONAL , GROUP A,B,C.			
i. Classroom	1.9, net	7.6 mm	5 mm
i. Shops, Laboratories, Vocational etc.	4.6, net	7.6 mm	5 mm