

Table 3.16.: Commonpath, Dead end and Travel Distances

OCCUPANCY	COMMONPATH	DEAD END	TRAVEL DISTANCE
10. DETENTION , GROUP A,B,C.			
i. For Types II, III, IV	S 30 m, NS 15 m	S 15 m, NS 6.1 m	S 61 m, NS 46 m
ii. For Types V	S 30 m, NS 15 m	S 6.1 m, NS 6.1 m	S 61 m, NS 46 m
iii. Any room exit access door to Exit	S 30 m, NS 15 m	S 15 m, NS 6.1 m	S 46 m, NS 46 m
11. HOTEL			
i. Hotel guest room Main door to exit	S 15 m, NS 10.7 m	S 15 m, NS 10.7 m	S 61 m, NS 53 m
i. Within Guest room to Main door	NA	NA	S 38 m, NS 23 m
12. DAY CARE, GROUP A, B			
i. From any room door to exit door	S 30 m, NS 23 m	S 15 m, NS 6.1 m	S 46 m, NS 30 m
ii. From any point in room to exit door	S 30 m, NS 23 m	S 15 m, NS 6.1 m	S 61 m, NS 46 m
iii. From any point in room to room door	NA	NA	S 30 m, NS 15 m
13. MERCANTILE, GROUP A,B,C.			
i. For Class A,B,C	S 30 m, NS 23 m	S 15 m, NS 6.1 m	S 76 m, NS 46 m
ii. For Open air	S 0 m, NS 0 m	S 0 m, NS 0 m	NA
iii. High Hazard Mercantile	S 0 m, NS 0 m	S 15 m, NS 6.1 m	S 23 m, NS 23 m
14. MALL, GROUP A			
i. Covered Mall	S 30 m, NS 23 m	S 15 m, NS 6.1 m	S 120 m, NS 46 m
ii. Within Tenant space, where provided with pedestrian way is provided as per Table 3.33.2.	S 30 m, NS 23 m	S 15 m, NS 6.1 m	S 76 m, NS 46 m
15. MALL, GROUP B			
i. Open Air Mall	S 0 m, NS 0 m	S 0 m, NS 0 m	NA
16. STORAGE, GROUP A			
i. High Hazard Storage	S 0 m, NS 0 m	S 0 m, NS 0 m	S 30 m, NS 23 m
17. STORAGE, GROUP B,C.			
i. Low Hazard Storage	S 30 m, NS 15 m	S 30 m, NS 15 m	S 122 m, NS 61 m
ii. Ordinary Hazard Storage	S 30 m, NS 15 m	S 30 m, NS 15 m	S 122 m, NS 61 m
iii. Aircraft Storage, ground floor	S 30 m, NS 15 m	S 15 m, NS 15 m	S 30 m, NS 23 m
iii. Aircraft Storage, Mezzanine floor	S 30 m, NS 15 m	S 15 m, NS 15 m	S 23 m, NS 23 m
18. INDUSTRIAL, GROUP A			
i. High Hazard content	S 0 m, NS 0 m	S 0 m, NS 0 m	S 23 m, NS 0 m