4.4. Midrise Building Fire Protection Systems

4.4.3. Midrise buildings having a building height from more than 15 m to less than 23 m and having a single exit stair and built-up ground floor area of up to 500 m² shall be provided with Fire protection Systems in compliance with Table 9.20.c., and Auxiliary Rooms Fire Protection Systems as per Table 9.30.

Table 9.20.c.: Midrise Building Fire Protection Systems		
PREDOMINANT OCCUPANCY	SYSTEM REQUIREMENTS	COMBINED FIRE PUMP SET AND FIRE WATER TANK CAPACITIES
A. RESIDENTIAL GROUP A, B, C.	1. IF BUILT-UP GROUND FLOOR AREA IS UPTO 500 M ² AND A SINGLE EXIT STAIR	1. IF BUILT-UP GROUND FLOOR AREA IS UPTO 500 M ² AND A SINGLE EXIT STAIR
(APARTMENTS, LA-BOR ACCOMMODA-TION, STAFF ACCOMMODATION, HOSTEL) HAVING GROUND FLOOR BUILT-UP AREA OF UPTO 500 m ² AND A SINGLE EXIT STAIR	 i. Sprinklers shall be provided throughout the building including basements and podiums (open as well as closed) as per Section 3.5. ii. A wet riser System shall be provided throughout the building as per Section 3.4. iii. Wet risers shall be interconnected at the highest level. iv. Auxiliary rooms and various areas of the building shall be protected as per Table 9.30. 	 v. Capacity of the fire pump set shall be 500 gpm at pressure as required to satisfy 6.9 bar at the most remote Landing valve. vi. Water tank shall have capacity of 45 minutes of operation, complete with low water level detection, dedicated direct breeching inlet for refilling and instantaneous refilling arrangement for utility water supply.
B. BUSINESS GROUP A, B, C.		
HAVING GROUND FLOOR BUILT-UP AREA OF UPTO 500 m ² AND A SINGLE EXIT STAIR		
C. ANIMAL HOUS- ING GROUP A, B, C.		
HAVING GROUND FLOOR BUILT-UP AREA OF UPTO 500 m ² AND A SINGLE EXIT STAIR		

