

5. Exit Sign Material Test Standards and Approval.

5.1. Acceptable Test Standards and criteria

- 5.1.1.** All the Signage Materials, Systems, Assemblies, Products and Accessories, referred to in this chapter shall be Listed, Approved and Registered by the Civil Defence Material Approval Department.
- 5.1.2.** There is no year of edition mentioned against any test standards. It is the intent of Civil Defence to convey to the customers seeking laboratory tests and the test laboratories to follow the "LATEST EDITION OF THE TEST STANDARD, AS AND WHEN THEY ARE UPGRADED/REVISED/AMENDED, TO THE DATE."
- 5.1.3. Exit Signs**
 - i.** ANSI/UL 924, Standard for Emergency Lighting and Power Equipment.
 - ii.** BS ISO 3864, Standard for Fire Safety Signs
 - iii.** BS 5499-1, Standard for Exit Signs
- 5.1.4. Tactile Signs**
 - i.** UL 924, Standard for Emergency Lighting and Power Equipment.
- 5.1.5. Photoluminescent Signs**
 - i.** UL 1994, Standard for Luminous Egress Path Marking Systems.