

1.7. Clean Agent Systems

1.7.12. Fill Density

Mass of agent per unit of container volume (the customary units are lb/ft³ or kg/m³).

1.7.13. No Observed Adverse Effect Level (NOAEL)

The highest concentration at which no adverse toxicological or physiological effect has been observed.

1.7.14. Lowest Observed Adverse Effect Level (LOAEL)

The lowest concentration at which adverse toxicological or physiological effect has been observed.

1.7.15. Normally Occupied Area

Area that is intended for occupancy.

1.7.16. Unoccupied Area

Area that is intended only for equipment and machinery providing services with periodic visits by personnel for repair and maintenance.

However, with respect to the use of clean agent systems, the LV rooms, transformer rooms, telephone rooms, generator rooms and other such equipment/ machinery rooms located in the occupied buildings or attached to occupied buildings, are not considered as unoccupied area because of the proximity of these rooms to public movement and the possible adverse effects of clean agents.