

Table 1.9.: Fire Resistance Separation and other requirement of incidental accessory /Occupancies.

INCIDENTAL ACCESSORY ROOMS AND OCCUPANCIES	REQUIRED SEPARATION WITH AUTOMATIC FIXED FIRE PROTECTION SYSTEM	REQUIRED SEPARATION WITHOUT AUTOMATIC FIXED FIRE PROTECTION SYSTEM	OTHER CONSTRUCTION AND PROTECTION REQUIREMENTS (See Chapter 9 for Fire Protection requirements Chapter 10 for smoke control requirements)
23. GARBAGE ROOM	1 Hour	2 Hour	 i. Garbage Room shall be located above grade level, on the exterior perimeter of the building. ii. Separation and Compartmentation shall be complete with walls, floor and opening protection. iii. Fire door shall be 60 minutes fire rated.
24. LABORATORIES USING FLAMMABLE OR COMBUSTIBLE LIQUID (See Chapter 13. Flammable Liquids and Hazardous materials)	1 Hour	2 Hour	 i. Separation and Compartmentation shall be complete with walls, floor and opening protection. ii. Fire door shall be 60 minutes fire rated.
25. PAINT SHOPS	1 Hour	2 Hour	 i. Separation and Compartmentation shall be complete with walls, floor and opening protection. ii. Fire door shall be 60 minutes fire rated.
26. PAINT BOOTHS (SPRAY)	1 Hour	2 Hour	 i. Separation and Compartmentation shall be complete with walls, floor and opening protection with non-combustible and approved construction materials. ii. Vapor extract System shall be provided.
27. GIFT SHOPS	1 Hour	1 Hour	 The separation is between gift shop and other occupancies. Front of the gift shop if opens to enclosed mall, open mall, circulation areas, need not be fire resistance rated.
28. MAINTENANCE WORKSHOPS	1 Hour	2 Hour	i. See Chapter 9 for Firefighting requirements.ii. See Chapter 10 for Smoke Control requirements.

