


Table 10.19.: Super Highrise Building Smoke Control System Requirements

LOCATION	SYSTEM REQUIREMENTS
4. FIREMAN'S LIFT LOBBY (FIREFIGHTING LOBBY)	<ul style="list-style-type: none"> i. The fire man's lift and firefighting lobby shall be mandatory for all super highrise buildings. ii. Such fire man's lift and firefighting lobby shall extend to the stairs and connect all levels of the building, including basements. iii. Every fire man's lift in super highrise buildings shall have a firefighting lobby, in accordance with Chapter 1. iv. The firefighting lobby enclosure shall be constructed of smoke partitions, enclosed in one hour fire-resistance rating and shall be arranged as smoke barrier. v. Smoke control or smoke purge shall not be required for firefighting lift shafts or fireman's lift lobby when the fire man's lift is provided with the firefighting lobby. vi. Firefighting stairs shall be pressurized in accordance with Table 10.19.1. vii. See Figure 10.39.



Schematic 10.39.: Fireman's Lift and Fire Lift Lobby (Firefighting Lobby)