

## 2.5. Application of Fire Extinguishers

**2.5.1.** The application of Fire Extinguishers for various hazards shall be as per **Table 4.3.** 

## **Table 4.3: Application of Fire Extinguishers**

## TYPE OF EXTINGUISHER DISTRIBUTION **HAZARD AREA** 1. CLASS A 1. ASSEMBLY i. Each extinguisher of i. Multi-purpose Dry Pow-**FIRES** i. Seating areas size mentioned serves approximately 280 m<sup>2</sup> ii. Corridors der (ONE) iii. Waiting areas 2-A, 20-B, C of the area. iv. Exit routes 4 Kg ii. Maximum travel distance to such an extin-2. BUSINESS guisher shall not be i. Office areas more than 30 m. That is ii. Shops from any point of the iii. Corridors area, there shall be one iv. Exit routes extinguisher within a **AND** distance of 30 m. 3. EDUCATIONAL iii. Extinguishers shall be i. CO2 Type (ONE) i. Corridors placed along the corriii. Reception 5 Kg dors, waiting areas, iii. Auditoriums shops, supermarkets, iv. Assembly halls service corridors, staff v. Locker rooms and reception areas etc., where people can **4. HEALTHCARE** easily find and use i. Patient rooms them during fire acciii. Nurse Stations dents. iii. Corridors iv. As a practice fire extiniv. Waiting areas guishers are placed in v. Exit routes Fire Hose Cabinets in **UAE.** Such cabinets 5. RESIDENTIAL shall clearly have signi. Apartments age that indicates presii. Corridors ence of extinguishers inside the Fire Hose 6. HOTEL Cabinet (FHC) i. Guest Rooms ii. Corridors iii. Reception iv. Dining areas v. Exit routes 7. DAYCARE i. Corridors ii. Reception iii. Exit routes