

Table A2.7.: Minimum Fire and Life Safety requirements for Events

ITEM	REQUIREMENTS
5. EXIT SIGNAGE	<ul style="list-style-type: none"> i. Approved Exit Signs and directional signs with a directional indicator showing the direction of Exit travel shall be installed throughout the area. ii. Exit Signs shall be easily visible from any direction of exit access. iii. Sign placement shall be within rated viewing distance of 30 m. iv. No decorations, furnishings, or equipment that impairs the visibility of a sign shall be permitted.
6. PORTABLE FIRE EXTINGUISHERS	<ul style="list-style-type: none"> i. Portable fire extinguishers in compliance to latest edition of UAE Fire and Life Safety Code of Practice, shall be provided along normal walking paths of exitways and exits, near stages, cooking areas and at 30 m intervals. ii. All the Portable Fire Extinguishers shall be fully charged and ready for use in case of an emergency.
7. OTHER SAFETY REQUIREMENTS	<ul style="list-style-type: none"> i. LPG systems shall not be installed without Civil Defence approval. ii. Flame shows, pyrotechnics shall not be conducted at events without Civil Defence approval. iii. Events shall not be held without Civil Defence approval and inspection. iv. Events organizers shall request for inspection from Civil Defence prior to the event commencement. v. Events organizers shall request for Standby fire trucks and Civil Defence personnel where it is required by the Civil Defence operations department. It is event organizers responsibility to verify with Civil Defence operations department. vi. Smoking and Shisha shall be permitted only at designated areas.
8. EVENT ORGANIZERS RESPONSIBILITY	<ul style="list-style-type: none"> i. Event organizers shall comply with their responsibility in accordance with latest edition of UAE Fire and Life Safety Cde of Practice, Chapter 18. Section 2.21.