



2.13.2. Compartmentation and Subdivisions in occupancies shall be as per **Table 1.11.b.,**

Table 1.11.b.: Compartmentation (Sub divisions) within the same occupancy

OCCUPANCY	COMPARTMENTATION (SUB DIVISIONS) WITH SPRINKLER	COMPARTMENTATION (SUB DIVISIONS) WITHOUT SPRINKLER
12. MERCANTILE GROUP A, B, C.	No requirements	No requirements
13. MALL	<ul style="list-style-type: none"> i. Anchor Units/buildings or bulk merchandising Units more than 1000 m² shall be separated from the Mall by a fire resistance rated wall of the Mall construction type but not less than 2 hour fire resistance rated. ii. Each tenant unit including assembly, business, mercantile, in the mall shall be separated from other tenant Unit/space by fire resistance rated wall/partition of 1 hour fire resistance rating. (Such separation can be up to underside of the ceiling. if ceiling is not provided, separation shall be up to underside of roof). iii. Parking structure within 18.3 m of mall shall be of Type I or Type II construction. 	<ul style="list-style-type: none"> iv. Anchor Units/buildings or bulk merchandising Units more than 1000 m² shall be separated from the Mall by a fire resistance rated wall of the Mall construction type but not less than 2 hour fire resistance rated. v. Each tenant unit including assembly, business, mercantile, in the mall shall be separated from other tenant Unit/space by fire resistance rated wall/partition of 1 hour fire resistance rating. (Such separation can be up to underside of the ceiling. if ceiling is not provided, separation shall be up to underside of roof). vi. Parking structure within 18.3 m of mall shall be of Type I or Type II construction.
14. STORAGE GROUP A	<ul style="list-style-type: none"> i. 1 Hour fire resistance rated walls from foundation to roof shall separate multitenant warehouses as per 1.9.31. 	<ul style="list-style-type: none"> ii. 2 Hour fire resistance rated walls from foundation to roof shall separate multitenant warehouses as per 1.9.31.
15. STORAGE GROUP B, C	<ul style="list-style-type: none"> i. 1 Hour fire resistance rated walls from foundation to roof shall separate multitenant warehouses as per 1.9.31. 	<ul style="list-style-type: none"> ii. 2 Hour fire resistance rated walls from foundation to roof shall separate multitenant warehouses as per 1.9.31.
16. INDUSTRIAL GROUP A	<ul style="list-style-type: none"> i. 1 Hour fire resistance rated walls from foundation to roof shall separate multitenant warehouses as per 1.9.31. 	<ul style="list-style-type: none"> ii. 2 Hour fire resistance rated walls from foundation to roof shall separate multitenant warehouses as per 1.9.31.
17. INDUSTRIAL GROUP B, C	<ul style="list-style-type: none"> i. 1 Hour fire resistance rated walls from foundation to roof shall separate multitenant warehouses as per 1.9.31. 	<ul style="list-style-type: none"> i. 2 Hour fire resistance rated walls from foundation to roof shall separate multitenant warehouses as per 1.9.31.