- 4.4.6. Measurement of remoteness of Exit arrangement in buildings required by Table 3.15. for Lowrise and Midrise buildings shall be as per Figure 3.20.a.
- **4.4.7.** However, the allowance of measuring remoteness by walking distance between exits shall not apply where the arrangement of means of egress is blocked by any one fire or emergency condition which prevents the access to both the exits.
- 4.4.8. Required exit remoteness shall also be required where exits are connected by looped corridors or passageways.



