

Table 9.27.: Storage, Warehouse and Industrial Fire Protection Systems

PREDOMINANT OCCUPANCY	SYSTEM REQUIREMENTS	COMBINED FIRE PUMP SET AND FIRE WATER TANK CAPACITIES
C. MULTI TENANT INDUSTRIES, AND FACTORIES (ORDINARY HAZARD, GROUP 2 CATEGORY ACTIVITIES AS PER DEFINITION 1.1.13.3.c.)	1. IF TOTAL BUILT-UP GROUND FLOOR AREA IS LESS THAN 900 m² AND EACH INDIVIDUAL UNIT COMPARTMENT AREA IS LESS THAN 230 m² i. Hose Reel System shall be provided throughout the building as per Section 3.3. ii. Hose Reel System shall be extended to mezzanine levels, if any. iii. Dry landing valves and risers shall not be required.	1. IF TOTAL BUILT-UP GROUND FLOOR AREA IS LESS THAN 900 m² AND EACH INDIVIDUAL UNIT COMPARTMENT AREA IS LESS THAN 230 m² iv. The capacity of the fire pump set shall be 50 gpm at a pressure as required to satisfy 4.5 bar at the most remote Hose reel outlet valve. v. The water tank shall have a capacity of 30 minutes of operation, complete with low water level detection and instantaneous refilling arrangement.
	2. IF TOTAL BUILT-UP GROUND FLOOR AREA IS MORE THAN 900 m² OR ANY INDIVIDUAL UNIT COMPARTMENT AREA IS 230 m² –UP TO 900 m² i. Sprinklers shall be provided throughout the facility as per Section 3.5. ii. The sprinkler design density shall be 0.20 gpm with area of sprinkler operation of 1500 ft ² (140 m ²). iii. Hose Reel System shall be provided throughout the building as per Section 3.3. No dry landing valves required.	2. IF TOTAL BUILT-UP GROUND FLOOR AREA IS MORE THAN 900 m² OR ANY INDIVIDUAL UNIT COMPARTMENT AREA IS 230 m² –UP TO 900 m² iv. The capacity of the fire pump set shall be 350 gpm at pressure as required to satisfy 4.5 bar at the most remote Hose reel outlet valve. v. The water tank shall have capacity of 45 minutes of operation, complete with low water level detection and instantaneous refilling arrangement.
	3. IF INDIVIDUAL COMPARTMENT OR UNIT AREA IS MORE THAN 900 m² i. Sprinklers shall be provided throughout the facility as per Section 3.5. ii. The sprinkler design density shall be 0.20 gpm with area of sprinkler operation of 1500 ft ² (140 m ²). iii. Hose Reel System shall be provided throughout the building as per Section 3.3. No dry landing valves required.	3. IF INDIVIDUAL COMPARTMENT OR UNIT AREA IS MORE THAN 900 m² iv. The capacity of the fire pump set shall be 350 gpm at a pressure as required to satisfy 4.5 bar at the most remote hose reel valve. v. The water tank shall have a capacity of 60 minutes of operation, complete with low water level detection, dedicated direct breeching inlet and instantaneous refilling arrangement.
	4. IF SUM OF ALL GROUND FLOOR BUILT-UP AREAS IS MORE THAN 3600 m² i. Sprinklers shall be provided throughout the facility as per Section 3.5. ii. Sprinkler design density shall be 0.20 gpm with area of sprinkler operation of 1500 ft ² (140 m ²). iii. Yard Fire Hydrants shall be provided as per Section 3.11. , in a loop to cover the entire facility. iv. Hose Reel System shall be provided throughout the building as per Section 3.3. v. Wet risers and internal landing valves shall not be required.	4. IF SUM OF ALL GROUND FLOOR BUILT-UP AREAS IS MORE THAN 3600 m² vi. The capacity of the fire pump set shall be 750 gpm at a pressure as required to satisfy 6.9 bar at the most remote Hydrant valve. vii. The water tank shall have capacity of 60 minutes of operation, complete with low water level detection, dedicated direct breeching inlet and instantaneous refilling arrangement.