

3. Application of Exit Signs and Directional marking

- 3.1.** The application of exit Signs and Directional marking shall be as per **Table 5.3.**
- 3.2.** The Installation of Exit Signs, Directional Signs and Floor proximity Signs shall comply with **Table 5.2.**

Table 5.3: Application of Exit Signs and Directional Markings

LOCATION	REQUIREMENTS
1. AT EXIT DOORS	<ul style="list-style-type: none"> i. Exit Doors, at exit corridors, providing exits that lead to Exit discharge or to assembly points shall be provided with Exit Signs complying to Table 5.1.1. ii. Doors in Horizontal Exits shall be provided with Exit Signs complying to Table 5.1.1. iii. Tactile Signs, in compliance with Table 5.1.3. shall be installed at every exit location where Exit Signs are required by Table 5.2. iv. Floor proximity Exit signs shall comply with Table 5.1.7.
2. AT EXIT STAIR	<ul style="list-style-type: none"> i. Exit stairs, providing exits that lead to Exit discharge or to assembly points shall be provided with Exit Signs complying to Table 5.1.1. ii. Tactile Signs, in compliance with Table 5.1.3. shall be installed at every exit location where Exit Signs are required by Table 5.2. iii. Floor proximity Exit signs, if provided shall comply with Table 5.1.7.
3. EXIT ACCESS CORRIDORS	<ul style="list-style-type: none"> i. The Directional Signs shall be provided in compliance with Table 5.1.2. ii. Floor proximity Directional signs, if provided shall comply with Table 5.1.7.
4. DEAD ENDS	<ul style="list-style-type: none"> i. NO EXIT signs shall be provided at any door, passage or stair that is neither an exit nor way of exit access and that is located or arranged that it is likely to be mistaken for an exit. ii. NO EXIT sign shall comply with Table 5.1.5.
5. ELEVATOR SIGNS	<ul style="list-style-type: none"> i. Any elevator that qualifies as evacuation elevator as defined in Chapter 3., Section 3.9., shall be provided with Evacuation Elevator Sign in compliance with Table 5.1.6.
6. ASSEMBLY OCCUPANCIES	<ul style="list-style-type: none"> i. Exit Signs and Directional Signs shall be provided as per Section 3. ii. All assembly occupancies shall be provided with Floor proximity Signs as per Table 5.1.7. iii. Tactile Signs, in compliance with Table 5.1.3. shall be installed at every exit . iv. Wash rooms shall be provided with Directional Signs as per Table 5.1.2. v. In special amusement buildings where mazes, mirrors, or other designs are used to confound the egress path, Directional exit marking in compliance with Table 5.1.2., that becomes apparent in an emergency shall be provided. vi. All amusement parks, indoor rides, theme parks, play areas shall be provided with Photoluminescent Exit Marking strips per Table 5.1. 4. vii. Night Clubs and Discos shall be provided with Photoluminescent Exit Marking strips per Table 5.1. 4. viii. Theaters and Cinemas shall be provided with Photoluminescent Exit Marking strips as per Table 5.1. 4. ix. Evacuation Plan shall be provided in each floor and at multiple locations as per Table 5.1.8.