



Table 1.15.b.: EIFS and ETICS on Fire Resistance rated Exterior wall coverings-Test Requirements

OCCUPANCY AND TYPE OF BUILDING	TEST 1 EIFS/ETICS COMPONENTS AND PANEL AS PRODUCT	TEST 2 EIFS/ETICS AS WALL ASSEMBLY
1. ANY BUILDING 2. ANY INSTALLATION 3. ANY AESTHETICS	<p>i. All components of the EIFS (All layers including coating, insulation, mesh, adhesive and finish.) shall be class A when individually tested to ASTM E 84 or UL 723</p> <p>AND</p> <p>ii. NFPA 268 With pass criteria "No Ignition at 12.5 kw/m² at 20 minutes"</p>	<p>iii. ASTM E 119 With pass criteria "1 Hr or 2 Hr OR 3 Hr as per required fire rating of the wall.</p> <p>OR</p> <p>iv. UL 263 With pass criteria "1 Hr or 2 Hr OR 3 Hr as per required fire rating of the wall.</p> <p>OR</p> <p>v. EN 1362-3 With pass criteria "1 Hr or 2 Hr OR 3 Hr as per required fire rating of the wall.</p> <p>OR</p> <p>vi. EN 1362-4 With pass criteria "1 Hr or 2 Hr OR 3 Hr as per required fire rating of the wall.</p>