FICTIONAL SAMPLE SOP — created for the EvidenceLoop demo. Not a real procedure.

SOP FX-03: Fire extinguisher bracket installation

Applies to wall brackets for 6 kg portable extinguishers at marked corridor positions, including Corridor B.

Specified unit: Brackwell BX-6 wall bracket.

Procedure

1. Install a Brackwell BX-6 bracket at the marked position in Corridor B.
2. Fix the bracket to the wall with all four fixings.
3. Mount the bracket so the extinguisher handle is between 1.0 m and 1.2 m above the floor.
4. Seat the extinguisher in both cradles.
5. Fit the FIRE EXTINGUISHER sign directly above the bracket.

Evidence to record

- Before photo of the marked position with the corridor sign visible.
- After photo showing extinguisher, bracket and sign.
- Close-up of the fixings with a tape measure showing the handle height.

This procedure supports verification. It does not replace qualified inspection or certification.