FICTIONAL SAMPLE SOP — created for the EvidenceLoop demo. Not a real procedure.

SOP EL-07: Emergency light replacement

Applies to wall-mounted maintained emergency luminaires above exit doors, including Room 204.

Specified unit: Lumora EL-2040 (3 h maintained, LED). No other model may be installed.

Procedure

1. Isolate the lighting circuit and remove the failed unit.
2. Install the Lumora EL-2040 at the position of the unit it replaces, above the door.
3. Fix the unit flush to the wall with all four fixings.
4. Connect the supply through a 20 mm conduit gland; terminate and close the terminal cover.
5. Restore the supply and confirm the green CHARGE indicator is lit.
6. Press TEST: the unit must illuminate on battery. Record a 5-10 second video of the test.

Evidence to record

- Before photo of the old unit with the room sign visible.
- After photo from the same position, model label and indicator visible.
- Close-up of the fixings and supply entry.
- Functional test video (5-10 s).

This procedure supports verification. It does not replace qualified inspection or certification.