

CALIBRATION CERTIFICATE



Company Information **Alchem Bharuch**

Certificate No.: **ATM00019**

Instrument Number: **141414**

Instrument Details: **Diff. Pr. Transmitter**

MASTER INSTRUMENT DETAILS

Model: **141242**

Last Cal. Date: **2024-10-14**

Make: **dfgdfg**

Range: **1-100**

CURRENT INSTRUMENT DETAILS

Model: **14141**

Last Cal. Date: **2024-10-21**

Make: **Siemens**

Range: **1-100**

CALIBRATION RESULTS

Sr. No.	Ideal Reading		Instrument Reading		Difference		Accuracy in %		Output (mA)		Remark
	Reading	%	UP	Down	UP	Down	UP	Down	UP	Down	
1	1	0	1	1	0.00	0.00	0.00%	0.00%	1	1	
2	25.75	25	25	25	-0.75	-0.75	-2.91%	-2.91%	1	1	
3	50.5	50	50	50	-0.50	-0.50	-0.99%	-0.99%	1	1	
4	75.25	75	75	75	-0.25	-0.25	-0.33%	-0.33%	1	1	
5	100	100	100	100	0.00	0.00	0.00%	0.00%	1	1	