****
* CONT. FROM 1 *
****

CUT PIPE LENGTH

PIECE NO	CUT LENGTH	N.S. (INS)	REMARKS	PIECE NO	CUT LENGTH	N.S. (INS)	REMARKS
<1>	200	2		<2>	1856	2	
<3>	246	2		<4>	100	2	
<5>	120	3/4					

PROJECT: HDPE PLANT AND UTILITY (2146)

OWNER: RAYAN POLYMER POUYA COMPANY

CONTRACTOR: HAMPA ENERGY ENGINEERING & DESIGN COMPANY

DOCUMENT NO.: 2146-ISO-25-0010

LINE NO.: 6"-LC-31002-1P2-HB | ISOMETRIC NO.: ISO-25-1027 | SHT NO.: 2 /3

REF. P&ID DWG.: 3104/8059(1)

REF. PLAN DWG.: 2146-10-20-DD-PI-DWG-0011-12

PRESSURE (barg.)
DESIGN: 1 , FV
OPERATING: ATM

TEMPERATURE (C.)
DESIGN: 130
OPERATING: 100

INSULATION
TYPE: HB
THK (mm): 60

TEST
FLUID: Water
PRESSURE (barg.): 1.5

PAINT: P-4

NDT: A

PWHT: ASME B31.3

LOCATION: AG

LEVEL: 2

LINE CLASS: 1P2

REV.	DATE	DESCRIPTION	PRE'D.	CHE'D BY	APP'D BY
0	01.08.2026	ISSUED FOR CONSTRUCTION	M.IM	R.D	M.A

NOTE
1- ROOT GAPS OF BUTT WELD FITTINGS ARE NOT INCLUDED IN DIMENSIONS
2- ISOMETRIC DRAWING FOR 1 1/2" AND SMALLER PIPINGS ARE JUST FOR INFORMATION. PIPING ROUTING, DIMENSIONS AND ELEVATIONS TO BE CHECKED BY CONSTRUCTION CONSTRUCTOR BEFORE INSTALLATION.
3- FOR 1 1/2" AND SMALLER, SUPPORTS TO BE SELECTED BY CONSTRUCTION CONSTRUCTOR EXCEPT AS NOTED.
4- ACTUAL DIMENSION AND SIZE OF SPECIAL/INSTRUMENT ITEMS SHALL BE CHECKED BEFORE SPOOL FABRICATION BY CONSTRUCTION CONTRACTOR.

Piping Supervision
شرکت رایان پلیمر پویا
(سهامی خاص)
نظارت پایپینگ

THIS DOCUMENT AND THE DESIGN IT COVERS IS THE PROPERTY OF PDQC AND ALL RIGHTS ARE RESERVED. NEITHER IN WHOLE NOR IN PART MAY BE REPRODUCED OR TRANSMITTED TO THIRD PARTY WITHOUT PRIOR WRITTEN CONSENT OF OWNER.