

OREGON STATE HOSPITAL

POLICY ATTACHMENT

PROCEDURES A:	Interim Life Safety Measures (ILSM) Procedures	POLICY: 8.028
----------------------	--	----------------------

POINT PERSON:	Director of Occupational Health and Safety
----------------------	--

APPROVED:	Interim Superintendent	DATE: JULY 31, 2024
------------------	------------------------	----------------------------

SELECT ONE:	☐ New policy attachment	☒ Minor/technical revision of existing policy attachment
	☐ Reaffirmation of existing policy attachment	☐ Major revision of existing policy attachment

I. ILSM PROCEDURES

A. Whenever any life safety system or equipment is out of service or is incapable of operating as designed or per standards due to unplanned hazardous or abnormal conditions (e.g., power outage or flooding) and it cannot be immediately corrected, the following processes must occur:

1. Staff must report the outage to Facilities and Safety Departments
2. The Safety Director or Superintendent must assign an impairment coordinator from the safety or Facility department to comply with requirements for reporting, coordinating, and documenting ILSM.
3. The designated impairment coordinator must immediately evaluate the situation for impact on exiting, compartmentation, fire detection and response systems, ignition sources, storage debris, and other potential hazards; determine its significance per NFPA requirements; and establish a relevant ILSM plan.
 - a. The impairment coordinator must document the findings on the approved Interim Life Safety Assessment form (see attached).
 - i. When ILSM are indicated, the designated impairment coordinator must use the Interim Life Safety Assessment form to identify code deficiencies, construction hazards, and the administrative actions required to compensate for the deficiencies.
 - ii. The impairment coordinator must address each of the required actions identified on the Interim Life Safety Assessment form and document findings, including frequencies for testing, training, monitoring, and evaluation.

- b. At a minimum, ILSM must include the following assessment and plans:
 - i. associated hazards;
 - ii. equivalent exiting, if applicable; and
 - iii. protection of all OSH occupants from fire and smoke by establishing a temporary and equivalent alarm and smoke detection system.
 - c. If indicated, ILSM must:
 - i. provide additional exits to ensure egress,
 - ii. ensure access for emergency responders,
 - iii. provide for additional fire protection,
 - iv. include “Just in Time Refresher Fire Response” integrating changes to exit points and temporary exit routes,
 - v. provide for increased staffing to perform surveillance of the buildings and grounds through a fire watch,
 - vi. build smoke-tight temporary construction partitions or fire barriers,
 - vii. provide additional emergency lighting within the means of egress,
 - viii. temporarily revise the hospital’s emergency evacuation plans, or
 - ix. remove debris from the affected area.
4. The designated impairment coordinator must immediately notify OSFM and the local fire department (*i.e.*, city or county fire responders) of findings and proposed ILSM. Other licensing agencies may be notified dependent on the reason for ILSM implementation.
- a. The impairment coordinator must contact the OSFM via email or phone and provide the name of the facility, location, nature of emergency condition, beginning time and date of the impairment requiring ILSM, and proposed ILSM.
 - b. OSFM or the local fire department may modify the plan as necessary.
 - c. The impairment coordinator must adjust the ILSM plan if directed by OSFM or the local fire department.
 - d. Documentation of ILSM plans must be in writing and be approved by the OSFM prior to implementation in accordance with Oregon Fire Code (2022), Section 901.7.
5. ILSM must be communicated to all appropriate persons at OSH.
- a. The impairment coordinator must submit written recommendations to the Safety Director and Superintendent or their designee.

- b. The impairment coordinator must alert and inform the supervisors in affected areas of the impairment and implemented ILSM.
 - c. The written plan must be submitted to the OSH Environment of Care Committee for informational and documentation purposes.
- 6. The ILSM plan must be implemented immediately after notification to the parties listed above has been completed. ILSM documentation must include the ILSM start time and date and its end time and date.
- 7. The impairment coordinator or designee must assemble necessary tools and materials at the impairment site.
- 8. The impairment coordinator must implement a tag impairment system.
 - a. A tag must be used to indicate that a system, or portion thereof, has been removed from service.
 - b. The tag must be posted at each fire department connection, system control valve, fire alarm control unit, security office, Access Control, and fire command center indicating which system, or part thereof, has been removed from service.
- 9. When an impaired fire protection system or equipment is restored to normal working order, the impairment coordinator must:
 - a. verify necessary inspections and test have been conducted to ensure affected systems are operational,
 - b. gather all inspection or test reports from third-party vendors,
 - c. advise supervisors of affected areas that protection is restored,
 - d. advise the local fire department, OSFM, and other notified licensing agencies that protection is restored,
 - e. remove the impairment tag, and
 - f. document required information, including the time and date the ILSM ended.
- 10. All documentation, including tags, must be completed and filed.

Documentation must be maintained for a minimum of five years, unless otherwise indicated by external regulations.
- B. The impairment coordinator must notify OSFM and the local fire department whenever required fire protection systems are out of service for four or more hours or when a sprinkler system is out for ten or more hours in a 24-hour

period during planned outages or non-emergency conditions for scheduled system testing or maintenance.

1. Planned outages or non-emergency conditions must be authorized by the designated impairment coordinator.
2. Before authorization is given, the impairment coordinator must inspect the areas or buildings involved for impact on exiting, compartmentation fire detection and response system, ignition sources, storage debris, and other potential hazards, and determine risks using the most current ILSM Assessment form.
3. The building must either be evacuated, or an approved fire watch must be provided for all occupants left unprotected by the outage until the condition has been corrected. Other ILSM must also be implemented as appropriate.
4. Processes for emergency conditions or unplanned outages processes must be completed as indicated above in this policy.