

OREGON STATE HOSPITAL

POLICY

SECTION 8: Safety, Emergency Management **POLICY: 8.022**

SUBJECT: Code Red Response

POINT PERSON: Environmental Safety Manager.

APPROVED: Jim Diegel

Interim Superintendent

DATE: JANUARY 15, 2026

SELECT ONE: ☐ New policy

☐ Minor/technical revision of existing policy

☐ Reaffirmation of existing policy

☒ Major revision of existing policy

I. PURPOSE AND APPLICABILITY

- A. This policy establishes Oregon State Hospital (OSH) Code Red (fire) response procedures and fire drill requirements.
- B. This policy applies to all staff.

II. POLICY

- A. Fire drills are conducted regularly to verify all staff possess the knowledge, skills, and abilities to perform duties during an actual fire emergency.
- B. Fire drills are, at minimum, conducted according to work area within OSH as follows:
 - 1. At least once annually in non-patient care areas;
 - 2. At least quarterly on each core shift (swing, noc, and day) in each patient care area.
- C. Staff must fully participate in Code Red drills as indicated in Procedures A, and B, and must follow Procedure C regarding carbon monoxide response in the Salem cottages.
 - 1. Staff response to a Code Red drill must follow the established protocols to ensure that the response is appropriate. Staff must follow instructions from Access Control, emergency personnel, and the Code Red drill coordinator.

2. Staff must be familiar with the evacuation or relocation map for their work area.
 3. Evacuation or relocation maps are posted in each work area in accordance with relevant accreditation requirements.
- D. Staff shall be provided fire response training during New Employee Orientation (NEO) and annually per policy 9.002, "Training for Staff."
- E. Oregon State Hospital (OSH) follows all applicable regulations, including federal and state statutes and rules; Oregon Department of Administrative Services (DAS), Shared Services, and Oregon Health Authority (OHA) policies; and relevant accreditation standards. Such regulations supersede the provisions of this policy unless this policy is more restrictive.
- F. Staff who fail to comply with this policy or related policy attachments or protocols may be subject to disciplinary action.

III. DEFINITIONS (SEE GLOSSARY)

IV. PROCEDURES

- | | |
|--------------|--|
| Procedures A | Patient Care Area Code Red Response |
| Procedures B | Non-Patient Care Area Code Red Response |
| Procedures C | Cottage Carbon Monoxide Detector Evacuation Response |

V. ATTACHMENTS

- | | |
|--------------|-------------------------------|
| Attachment A | Salem Campus Evacuation Maps |
| Attachment B | Junction City Evacuation Maps |
| Attachment C | Salem Campus Fire Zone Map |

VI. RELATED OSH POLICIES AND PROTOCOLS

8.028 Interim Life Safety Measures

VII. REFERENCES

42 CFR § 482.41

Joint Commission Resources, Inc. (2025). *The joint commission comprehensive accreditation manual for hospitals*, EC.02.03.01. Oakbrook Terrace, IL: Author.

Joint Commission Resources, Inc. *The joint commission comprehensive accreditation manual for hospitals*, EC.02.03.03. (2025). Oakbrook Terrace, IL: Author.

SUBJECT: Code Red Response

POLICY NUMBER: 8.022

DATE: January 15, 2026

PAGE 3 OF 3

Joint Commission Resources, Inc. (2025). *The joint commission comprehensive accreditation manual for hospitals*, EC.02.03.05. Oakbrook Terrace, IL: Author.

National Fire Prevention Association 101 2012 edition 18.7.1.2. Author.

Oregon Fire Code §§ 402.1 — 408.12.5. Author.