



To: Historic and Architectural Review Commission (HARC)
From: Jonna Wensel, Historic Preservation Director
Meeting Date: March 16, 2022
RE: New Construction - VooDoo Lounge Site

PROJECT TITLE: VooDoo Lounge Affordable Housing (*continued from the February 2, 2022 special HARC meeting*)

SUMMARY: Consideration of applications for **A)** the Insubstantial alteration to a non-designated structure (Marshal's Department Building) which does not increase its floor area, per LUC 7-203.D.4; **B)** the Insubstantial demolition of a non-designated secondary structure (shed) within the THLD, per LUC 7-203.D.7; **C)** the Minor-Scale alterations to a rated structure (Contributing shed 5SM.1606) which does not increase its floor area, per LUC 7-203.C.8; **D)** the Small-Scale demolition of a non-designated principal structure (VooDoo Lounge) within the THLD, per 7-203.B.8; and **E)** the Preliminary Large-Scale new construction in the Commercial zone district which will contain more than 5,000 s.f. of floor area, per LUC 7-203.A.2.

LEGAL DESCRIPTION: Lots 1 & 3, portions of Lots 2, 4, 6 & 8, and vacated alley ROW, Block 10, TOT

ADDRESS: TBD, 200 Block of East Pacific Ave. / TBD S. Willow Ave.

ZONE DISTRICT: Commercial

OWNER: Town of Telluride

APPLICANT: CCY Architects

STAFF MEMBER: Jonna Wensel, Historic Preservation Director

LAND USE

FLOOD HAZARD AREA: not in a Flood Zone

GEOLOGIC HAZARD AREA: not in a geologic hazard area

GROUNDWATER ZONE: Zone 2, depth at 5-20 feet

WETLANDS: not in wetlands

NATIONAL HISTORIC LANDMARK DISTRICT (NHLD): inside the district

TREATMENT AREA: Warehouse Commercial (WC) & the River Park Corridor Overlay (RPC)

ATTACHMENTS

- Revised Project Narrative provided by the applicant dated 2-28-2022
- Response to Feb. 2, 2022 HARC Conditions, provided by applicant
- Revised Drawings provided by applicant dated 3-7-2022
- Staff memo and plans from the Feb. 2, 2022 HARC review

PROJECT DESCRIPTION

This project proposes the following:


- Demolition of the Community Room, the VooDoo Lounge Studios, the non-historic shed, and the skatepark.
- Alteration to Marshal's Department Building
- New construction of affordable housing, commercial space, and on-site parking
- Rehabilitation of the Contributing shed
- Relocation of the Free Box
- New construction of public restrooms

PUBLIC NOTICE

This item was properly noticed per LUC Section 5-204.B.1. The affidavit of posting is on file in the Preservation Department.

SITE SUMMARY

The site is located on the northwest corner of East Pacific Avenue and South Willow Street, to the west of the Post Office. It is located inside the Telluride Historic Landmark District (THLD). Currently on the site are a Contributing shed (THAS 1606), a non-historic shed, a skateboard park, the non-historic VooDoo Lounge artists' studios, and the Community Room and Marshals' Department. Adjacent to the west is a Contributing structure known as "The Good Time Society" and the old Telluride jail.



Pursuant to Land Use Code Section 3-212.B Note 2, the frontage of the building for the purpose of determining the required 35' residential use setback is Willow Street. This will be reflected at Final HARC review.

DEVELOPMENT REVIEW HISTORY

- Jan. 27, 2022: A Conceptual PUD application was reviewed and approved by the Planning and Zoning Commission, including the proposed maximum height of 40' for a portion of the building
- Feb. 2, 2022: HARC held a work session to discuss the proposed PUD and reviewed the Preliminary development plan, which was continued to March 16, 2022
- Mar. 16, 2022: HARC will provide a review and recommendation on the Preliminary Subdivision and Preliminary PUD applications

LAND USE CODE CONSIDERATIONS

Section 3-212: Commercial Zone District: *The purpose of the Commercial Zone District (C) is to allow land to be used for retail and service commercial establishments and uses, affordable housing, together with accommodations uses. Some recreation, multi-family residential, accessory and institutional uses may also be appropriate, especially those that strengthen the Town's commercial core.*

A Planned Unit Development (PUD) is proposed, which will request variations to certain dimensional requirements, as noted in the chart below.

Dimensional Limitations	Required by LUC	Proposed/ PUD	Compliant
Minimum Lot Width:	25'	100' (Willow St.)	Yes
Minimum Lot Front:	25'	100'	Yes
Minimum Lot Area:	2,500 s.f.	17,540 s.f. per PUD	Yes
Maximum Lot Area:	11,750 s.f.	17,540 s.f. per PUD	Yes
# Dwellings:	Multi-family use by right	29	Yes
Minimum Setbacks:			
Front (Willow St.)	No limit	0'	Yes
North Side (Alley)	No limit	0'	Yes
South Side (Pacific)	No limit	0' – varies	Yes

Rear (West Side)	No less than 5'	5'	Yes
Max Primary Façade Width	50', unless modified by HARC. No more than 75'	37'-10" (Willow) 42'-6" (Pacific)	Yes
Max Floor Area:	Up to 2.25:1 (39,465 s.f.)	33,241 s.f. (was 34,061 s.f.)	Yes
Max Site Coverage:	No limit	NA	NA
Max Height of Principal Building:	Up to 40' per PUD	40' per PUD	Yes
Roof Pitch	No limit	Pitches vary on gables & sheds / flat	Yes
Parking	31 spaces	32 spaces	Yes

DESIGN GUIDELINES CONSIDERATIONS

The "Warehouse Commercial" and "River Park Corridor Overlay" sections of the Design Guidelines apply to the entire project. The "Rehabilitation Standards" and "Alley, Shed, and Secondary Structure Standards" apply to the historic shed. The "Exterior and Site Lighting Standards" will be applied at the Final review. A complete analysis of the guidelines was provided in the February 2, 2022 staff memo.

Typically, HARC reviews items related to mass, scale, form and other macro design items during review of the Preliminary Application, and reviews details such as windows, materials, and architectural elements with the Final Application. HARC reviewed the initial application at the February 2, 2022 Special HARC meeting, and continued it with 11 conditions. Please see the applicant's narrative for information about how they worked to address each condition. Staff's analysis of HARC's conditions is provided below.

Design Principles

1. Keep it simple.
2. Keep it in scale.
3. Respect historic resources.
4. Make all new design compatible with the existing context.

Feb. 2, 2022 HARC Condition	Staff Analysis
<i>1. Consider setting back the balcony at the rear property line to maintain the traditional spacing from the historic crib, consistent with WC#15.B, WC#15.B.1, and WC#15.B.2.</i>	The balcony at the southwest corner has been set back 5 feet from the west property line.
<i>2. Reduce the height of the parapet at the southwest balcony, consistent with WC#21.A and WS#21.A.1.</i>	The height of the parapet at the southwest balcony has been reduced by 10 inches.
<i>3. Revise the asymmetrical gables along Pacific Ave. to a more traditional roof form, consistent with WC#24.C.POLICY and WC#24.C.3.</i>	The gables have been revised to symmetrical gables along the south façade. Two symmetrical gables have been added to the west façade.
<i>4. Revise the blue glazed brick to maintain the existing range of exterior wall materials found in this treatment area, consistent with WC#32.A and WC#32.A.3.</i>	The brick has been revised to a more traditional type of brick. Accents are shown in gray or blue brick. Materials and details will be reviewed at the Final stage.

5. Provide details of the historic shed replacement windows, consistent with RE#8.A and RE#8.D.	Details will be provided at Final. Condition retained.
6. Provide details of the new shed doors, consistent with RE#9.	Details will be provided at Final. Condition retained.
7. Provide details of the shed's new foundation, consistent with RE#10.A.	Details will be provided at Final. Condition retained.
8. Break up the Pacific Street façade to have the appearance of three separate buildings versus two presently WC#21.D.3, WC#1, WC#2.A, WC#5.A, WC#21.A, WC#21.D, WC#21.E, WC#21.F, WC#21.G, WC#22 - all the items in Article 21.	The Pacific Ave. façade has been revised to further break up the massing into three prominent masses at the sidewalk edge. A gap of 8 feet separates the two eastern brick commercial facades and a gap of almost 15 feet separates the gabled residential masses.
9. Reduce the height of the commercial and residential buildings on Pacific and Willow, as well as the alley, per 21.C.1, WC#6, WC#6.A, and WC#33.A.	The overall height of the project has not been reduced, but it has been reconfigured. The height of the flat roofs at the east end have not changed from the previous height of 36.3'. The height of the west end has been reduced from 36.3' to 35', which is the average height of the gables. A new shed roof has been added adjacent to the elevator overrun, which adds more area at the 40' average height. HARC is encouraged to discuss these revisions.
10. Step back the third floor along Pacific, Willow, the Willow Street modules surrounding the historic shed, alley, and the northwest corner, per WC#21.C.1, WC 21 Intro, and 25.A.1, 21#B.2, WC#21.A.2 WC#A.3, and WC#21.A.	The third-floor setbacks have been increased on the Pacific and Willow elevations and at the northwest corner. The third-floor setback around the historic shed has increased overall, although it was decreased in a small area of the northeast corner.
11. Either reduce the height and/or increase the setback to the historic blue crib house as per WC#21.A.1.	The height has been reduced and the setback has been increased to minimize the scale between the new project and the historic blue crib.

STAFF FINDINGS AND RECOMMENDATION

The revised proposal incorporates increases to the setbacks on all sides. The building has been moved away from the historic blue crib an additional 5 feet at the ground level, consistent with WC#21.A. This one-story mass at the southwest corner better relates to the historic structure to the west.

The height of the two-story southeastern module is about 30 feet, which is 5 feet less than the maximum allowed height of 35 feet, consistent with WC#21.C.2. The third story has been set back 14'-6" from Willow Street at the southeast corner, consistent with WC#25.A.1.

The mass along Pacific Avenue has been anchored with one- and two-story commercial modules at the east and west corners, consistent with WC#21.C. The modules along Pacific Avenue are broken up by variations in façade treatments, setbacks, and rooflines, consistent with WC#21.D.3 and WC#21.E. 2. The larger three-story residential facades have been set

back from Pacific Ave. an average of about 8 to 9 feet, and the greater mass and height is at the interior of the lot, consistent with WC#21.B.2. Planted areas and site walls are proposed along the gabled modules facing Pacific, consistent with WC#6.E, however, these three-story modules should provide greater stepping down to the street to enhance the pedestrian scale, consistent with WC#6.C, which has been added as a new condition.

Additional mass and height have been added to the center of the project with a second shed roof form near the elevator overrun. This area is to be included in the PUD request for the maximum height up to 40 feet. It is set back 29'-6" from Pacific and 68'-7" from Willow.

The height of the west façade is compliant with the 35' maximum. The gables increase the overall perceived height by a couple of feet, but generally reduce the perceived mass, and the gables relate to the west-facing gable of the blue crib.

Demolition of non-designated shed and the Voodoo Lounge/Studios were approved unanimously at the February 2, 2022 special HARC meeting.

PROPOSED MOTION FOR PRELIMINARY REVIEW

I move to _____ (approve OR continue to the April 20, 2022 regular HARC meeting) the Insubstantial alteration to a non-designated structure (Marshal's Department Building); Minor-Scale alterations to a rated structure (Contributing shed 5SM.1606); and Preliminary Large-Scale new construction, located at Lots 1 & 3, portions of Lots 2, 4, 6 & 8, and vacated alley ROW, Block 10, TOT, based on the findings in the staff memo dated March 16, 2022, and with the following conditions:

- 1. Enhance the pedestrian scale at the ground level of the gabled modules facing Pacific Ave., consistent with WC#6.A, WC#6.C.*
- 2. Provide details of the historic shed replacement windows, consistent with RE#8.A and RE#8.D.*
- 3. Provide details of the new shed doors, consistent with RE#9.*
- 4. Provide details of the shed's new foundation, consistent with RE#10.A.*

This motion is based on evidence and testimony provided at a public hearing held on March 16, 2022, with notice of such hearing provided as required by the Telluride Land Use Code.