

Modelling of a fully renewable energy grid with hydrogen storage: time aggregation for a scalable Capacity Expansion Problem

Bianca Urso · Gabor Riccardi

Received: date / Accepted: date

Abstract In recent years, the integration of renewable energy sources into electrical grids has become a critical area of research due to the increasing need for sustainable and resilient energy systems. To address the variability of wind and solar power output over time, electricity grids expansion plans need to account for multiple scenarios over large time horizons. This significantly increases the size of the resulting Linear Problem (LP), making it computationally challenging for large scale grids. To tackle this, we propose an approach that aggregates time steps to reduce the problem size, followed by an iterative refinement of the aggregation, in order to converge to the optimal solution. Using the previous iteration's solution as a warm start, we introduce and compare methods to select which time intervals to refine at each iteration. The first method employs a validation function, which evaluates with a Rolling Horizon method the feasibility of the aggregated solutions and selects the time interval on which the validation fails. The second method uses the proportion of net power production in each time step relative to the aggregated time interval. These selection methods are then compared against a random interval selection approach.

Keywords Electric power system · Stochastic Programming · Rolling Horizon · Time aggregation · Renewable Energy

Mathematics Subject Classification (2020) 90-10 · 90B15

B. Urso
IUSS School of Advances Studies, Palazzo del Broletto, Piazza della Vittoria, 15 – 27100
Pavia PV, Italy
Tel: +39 0382 375811
Fax: +39 0382 375899
E-mail: bianca.urso@iusspavia.it

G. Riccardi
Dipartimento di Matematica "F. Casorati" Via Adolfo Ferrata, 5 – 27100 Pavia

1 INTRODUCTION

The threat of climate change is pushing policy-makers to pursue greater integration of renewable energy sources into electrical grids, while at the same time ensuring reliability and resilience through digital optimization of electric power distribution and transmission in smart grids [3]. One of the main difficulties arising when designing an electric power system relying on renewables is the great variability of the generation of electricity through wind and solar, since these resources are highly dependent on weather conditions. To deal with this variability, a possible solution gaining a lot of traction in recent years is the introduction of an energy storage system relying on hydrogen, converting energy from hydrogen to electricity and vice versa in fuel cells and electrolyzers [2], [16]. It is of interest to evaluate the optimal solution, in terms of investment plan, to supply the grid along with industrial hydrogen demand in a dependable way. The stochastic nature of the problem though makes it impossible to plan long-term by optimizing on forecasts, and requiring a statistical approach to ensure a robust model.

Up to now, common approaches have adopted Stochastic Programming (SP) or Robust Optimization (RO) models, along with hybrid models involving Information Gap Decision Theory or Chance Constraint [11]. While initially favored, the SP approach comes with high computational burden, so RO models have seen more popularity in recent years, despite the drawback of being conservative methods with higher average cost of operation and planning of energy systems.

In the typical setting, the problem to solve is a Capacity Expansion Problem (CEP) regarding infrastructure investments: solar and wind farms, fuel cells, hydrolizers, grid upgrades to augment Net Transfer Capacity (NTC) and so on. Nested within the CEP is an Economic Dispatch (ED) problem concerning the operational costs of said infrastructure. The problem is well suited to be modelled through mixed integer linear programming (MILP), as is explained in detail in [12] and ((other examples?))

The CEP for investment planning requires to look at long time horizons, and on the other hand intra-day variability in generation is the main complexity driver for the ED problem, so the time horizon must be modelled by a large quantity of fairly tight time steps. Furthermore, Large scale grids can be modelled with various degrees of spacial aggregation, as is explored in [8] and [1], and problem size increases more than linearly with the number of nodes. Thus the temporal and spacial characteristics of the model bring the MILP size to increase rapidly. This is especially demanding in the case of SP, since all the variables from the inner ED problem must be reproduced over all scenarios.

To reduce these costs, one possible approach is to use a Rolling Horizon (RH). The basic technique is described in [5], along with some results regarding quality guarantees for the optimality of the solution. In [14], a rolling horizon approach is used within a RO model to optimize the operation of a micro-grid composed of two PV systems, a wind turbine, a diesel generator and a lead-

acid battery for storage, serving an isolated area in Chile. [other examples of RH used for the ED - see Dagdougui?](#). A similar idea is applied in [7], where integer variables representing capital investments are initially relaxed and then progressively fixed in successive time steps, reducing the computational costs associated to the search for integer solutions.

A big drawback of the RH approach is that the solution it provides is not optimal on the whole time horizon. Indeed [9] explores the effect of short-term planning with limited foresight compared to perfect foresight optimization. On the other hand, the RH approach better reflects actual decision making based on information that is only available progressively, which is the case for the management of energy system planning relying on weather forecasts.

In our work, we build a LP model of a large scale electrical grid powered by wind and solar power generation and supported by hydrogen storage. The LP aims to solve the CEP for the design of the grid, stochastically on the scenarios for the inner ED problem. We present our attempt at dealing with the great computational requirement by building a hybrid model, exploring the use of the RH method as a tool to guide progressively tighter relaxations of the perfect foresight model, rather than as a stand-alone technique.

Further, RH is then used for the validation of the results for the CEP obtained in the perfect foresight optimization, to ensure that given a solution to the CEP, the ED problem admits feasible solutions even in a limited-foresight environment. The idea is to solve the CEP as to build a grid that can be operated as a "smart grid", through a control system that optimizes on day ahead forecasts. Finally, to generate the scenarios needed to train and test the SP model, a Gaussian Copula method was used. This has been previously done by [15].

This paper is organized as follows. Section 2 describes the formulation of the LP problem: the first subsection details the perfect foresight model, and the second adapts the structure from the first to the RH approach.

Section 3 deals with time aggregation. In subsection 3.1 it is shown that the aggregated LP is a relaxation of the disaggregated one; In subsection ??, the structure of the constraint matrix is explored to derive conditions under which the aggregated solution is feasible for the disaggregated problem. Finally, in subsection ?? a method is proposed to iterate through progressively finer time aggregations, in order to select the interval to disaggregate. [CHECK](#)

Section 4 contains the computational results: some example outputs from the perfect foresight LP are explored, then the three aggregation-iteration methods are compared over time and number of iterations for convergence.

An appendix is given detailing the scenario generation method used to generate the input scenarios for the model.

2 MODEL

2.1 LP Formulation

Our model describes a network in Europe that is to be powered and supplied of hydrogen through power generated by photovoltaic panels and wind turbines, converted to hydrogen through electrolysis and potentially reconverted in fuel cells.

The network is represented by an undirected multigraph $\mathcal{G} = (\mathcal{N}, \mathcal{E})$, where \mathcal{N} corresponds to the nodes in the network, and $\mathcal{E} = \mathcal{E}_H \cup \mathcal{E}_P$ represents transmission lines ($e \in \mathcal{E}_P$) and hydrogen lines ($e \in \mathcal{E}_H$). Each of these nodes can be in different countries in Europe, and the power generated by wind and solar power depends on the node location. In particular, if node $n \in \mathcal{N}$ is in France, the scenarios for power generation at n will be generated using parameters fitted to France's data.

Each node has its generators, hydrogen storage, fuel cells and hydrolyzers, for which the capacity is to be decided. Likewise, the CEP aims to solve for transmission line NTC and hydrogen pipe transmission capacity for each edge of the network. The basic formulation of the LP described in this subsection allows us to solve the CEP with perfect foresight.

We decided to model our problem as a LP problem instead of MILP, as would be standard in the literature. This is because when modelling a large grid with high demand, optimizing on continuous variables and then rounding up to the closest integer for variables ns and nw notably decreases computational costs, without relevant difference in the final cost. The same wouldn't be possible when optimizing over micro-grids.

The model takes in input the generation and load scenarios of the given area along with various parameters indicating costs and efficiency of the current state of technology and possible upper bounds for the decision variables. The CEP and the ED problems for all scenarios are solved concurrently. When optimizing over multiple scenarios jointly, the solver returns the minimal amount of infrastructure and capacities that is needed to have feasibility (that is, demand met at all time and no blackouts) over all scenarios in input, with minimal cost. Cost is considered to be the sum of capital costs and average operational costs of the infrastructure over the scenarios.

The optimization problem is solved using the Gurobi solver [6].

2.1.1 Decision Variables

The main variables that are of interest to the policy maker are, for each location n , the number of wind turbines and PV panels to install, as well as hydrogen storage capacity. Stored hydrogen is considered to be the total of liquid and gas hydrogen to be stored. Our model does not assume a distinction between the two forms, and considers hydrogen to be immediately ready for long-term storage as soon as it is converted from electricity, as well as in-

Table 1 Decision variables

| Name | Unit | Description |
|---------------------|------|-----------------------------------------------------------------------|
| ns_n | - | Number of solar units at node $n \in \mathcal{N}$ |
| nw_n | - | Number of wind units at node $n \in \mathcal{N}$ |
| nh_n | kg | Storage capacity at node $n \in \mathcal{N}$ |
| $mhte_n$ | kg | Maximum hydrogen to electricity capacity, at node $n \in \mathcal{N}$ |
| $meth_n$ | MWh | Maximum electricity to hydrogen capacity at node $n \in \mathcal{N}$ |
| $addNTC_l$ | MWh | Additional net transfer capacity on line $l \in \mathcal{E}_P$ |
| $addMH_l$ | kg | Additional hydrogen transfer capacity on pipe $l \in \mathcal{E}_H$ |
| $H_{j,t,n}$ | kg | Stored hydrogen at node n , time t , scenario j |
| $HtE_{j,t,n}$ | kg | Hydrogen converted to electricity at time t , scenario j |
| $EtH_{j,t,n}$ | MWh | Electricity converted to hydrogen at time t , scenario j |
| $P_edge_{j,t,l}^+$ | MWh | Power passing through line l at time t , scenario j |
| $P_edge_{j,t,l}^-$ | MWh | Power passing through line l at time t , scenario j |
| $H_edge_{j,t,l}^+$ | kg | Hydrogen transported through line l at time t , scenario j |
| $H_edge_{j,t,l}^-$ | kg | Hydrogen transported through line l at time t , scenario j |

stantaneously convertible to electricity in fuel cells at need. For more detailed models of the management of hydrogen see [?].

Important values to consider when planning the grid are the power capacity and conversion speed of fuel cells and electrolyzers: variables $mhte_n$ and $meth_n$, indexed by node n , indicate for each location the maximum amount of energy that can be converted at a single time step respectively from hydrogen to electricity and vice versa. These values are essential to estimate in order to design a grid that can effectively accommodate peak production and supply during low production periods.

explain what NTC is? quote paper. Existing NTC is estimated through the procedure followed by link (page 30) - *domanda nella mail*, by collecting data from link. Improvements on the existing capacity for power lines or hydrogen transport infrastructure are considered through variables $addNTC_l$ and $addMH_l$. Indeed, upgrades to the European grid's transfer capacity are currently considered a key element for the integration of renewables [?].

Variables linked to the inner ED problem are indexed by scenario j , time step t , and either node $n \in \mathcal{N}$ or edge $l \in \mathcal{E}_H$ or $l \in \mathcal{E}_P$. For the variables pertaining to transmission on an edge, two distinct variables are considered, one for each direction. This way, all variables are set to be non-negative. This will be relevant for the formulation of the time-aggregated relaxation of the LP problem.

See Table 1 for the summary of all decision variables.

2.1.2 Parameters

There are numerous parameters that describe the grid and are passed to the model. The main ones are related to capital costs of the infrastructure to be built and the following values are assumed for panels and turbines: $cs = 400\text{€}$, $cw = 3000000\text{€}$. We also set capital costs for fuel cells and electrolyzers: since hydrogen infrastructure is usually obtained by reconvertig existing infrastructure from other purposes, the estimation of investment costs is very location dependent and beyond the scope of this work [?]. Thus for our purposes, instead of representing the actual investment for the facilities, a minimal "symbolic" cost is assigned per unit of capacity, so that in minimizing the model estimates needed conversion capacities $mhte_n$ and $meth_n$.

The storage of the hydrogen has a cost that depends on various factors: capital cost of the technology used for storage, operating costs, length of time that the hydrogen is kept in storage. For our model we only set the parameters ch , to be multiplied by the maximum storage needed (nh), representing capital cost of storage infrastructure. We ignore marginal costs of keeping the hydrogen stored.

In this model we assume no marginal costs for PV and wind power production: the operating costs of the farms throughout their life-cycle can be factored into the capital costs, and there is no additional cost linked to the production itself.

Conversely, the marginal costs of conversion within electrolyzers and power cells are relevant. According to the European Hydrogen Market Landcape November 2023 Report [13], "Hydrogen production costs via electrolysis with a direct connection to a renewable energy source in Europe vary from 4.18 to 9.60 €/kg H₂ of hydrogen, with the average for all countries being 6.86 €/kg H₂". For electrolyzers, we consider the Levelised cost of hydrogen (LCOH) to account for both marginal costs and capital costs. Such cost is dependent on the country's specific market condition and can be calculated through the European Hydrogen Observator tool [?].

Parameters $fhte_n$ and $feth_n$ are set as scalars between 0 and 1 to indicate efficiency of the conversion from hydrogen to electricity and vice versa. It is assumed that 1kg of hydrogen has an energy value of 33kWh [?]. Thus if we consider an electrolyzer operating at maximum efficiency ($feth = 1$), one MWh of electricity yields $1000/33 \simeq 30\text{kg}$ of hydrogen. For our purposes, a standard value of $feth = 0.66$ is considered, thus 1MWh yields 20kg of hydrogen. Conversely, in a fuel cell operating at maximum efficiency ($fhte = 1$) 1kg of hydrogen yields 33kWh. We consider a value of $fhte = 0.75$, yielding 24.75kWh per kg of hydrogen. Actual efficiencies vary a lot depending on the technology used. Furthermore, chemical and physical constraints make it so that efficiencies higher than 0.80-0.85 are currently considered unachievable [4].

Additionally, we assume the flow of electricity has no marginal cost nor power loss (the modelling of that problem is beyond the scope of this project), whereas we do set a cost for the use of hydrogen pipes (or other means of

Table 2 Model parameters

| Name | Unit | Description |
|--------------|-------|-------------------------------------------------------------------------|
| cs | € | Cost of one Solar Panel at node n |
| cw | € | Cost of one Wind Turbine at node n |
| $chte_n$ | €/kg | Conversion cost of hydrogen to electricity |
| $ceth_n$ | €/MWh | Conversion cost of electricity to hydrogen |
| ch_n | €/kg | Cost of hydrogen storage capacity |
| cH_edge_l | € | Cost of transferring 1kg of hydrogen through edge $l \in \mathcal{E}_H$ |
| $cNTC_l$ | €/MWh | Cost of adding NTC to line $l \in \mathcal{E}_P$ |
| cMH_l | €/kg | Cost of adding hydrogen transfer capacity to line $l \in \mathcal{E}_H$ |
| $cmhte$ | €/kg | Cost of needed HtE capacity per unit |
| $cmeth$ | €/MWh | Cost of needed EtH capacity per unit |
| $fhte_n$ | - | Efficiency of hydrogen to electricity conversion |
| $feth_n$ | - | Efficiency of electricity to hydrogen conversion |
| NTC_l | MWh | Net Transfer Capacity on line $l \in \mathcal{E}_P$ |
| MH_l | kg | Hydrogen transfer capacity on edge $l \in \mathcal{E}_H$ |
| Mns_n | - | Maximum number of solar panels installable at node n |
| Mnw_n | - | Maximum number of wind turbines that can be installed |
| Mnh_n | kg | Maximum hydrogen storage capacity |
| $Mhte_n$ | kg | Upper bound for $mhte$ |
| $Meth_n$ | MWh | Upper bound for $meth$ |
| $ES_{j,t,n}$ | MWh | Power output of a single solar panel |
| $EW_{j,t,n}$ | MWh | Power output of a single wind turbine |
| $EL_{j,t,n}$ | MWh | Electricity load |
| $HL_{j,t,n}$ | kg | Hydrogen load |

transfer). The existing capacity of transmission lines and hydrogen pipes is also set.

Finally, the model allows for upper bounds to be placed on the variables, based on either technological and physical constraints (dimension of the facilities) or because of political choices (e.g. local population unfavourable to wind turbines).

The parameters ES , EW , EL , HL , indexed by scenario, time step and node represent the time series of power generation and load values for different scenarios in every node of the grid. The method used for generation is described in Appendix A.

See Table 2 for the summary of all parameters.

2.1.3 Objective Function

The cost function is given by the sum of all capital costs of installing infrastructure, plus all marginal costs of the hydrogen to electricity and electricity to hydrogen conversions and hydrogen transfer on the edges at each time step.

Let d be the number of scenarios, and T the number of time steps. The objective function is as follows:

$$\begin{aligned}
\min \quad & \sum_{k \in \mathcal{N}} (cs_k \cdot ns_k + cw_k \cdot nw_k + ch_k \cdot nh_k) + \\
& + \sum_{k \in \mathcal{N}} (cmhte_k \cdot mhte_k + cmeth_k \cdot meth_k) + \\
& + \sum_{l \in \mathcal{E}_P} (cNTC_l \cdot aNTC_l) + \sum_{l \in \mathcal{E}_H} (cMH_l \cdot addMH_l) + \\
& + \frac{1}{d} \sum_{j=1}^d \sum_{t=1}^T \left(\sum_{k \in \mathcal{N}} (ch_{t,k} \cdot H_{j,t,k} + ch_{t,k} \cdot H_{tE_{j,t,k}} + ceth_k \cdot EtH_{j,t,k}) + \right. \\
& \quad \left. + \sum_{l \in \mathcal{E}_H} (cH_edge_l \cdot H_edge_{j,t,l}) \right)
\end{aligned} \tag{1}$$

The $1/d$ factor in front of the marginal costs allows to average over the scenarios, whereas the capital costs are the same for all scenarios. Thus, ignoring the costs of $mhte_k$ and $meth_k$, the objective function value gives an estimate of the actual costs (in €) for the set up and maintenance of the system throughout the length of the time horizon.

2.1.4 Constraints

The following constraints are to ensure that for all time steps t and all scenarios j , the electricity load and the hydrogen load are met. The measure units are MWh and kg respectively, and conversion factors are considered for HtE and EtH respectively. Let $Out(n)$ and $In(n)$ indicate the outgoing and incoming edges from node n on the respective graph. For simplicity, we indicate with $P_edge_{j,t,l}$ the difference of the corresponding variables $P_edge_{j,t,l}^+ - P_edge_{j,t,l}^-$, and analogously for H_edge . When solving, it is sufficient to assign a symbolic cost to them to ensure that only one of them is non zero at each time step. Then for each node n , scenario j and time step t , the following flow balance

constraints are imposed:

$$\begin{aligned}
\text{Electricity Balance: } & ns_n \cdot ES_{j,t,n} + nw_k \cdot EW_{j,t,n} - EL_{j,t,n} + \\
& + 0.033 \cdot fhte_k \cdot HtE_{j,t,n} - EtH_{j,t,n} + \\
& + \sum_{l \in Out(n)} P_edge_{j,t,l} + \sum_{l \in In(n)} P_edge_{j,t,l} \geq 0;
\end{aligned} \tag{2}$$

$$\begin{aligned}
\text{Hydrogen Storage: } & H_{j,t+1,n} = H_{j,t,n} - HL_{j,t,n} + \\
& + 30 \cdot feth_k \cdot EtH_{j,t,n} - HtE_{j,t,n} + \\
& - \sum_{l \in Out(n)} H_edge_{j,t,l} + \sum_{l \in In(n)} H_edge_{j,t,l}
\end{aligned} \tag{3}$$

We ask that the consumed electricity be less or equal than the produced or received electricity at all times. On the grid itself, the two sides should be equal, but we observe that $ns \cdot ES_{j,t} + nw \cdot EW_{j,t}$ indicate the maximum power that can be generated with set weather conditions, whereas actual production will be regulated to meet demand through curtailment.

The stored hydrogen at time $t + 1$ is the result of what was stored at time t adjusted by what was converted and what was sent to the industrial load. For $t = T$ (the last time step) we set the same constraint on hydrogen by considering $t + 1$ to be index 1: this way we avoid placing a “start time” at an arbitrary place within the year (time is rendered modulo the year) and we avoid the model asking for conveniently high initial storage values of hydrogen appearing out of thin air.

The total storage and conversion capacities are calculated by minimizing the maximum over time and scenarios of the variables $H_{j,t}$, $EtH_{j,t}$ and $HtE_{j,t}$, for all scenarios j , time steps t and nodes n :

$$\text{Storage Capacity Limit: } H_{j,t,n} \leq nh_n; \tag{4}$$

$$\text{EtH Conversion Limit: } EtH_{j,t,n} \leq meth_n; \tag{5}$$

$$\text{HtE Conversion Limit: } HtE_{j,t,n} \leq mhte_n. \tag{6}$$

Finally, edge capacities on the respective graphs are considered for all scenarios j , time steps t and nodes n :

$$\text{Net Transfer Capacity: } P_edge_{j,t,l}^{\pm} \leq NTC_l + addNTC_l; \tag{7}$$

$$\text{Hydrogen Transfer Capacity: } H_edge_{j,t,l}^{\pm} \leq MH_l + addMH_l. \tag{8}$$

2.2 Validation: Rolling Horizon

While computing the optimal solution on a batch of scenarios by solving the LP model described in section ??, the solver “knows the future” for those scenarios. That is, the criteria it uses to determine, at each time step, how much electricity or hydrogen should be converted or transmitted, and where, is a mathematical minimum that is informed by the knowledge of what is needed

at any time during the one year scenario. In real life, accurate forecasts for weather, and consequently for power generation, are known on a day ahead basis, at most two days ahead. We are thus interested in evaluating whether an optimal grid as given by the solution of the CEP problem on a batch of train scenarios can (1) be operated without knowledge of the future in order to satisfy demand on the same scenarios it was trained on, and (2) generalize to new test scenarios.

Let's first consider the case where the grid is composed of a single node. The actions and choices of a power grid administrator of such an isolated micro-grid are very much limited to "given extra energy, store it, up to storage limit". Such a strategy is for example discussed in more detail in [?]. A deterministic system control can be easily designed to check whether a single node CEP solution is sufficient for feasibility over a certain scenario, even without day ahead forecasts. This is not true anymore once the node is taken out of isolation: at each moment, without knowledge of the full future, each fictional administrator at each node must choose whether to store the energy generated at their node, whether to send it to a neighbor (and how much to which neighbor) or how to collect missing energy to match their node's demand.

In order to operate a multi-node grid, we propose to use the Rolling Horizon optimization technique. The basic idea is to divide the time horizon into smaller periods and to progressively optimize on each period, passing the variables of the solved periods as fixed to the next. In our case, we are interested in periods of length one day each, representing the knowledge of future that is given to the grid administrator by weather forecasts.

Recall that when optimizing with the LP model described in section ??, the solutions to the CEP and to the ED problem for all train scenarios $j \in J_{train}$ are given concurrently. Consider now a test scenario with generation and load time series $ES_{t,n}^{test}, EW_{t,n}^{test}, EL_{t,n}^{test}, HL_{t,n}^{test}$ (the test scenario can be in J_{train} or not).

The RH algorithm is as follows:

- Start with $H_{0,n}^{test} = \max_{j \in J_{train}} H_{j,0,n}$.
- For each day in the time horizon:
 - Optimize the inner ED problem for that day. If the problem is infeasible, break.
 - Set the hydrogen storage levels of the last time step of the day equal to the ones for the first time step of the next day.

The daily ED problem is formulated in a similar way to the LP problem described in section ?. The differences are that the CEP variables (ns, nh, \dots) are fixed, and the hydrogen storage level doesn't loop as it did in the year, but it connects to the following day.

Definition 1 (RH-feasibility) Given a solution x_{CEP} to the CEP solved over train scenarios $j \in J_{train}$ and a test scenario j , we consider x_{CEP} to be RH-feasible over scenario j if the RH optimization algorithm terminates at the end of the year and $H_{j,T,n} \geq H_{j,0,n}$ for all nodes $n \in \mathcal{N}$.

We require the last condition to mean that the storage levels at the end of the year are at least as high as they were at the start, to flag as unfeasible solutions that manage to satisfy demand throughout the year only through a net consumption of unproduced hydrogen.

Written as such, the daily optimization would tend to avoid storing hydrogen unless needed within the same day, since operating the electrolyzers has a cost. This easily renders infeasible scenarios that would be feasible with better storage management. To solve this problem, one can introduce a loss function in the model: for example one can assign a cost to the difference between the hydrogen storage level at time step t and the average over the corresponding variables in the optimal solutions from train scenarios. Thus one defines positive variables $loss_{t,n}$ for each time step t and node n , with positive cost, and adds the constraint:

$$loss_{t,n} \geq \frac{1}{d} \sum_{j \in J_{train}} H_{j,t,n} - H_{t,n}^{test} \quad (9)$$

Another option would be to assign a slight negative cost to $H_{t,n}^{test}$, to incentivize filling up the storage, but this can inflate the estimated cost of operating electrolyzers more than necessary.

We observe that the overall solution to the ED problem throughout the full time horizon obtained by means of the RH method is not necessarily optimal, neither with nor without the added loss function. However, some results can be obtained regarding the distance of such solution from the optimal of the ED problem. Indeed: *The first step ensures that conditions 1-4 from [?] are satisfied. Thus we have near optimality guarantee.... to be checked again*

For a solution to the ED problem that is closer still to the perfect foresight optimal, more refined RH techniques can be used. For example, optimizing on two-day forecasts with a daily refresh rate, as done in [?] can improve the quality of the solution. However, for our purposes, being able to check for feasibility with less than optimal management is sufficient.

3 Time Resolution

The scenarios generated from our gathered data have a time resolution of one hour. Such resolution is enough to capture the daily variability of power generation and load. However, the number of variables and constraints grows linearly with the number of time steps, making the model intractable with just a few scenarios. Moreover, when optimizing over a full year, considering every hour of every day is partly redundant, as each day will be similar to neighboring days. Yet, simply considering a sample of days for each season might undermine long-term storage capacity representation. Thus we are interested in finding more efficient ways to deal with the time dimension in our problem.

3.1 Time aggregation as model relaxation

We introduce the following concept:

Definition 2 (Time partition) Given an initial time horizon $\mathcal{T} = \{1, \dots, T\}$, a time partition $P = \{I_1, \dots, I_{T'}\}$ is a partition of \mathcal{T} such that all subsets are intervals. Furthermore, we say that a time partition P' is finer than P if for every $I' \in P'$, there exists some $I \in P$ such that $I' \subset I$.

Given a time partition P , we can consider the problem CEP_P associated to the model obtained by considering each interval in P as a single time step. For every $I \in P$, define:

$$ES_{j,I,n} := \sum_{i \in I} ES_{j,i,n}, \quad EW_{j,I,n} := \sum_{i \in I} EW_{j,i,n}, \quad (10)$$

and analogously for $EL_{j,I,n}$ and $HL_{j,i,n}$.

It is easy to show that the optimal value to the aggregated problem CEP_P is a lower bound for the original problem $CEP_{\mathcal{T}}$. Indeed, given a feasible solution of the latter, we can obtain a solution of the former by fixing the capital infrastructure variables to be the same as in $CEP_{\mathcal{T}}$ and letting all time dependent variables for the inner ED problems be defined as follows:

$$EtH_{j,I,n} = \sum_{i \in I} EtH_{j,i,e}, \quad HtE_{j,I,e} = \sum_{i \in I} HtE_{j,i,e}, \quad \Delta H_{j,I,e} = \sum_{i \in I} \Delta H_{j,i,e}. \quad (11)$$

Similarly, we sum over $P_edge_{j,I,e}^{\pm}$ and $H_edge_{j,I,e}^{\pm}$, separately on the two directions. By defining the aggregated variables this way, the aggregated constraints are not violated, thus we get a feasible solution to CEP_P . Observe that all variables with non zero cost are defined as greater or equal to zero, so summing over them we define a cost-preserving linear map from the solution space of $CEP_{\mathcal{T}}$ to the solution space of CEP_P .

The above discussion holds in general in the case of any two partitions P and P' where P' is finer than P . We can summarize the above in the following observation:

Observation 3.1 *Let P and P' be two time partitions of $\mathcal{T} = \{1 \dots T\}$ such that P' is finer than P . Let $V_P \subset \mathbb{R}^{N_P}$ and $V_{P'} \subset \mathbb{R}^{N_{P'}}$ be the spaces of feasible solutions of CEP_P and $CEP_{P'}$, respectively. Then there exists a linear map $L : \mathbb{R}^{N_{P'}} \rightarrow \mathbb{R}^{N_P}$ such that $L(V_{P'}) \subset V_P$ and $c_P(L(x)) = c_{P'}(x)$, where c_P is the cost function of CEP_P and $c_{P'}$ is the cost function of $CEP_{P'}$.*

From this observation follows that:

Proposition 1 *Let P and P' be two time partitions of $\mathcal{T} = \{1 \dots T\}$ such that P' is finer than P . Then CEP_P is a relaxation of $CEP_{P'}$, and the optimal solution to CEP_P provides a lower bound for $CEP_{P'}$.*

To clarify what time aggregation implies on the model constraints, we express the LP problem in standard matrix form (as expressed in formulation 12), in order to highlight its inner structure.

$$\begin{aligned} \min_{x \in \mathbb{R}^n} \quad & c^\top x \\ \text{s.t.} \quad & Ax = b \\ & x \geq 0 \end{aligned} \quad (12)$$

Fistly, we can reformulate the model described in subsection 2.1 by introducing a new set of variables $\Delta H_{j,t,n} := H_{j,t+1,n} - H_{j,t,n}$, replacing the original variables $H_{j,t,n}$. Constraints (3) and (4) shall be reformulated accordingly, with the latter becoming:

$$\sum_{i=1}^t \Delta H_{i,j,n} \leq nh_n, \quad \forall t = 1 \dots T, \quad (4')$$

In the problem under consideration, we have various types of constraints: Electricity Balance (2), Hydrogen Balance (3'), Hydrogen Storage (4'), maximum capacity of the time dependent variables (5),(6),(7),(8), and bounds on the CEP variables. By splitting the variable vector \mathbf{x} into \mathbf{x}_{CEP} and \mathbf{x}_{ED} , we can view the constraint matrix A as divided in the following sections:

$$\begin{array}{|c|c|c|} \hline \begin{array}{c} A^{CEP} \\ (ES, EW, \dots) \end{array} & 0 & \begin{array}{c} \text{[Red blocks]} \\ \ddots \end{array} \\ \hline 0 & 1 & \begin{array}{c} \begin{array}{ccccccc} 0 & \dots & 0 & -1 & & & \\ 0 & \dots & 0 & 1 & \dots & 0 & -1 \\ 0 & \dots & 0 & 1 & \dots & 0 & 1 & \dots & 0 & -1 \\ 0 & \dots & 0 & 1 & \dots & 0 & 1 & \dots & 0 & -1 \end{array} \\ \vdots \end{array} \\ \hline \end{array} = \begin{array}{c} \begin{array}{c} ns \\ nw \\ \vdots \\ nh \\ \vdots \\ HL \\ EL \\ \vdots \\ 0 \end{array} \\ \begin{array}{c} \vdots \\ \vdots \\ \vdots \\ \vdots \\ \vdots \\ \vdots \\ \vdots \\ \vdots \end{array} \end{array} \quad (13)$$

Variable nh is represented individually and not within \mathbf{x}_{CEP} . The upper rows contain the balance constraints regarding electricity and hydrogen, and bounds for the time dependent variables. The bottom section of the matrix accounts for storage constraints (4'): summing over $\Delta H_{j,i,n}$ returns the original

variable $H_{j,t,n}$, bound by nh_n . All other variable bounds are not represented, since they pertain to one variable at the time and don't really influence the overall reasoning.

For clarity, we represent now a simplified version of the rows corresponding to a single time step, ignoring edge variables and including only balance constraints and the upper bound for HtE as an example.

$$\left[\begin{array}{ccc|ccc} ES_{j,t,n} & EW_{j,t,n} & 0 & 0.033 \cdot fhte_n & -1 & 0 \\ 0 & 0 & 0 & -1 & 30 \cdot feth_n & -1 \\ 0 & 0 & 1 & -1 & 0 & 0 \end{array} \right] \begin{array}{c} \left[\begin{array}{c} \text{ns} \\ \text{nw} \\ \text{mhTe} \\ \vdots \\ HtE_{j,t,n} \\ EtH_{j,t,n} \\ \Delta H_{j,t,n} \\ \vdots \end{array} \right] \end{array} \begin{array}{l} \geq \\ = \\ \geq \end{array} \begin{array}{c} \left[\begin{array}{c} EL_{j,t,n} \\ HL_{j,t,n} \\ 0 \end{array} \right] \end{array} \quad (14)$$

Inequalities can be transformed into equalities through slack variables.

Consider now the upper part of matrix 13. By summing over the respective rows corresponding to the time steps within the same interval I in a time partition P , we obtain the summations in 10. Row operations such as this always yield LP relaxations. In order to trace back to the model with aggregated variables as well, as defined in 11, a column operation must be carried on. In general, column operations (especially when reducing the dimension of the variable space) don't yield problem relaxations. However, thanks to the block structure with constant coefficients in all the blocks, the upper part of the constraint matrix of the aggregated LP formulation is indeed a relaxation of the disaggregated one. A formal proof of this fact, written for more general row and column operations, is given in Appendix B B.

The bottom part of the matrix is dealt with more easily: aggregating simply corresponds to dropping all rows constraining the storage for instants inside the aggregated time steps, while keeping the ones corresponding to the start/end of the aggregated time steps unchanged. Thus obtaining a relaxation.

3.2 Iteration on time partitions

Given that any time-aggregated LP is a relaxation for the original LP, but with many fewer variables, and thus lower optimization time, we wish to utilize purposely chosen aggregations to warm start the solver iteratively, converging to the optimal solution through progressively finer aggregations.

Power generation and electricity load data tend to follow very strong seasonal and daily patterns, and on a minor extent, a weekly trend. Generally, long term patterns are accounted for even with more loose aggregations. On the other hand, a grid described by the solution to the CEP_P for a loose

partition will likely be unable to deal with daily variability. Indeed, it is quite common to have days with overall greater power production than load, but with peak production at noon and most of the power load during the late evening; such a discrepancy is overlooked by the aggregated model. Choosing a finer partition with well distributed medium-sized time steps (for example weekly or even daily) would not solve this blind spot. For this reason, in choosing the refinement strategy for the time partitions we opted to disaggregate one single whole day per iteration into hourly time steps.

The method devised is the following:

1. Set up the model environment with enough variables for the iterations to come. Impose the constraints relative to an initial time partition, and solve.
2. Select a day with some given selection method.
3. Add the constraints relative to each hour of that day. Solve with warm start.
4. Repeat step 2 and 3 until some halting condition.

The first implementation we test considers a random selection method, and a very arbitrary halting condition on the number of iterations. This will be the baseline to compare the other methods we propose.

A second implementation makes use of the RH validation function we discussed in subsection 2.2. The RH will optimize day-by-day with hourly time steps, that is, limited foresight on the finest time resolution. To choose the day to disaggregate, let the RH start on one of the training scenarios with the fixed x_{CEP} values given by the solution to the previous iteration. If the RH iteration breaks before reaching the end of the year, choose the day it fails on as the day to disaggregate. Conversely, if the RH makes it through the year, then the considered x_{CEP} values are part of a feasible solution for the CEP+ED problem on the whole horizon, on the finest time resolution, thus we have solved the original problem we were aiming for.

One advantage of using the RH validation function within the iterative aggregation method is that it automatically provides an effective halting method that guarantees feasibility for the original problem.

Furthermore, the final x_{CEP} come from the optimal solution of a relaxation. This is not enough to guarantee optimality for the finer resolution CEP, since marginal costs of conversion to and back from hydrogen, and of its transportation, aren't accounted for fully. specify at the start of section LP that we use CEP, ED and LP to refer to one, two and both when talking about solutions. A solution to CEP is considered optimal if it is part of an optimal LP solution on given scenarios. We are always talking relative to given scenarios. However, distance from the actual optimal solution can be bound (estimate) by – marginal costs in those days times the year, since they are chosen to be the worst days.

A great disadvantage of using the RH validation within the iteration loop is that the computational costs it brings along is not insignificant, needing careful consideration on whether it is in effect preferable to directly optimizing on the full problem.

While obtaining a feasible solution to (??) from (??) is not always guaranteed, it is possible under certain assumptions. Here, if B is a matrix having I, J as set of indexes for the rows and columns respectively, then, for all $I' \subset I$ and $J' \subset J$, we denote with $B_{I', J'}$ the submatrix of B havins rows in I' and columns in J' .

Observation 3.2 *If (σ, δ) is a structure-preserving aggregation, let $R \in \sigma$ and $r \in R$. Let \tilde{x} be a solution to the aggregated problem (??). If $\tilde{b}_r - \tilde{A}_{R, \delta=1} \tilde{x}_{\delta=1} \neq 0$, define $\rho_r := \frac{b_r - A_{r, \delta=1} \tilde{x}_{\delta=1}}{\tilde{b}_r - \tilde{A}_{R, \delta=1} \tilde{x}_{\delta=1}}$. If $A_{r, \delta=1} = 0$ and $b_r = 0$, then ρ_r can be chosen arbitrarily. If $\rho_r \geq 0$ and $x \in \mathbb{R}^n$ satisfies $x_{\delta=1} = \tilde{x}_{\delta=1}$ and $x_{f^r(C)} = \rho_r \tilde{x}_C$ for all $C \in \text{supp}(\tilde{A}_R)_{>1}$, then x satisfies the constraint $A_r x = b_r$ of the original problem.*

Proof From the hypothesis and the definition of structure-preserving aggregation, we have:

$$\begin{aligned} A_r x &= \sum_{i \in \text{supp}(A_r)} A_{r,i} x_i \\ &= \sum_{S \in \text{supp}(\tilde{A}_R)_{>1}} A_{r, f^r(S)} x_{f^r(S)} + \sum_{j \in \delta=1} A_{r,j} x_j \\ &= \sum_{S \in \text{supp}(\tilde{A}_R)_{>1}} \tilde{A}_{R,S} \rho_r \tilde{x}_S + \sum_{j \in \delta=1} A_{r,j} x_j \end{aligned}$$

By the definition of ρ_r :

$$\begin{aligned} \rho_r \sum_{S \in \text{supp}(\tilde{A}_R)_{>1}} \tilde{A}_{R,S} \tilde{x}_S &= \rho_r (\tilde{A}_R \tilde{x} - \tilde{A}_{R, \delta=1} \tilde{x}_{\delta=1}) \\ &= \rho_r (\tilde{b}_r - \tilde{A}_{R, \delta=1} \tilde{x}_{\delta=1}) \\ &= b_r - A_{r, \delta=1} \tilde{x}_{\delta=1} \end{aligned}$$

Thus, we obtain:

$$A_r x = b_r$$

□

A structure-preserving aggregation does not inherently guarantee feasibility for all constraints in the original problem. However, Observation 3.2 illustrates how to partially reconstruct a solution x for a specific constraint r by appropriately scaling the aggregated variables within the support of A_r .

We can now define the hypergraph associated to the aggregation (σ, δ) .

Definition 3 *The hypergraph associated to the aggregation (σ, δ) is the hypergraph \mathcal{N}, \mathcal{E} having as nodes the aggregated variables $\mathcal{N} := \delta_{>1}$ and as edges the subset of \mathcal{N} that appear together in not row-agnostic constraints.*

When two edges (constraints) in the hypergraph, r and r' , share aggregated variables, the scaling factors ρ_r and $\rho_{r'}$ must be equal to maintain consistency. Then if ρ_r can be defined consistently, by applying observation 3.2, to all $r \in R \in \sigma_{>1}$ we can construct a feasible solution for the unaggregated problem (??). Thus we have:

Proposition 2 *If (σ, δ) is a structure-preserving aggregation. Let \tilde{x} be a solution to the aggregated problem (??). If for all $r \in R \in \sigma_{>1}$ such that $\tilde{b}_r - \tilde{A}_{R, \delta=1} \tilde{x}_{\delta=1} = 0$ we have $A_{r, \delta=1} = 0$ and $b_r = 0$. Define $\rho_r := \frac{b_r - A_{r, \delta=1} \tilde{x}_{\delta=1}}{\tilde{b}_r - \tilde{A}_{R, \delta=1} \tilde{x}_{\delta=1}}$ for all $r \in R \in \sigma_{>1}$ such that $\tilde{b}_r - \tilde{A}_{R, \delta=1} \tilde{x}_{\delta=1} \neq 0$. If $\rho_r \geq 0$ and is constant over the connected components of the hypergraph associated to (σ, δ) . Then $x_{\delta=1} := \tilde{x}_{\delta=1}$ and $x_{f^r(C)} := \rho_r \tilde{x}_C$ for all $C \in \text{supp}(\tilde{A}_R)$ and $C \in \delta_{>1}$ is well defined and is feasible solution for the unaggregated problem (??).*

While row aggregation of a linear problem is a relaxation of the original problem, the same does not apply to column aggregation. However, the column aggregation used for the Capacity Expansion Problem in this work is still a relaxation. In general a column aggregation of a linear problem is a relaxation of the original problem whenever it is a *constant-coefficients column aggregation*, that is:

It can be easily checked that:

Observation 3.3 *The aggregation of the Capacity Expansion Problem (CEP) is a structure-preserving aggregation with constant coefficients. Furthermore, the constraints (??) are ρ -agnostic.*

Since the only constraints linking variables across different time steps are those in (??), the connected components of the hypergraph representing the aggregation correspond to the hypergraphs of the Energy Dispatch (ED) at each time step. Specifically, there is one connected component per time step, with nodes representing the variables at that step. To construct a feasible solution from the aggregated problem, it is sufficient for ρ_r to be constant across constraints within the same time step.

Using the definition of ρ_r , it can be shown that for each time step $t \in T \in \mathcal{T}$, this corresponds to the ratio between the net energy production at time t and the net energy production over the interval T . Hence, the conditions of Proposition 2 are met if, for a fixed time step t , this ratio is the same for all nodes in the network, and if, during the interval T , the net production at each node is consistently positive or consistently negative. Thus, we state:

Observation 3.4 *If for each time step $t \in T \in \mathcal{T}$, the ratio of the net energy production at time t to the net energy production over the interval T is the same for all nodes in the network, and if, throughout the interval T , the net production at each node is either always positive or always negative, then the aggregated problem is exact.*

Although this is not generally the case, it suggests an iterative procedure for refining the solution of the aggregated problem. At each iteration, we refine

the time partition of the aggregated problem, selecting the time interval to be refined based on the extent to which it violates the conditions of Observation 3.4. Specifically, we split intervals where the net production changes sign, and those intervals T in which, for a fixed time step $t \in T$, the ratio between the net energy production at time t and the net energy production over the interval T exhibits the largest variance.

4 COMPUTATIONAL RESULTS

To evaluate the methodologies presented in this paper, we examine a 5-node network over a one-year span, utilizing timesteps of 1 hour across two distinct scenarios. In this section, we compare three approaches for iterating on the aggregated problem: (1) randomly selecting the interval for refinement, (2) selecting the interval with the highest ρ -variance as defined in Section ??, and (3) selecting the interval where the validation function ?? fails. The scenarios are generated as outlined in Section ?? in the Appendix. The computational tests were conducted on an Intel(R) Core(TM) i7-13700H CPU @ 2.40GHz with 16 GB of RAM using Gurobi.

Plot 1 illustrates the cost variation at each iteration using the ρ selection method compared to random interval selection. The ρ selection method demonstrates a faster increase in cost than the random selection method, with comparable optimization times: 174 seconds for the ρ selection method and 155 seconds for the random selection method over 10 iterations. In plot 2, we




Fig. 1 Cost variation at each iteration using the ρ selection method compared to random interval selection.

compare the cost variation at each iteration using the validation function for interval refinement against the random interval selection method. The results indicate that the former method yields a significantly faster increase, implying

quicker convergence to the optimal solution. However, this approach incurs greater computational time: many seconds s. It is worth noting that while both the ρ and random iteration methods continue even upon encountering a feasible solution for the original problem, the validation function iteration may halt before reaching the maximum iteration limit if the current solution is feasible, thereby being optimal for the original problem.




Fig. 2 Cost variation at each iteration using the validation function for interval refinement against the random interval selection method.

— plot same but over real time — or just table with time stamps
comment: the model takes a lot to set up, but iterations are quick: we are indeed using warm start successfully.
—plot at each iteration the optimization time trend—

5 Conclusion and Future Directions

References

1. Biener, W., Garcia Rosas, K.R.: Grid reduction for energy system analysis. *Electric Power Systems Research* **185**, 106349 (2020). DOI <https://doi.org/10.1016/j.epsr.2020.106349>. URL <https://www.sciencedirect.com/science/article/pii/S0378779620301553>
2. Blanco, H., Faaij, A.: A review at the role of storage in energy systems with a focus on power to gas and long-term storage. *Renewable and Sustainable Energy Reviews* **81**, 1049–1086 (2018). DOI <https://doi.org/10.1016/j.rser.2017.07.062>. URL <https://www.sciencedirect.com/science/article/pii/S1364032117311310>
3. Commission, E.: Communication from the commission: Guidance on article 20a on sector integration of renewable electricity of directive (eu) 2018/2001 on the promotion of energy from renewable sources, as amended by directive (eu) 2023/2413 (2024). URL <https://energy.ec.europa.eu/document/download/>

- efcd200c-b9ae-4a9c-98ab-73b2fd281fcc_en?filename=C_2024_5041_1_EN_ACT_part1_v10.pdf
4. Dawood, F., Anda, M., Shafiullah, G.: Hydrogen production for energy: An overview. *International Journal of Hydrogen Energy* **45**(7), 3847–3869 (2020). DOI <https://doi.org/10.1016/j.ijhydene.2019.12.059>. URL <https://www.sciencedirect.com/science/article/pii/S0360319919345926>
 5. Glomb, L., Liers, F., Rösel, F.: A rolling-horizon approach for multi-period optimization. *European Journal of Operational Research* **300**(1), 189–206 (2022). DOI <https://doi.org/10.1016/j.ejor.2021.07.043>. URL <https://www.sciencedirect.com/science/article/pii/S0377221721006536>
 6. Gurobi Optimization, LLC: Gurobi Optimizer Reference Manual (2024). URL <https://www.gurobi.com>
 7. Hasan U. Yilmaz Kai Mainzer, D.K.: Improving the performance of solving large scale mixed-integer energy system models by applying the fix-and-relax method pp. 1–5 (2020). DOI 10.1109/EEM49802.2020.9221934
 8. Hörsch, J., Brown, T.: The role of spatial scale in joint optimisations of generation and transmission for european highly renewable scenarios. In: 2017 14th International Conference on the European Energy Market (EEM), pp. 1–7 (2017). DOI 10.1109/EEM.2017.7982024
 9. Ilkka Keppo, M.S.: Short term decisions for long term problems – the effect of foresight on model based energy systems analysis. *Energy* **35**(5), 2033–2042 (2010). DOI <https://doi.org/10.1016/j.energy.2010.01.019>. URL <https://www.sciencedirect.com/science/article/pii/S0360544210000216>
 10. Khahro, S.F., Tabbassum, K., Soomro, A.M., Dong, L., Liao, X.: Evaluation of wind power production prospective and weibull parameter estimation methods for babaurband, sindh pakistan. *Energy Conversion and Management* **78**, 956–967 (2014). DOI <https://doi.org/10.1016/j.enconman.2013.06.062>. URL <https://www.sciencedirect.com/science/article/pii/S019689041300589X>
 11. Michal Jasinski Arsalan Najafi, e.a.: Operation and planning of energy hubs under uncertainty - a review of mathematical optimization approaches (2022)
 12. Morais, H., Kádár, P., Faria, P., Vale, Z.A., Khodr, H.: Optimal scheduling of a renewable micro-grid in an isolated load area using mixed-integer linear programming. *Renewable Energy* **35**(1), 151–156 (2010). DOI <https://doi.org/10.1016/j.renene.2009.02.031>. URL <https://www.sciencedirect.com/science/article/pii/S0960148109001001>
 13. Observatory, E.H.: European hydrogen market landscape - november 2023 report. *European Journal of Operational Research* (1) (2023). URL <https://observatory.clean-hydrogen.europa.eu/sites/default/files/2023-11/Report%2001%20-%20November%202023%20-%20The%20European%20hydrogen%20market%20landscape.pdf>
 14. Palma-Behnke, R., Benavides, C., Lanas, F., Severino, B., Reyes, L., Llanos, J., Sáez, D.: A microgrid energy management system based on the rolling horizon strategy. *IEEE Transactions on Smart Grid* **4**(2), 996–1006 (2013). DOI 10.1109/TSG.2012.2231440
 15. Papaefthymiou, G., Kurowicka, D.: Using copulas for modeling stochastic dependence in power system uncertainty analysis. *IEEE Transactions on Power Systems* **24**(1), 40–49 (2009). DOI 10.1109/TPWRS.2008.2004728
 16. Parra, D., Valverde, L., Pino, F.J., Patel, M.K.: A review on the role, cost and value of hydrogen energy systems for deep decarbonisation. *Renewable and Sustainable Energy Reviews* **101**, 279–294 (2019). DOI <https://doi.org/10.1016/j.rser.2018.11.010>. URL <https://www.sciencedirect.com/science/article/pii/S1364032118307421>
 17. Yuan, X., Chen, C., Jiang, M., Yuan, Y.: Prediction interval of wind power using parameter optimized beta distribution based lstm model. *Applied Soft Computing* **82**, 105550 (2019). DOI <https://doi.org/10.1016/j.asoc.2019.105550>. URL <https://www.sciencedirect.com/science/article/pii/S1568494619303308>

A SCENARIO GENERATION

To estimate the optimal capacities for the CEP through a stochastic approach, realistic and diverse weather scenarios are needed, so to capture the variability and uncertainty of power generation through renewable sources over extended periods. In order to generate such scenarios, samples are extracted from a joint probability density function (PDF) fit on historical data. In our project, we used an hourly time step ($T = 8760$) and fit the wind and solar distributions separately for each country considered.

To model the marginal probability distributions corresponding to the power output of wind turbines for each hour of the year, a Weibull distribution was used, justified by its proven effectiveness in capturing the variability and skewness of wind power distributions [10]. For solar power, Beta distributions were employed, as in [17]. To fit our model, we used a dataset containing 30 years of data for various European countries, which was collected by [?]. On the other hand, electricity load is taken from the [ENTSO-E Statistical Reports](#). [explain how is HL obtained](#) In this simple model, while fitting on historical data we did not account for possible changes in future climate, since the focus lies mostly in the computational aspect.

To account for interdependence between temporally near time steps, we coupled these distributions using a Gaussian Copula approach, which captures the dependencies between hourly power outputs effectively. This approach accurately represents the coupled behavior in renewable stochastic systems [?].

A possible improvement of the generation process could be to fit wind and PV data jointly in the copula step, potentially also including load scenarios with the generation scenarios through the same approach. This would consider dependence between Energy Demand and weather conditions, but it would necessitate of the historical dataset provided for the corresponding grid, and would also further increase computational costs.

A.1 Parametric Estimation of Wind Power distribution

The parameters defining the Weibull Distribution are estimated using the Maximum Likelihood Estimation (MLE). The Weibull density function is given by:

$$f(x; \theta, \gamma) = \left(\frac{\gamma}{\theta}\right) x^{\gamma-1} \exp\left(-\left(\frac{x}{\theta}\right)^\gamma\right) \quad (15)$$

where $\theta, \gamma > 0$ are the scale and shape parameters, respectively.

Given observations X_1, \dots, X_n , the log-likelihood function is:

$$\log L(\theta, \gamma) = \sum_{i=1}^n \log f(X_i | \theta, \gamma) \quad (16)$$

The optimum solution is found by searching for the parameters for which the gradient is zero:

$$\frac{\partial \log L}{\partial \theta} = -\frac{n\gamma}{\theta} + \frac{\gamma}{\theta^2} \sum_{i=1}^n x_i^\gamma = 0 \quad (17)$$

Eliminating θ , we get:

$$\left[\frac{\sum_{i=1}^n x_i^\gamma \log x_i}{\sum_{i=1}^n x_i^\gamma} - \frac{1}{\gamma} \right] = \frac{1}{n} \sum_{i=1}^n \log x_i \quad (18)$$

This can be solved to get the MLE estimate $\hat{\gamma}$. This can be accomplished with the aid of standard iterative procedures such as the Newton-Raphson method or other numerical procedures. This is done with the aid of the package *scipy*. Once $\hat{\gamma}$ is found, $\hat{\theta}$ can be determined in terms of $\hat{\gamma}$ as:

$$\hat{\theta} = \left(\frac{1}{n} \sum_{i=1}^n x_i^{\hat{\gamma}} \right)^{\frac{1}{\hat{\gamma}}} \quad (19)$$

A.2 Parametric Estimation of Solar Power distribution

To estimate the α and β parameters defining the Beta distribution Y , we use the Method of Moments. The mean of the random variable Y can be expressed as $\mathbb{E}[Y] = \frac{\alpha}{\alpha+\beta}$ and the variance as $Var[Y] = \frac{\alpha+\beta}{(\alpha+\beta)(\alpha+\beta+1)}$. In particular by explicating β in the first equation and substituting it in the second equation we obtain that:

$$\begin{cases} \alpha = \mathbb{E}[X] \left(\frac{\mathbb{E}[X](1-\mathbb{E}[X])}{Var[X]} - 1 \right) \\ \beta = (1 - \mathbb{E}[X]) \left(\frac{\mathbb{E}[X](1-\mathbb{E}[X])}{Var[X]} - 1 \right) \end{cases} \quad (20)$$

By substituting the mean and the variance with their empirical approximation we obtain the Method of Moments estimator for α and β .

A.3 Parametric Copula Estimation

The cumulative density function of both the Weibull and Beta distributions are continuous and invertible. Therefore, the random variables $U_t := F_{Y_t}(Y_t)$ have a uniform distribution over $[0, 1]$. The copula of the random variables $\{Y_t\}_{t \in T}$ is defined as the function $C : [0, 1]^T \rightarrow [0, 1]$ such that

$$C(F_{Y_1}(y_1), \dots, F_{Y_T}(y_{|T|})) = P(Y_1 \leq y_1, \dots, Y_{|T|} \leq y_{|T|}). \quad (21)$$

This function always exists because of Sklar's Theorem [?]. For a given correlation matrix Σ , the Gaussian Copula with parameter matrix Σ is defined as

$$C_{\Sigma}^{\text{Gauss}}(u_1, \dots, u_T) := \Phi_{\Sigma}(\Phi^{-1}(u_1), \dots, \Phi^{-1}(u_T)),$$

where Φ , Φ_{Σ} are the cumulative distribution functions of Gaussian variables having distribution $\mathcal{N}(0, 1)$ and $\mathcal{N}(\mathbf{0}, \Sigma)$ respectively. In particular if $C_{\Sigma}^{\text{Gauss}}$ is the copula associated with the random variables $\{Y_t\}_{t \in T}$ then we have that the random variables $Z_t = \Phi^{-1}(F_{Y_t}(Y_t)) = \Phi^{-1}(U_t)$ have joint distribution equal to $\mathcal{N}(\mathbf{0}, \Sigma)$. This follows from:

$$\begin{aligned} P(Z_1 \leq z_1, \dots, Z_T \leq z_T) &= P(\Phi^{-1}(U_1) \leq z_1, \dots, \Phi^{-1}(U_T) \leq z_T) = \\ &= P(U_1 \leq \Phi(z_1), \dots, U_T \leq \Phi(z_T)) = \\ &= C_{\Sigma}^{\text{Gauss}}(\Phi(z_1), \dots, \Phi(z_T)) = \\ &= \Phi_{\Sigma}(z_1, \dots, z_T) \end{aligned}$$

In particular, given the realization $\{y_{t,j}\}_{t \in T, j \in J}$ of the variables $\{Y_t\}_{t \in T}$, an unbiased estimation of the parameter matrix Σ is the empirical covariance matrix $\hat{\Sigma}$ of the samples $\{\Phi^{-1}(\hat{F}_{Y_t}(y_{t,j}))\}_{t \in T, j \in J}$, where \hat{F}_{Y_t} is the estimated marginal distribution of the variable Y_t obtained as seen in sections A.1 and A.2.

Finally, we can generate samples from a Multivariate Gaussian random variable $(Z_t, t \in T)$ having distribution $\mathcal{N}(\mathbf{0}, \hat{\Sigma})$. Then the power output scenarios are obtained from these samples by following the previous steps backwards, that is, for each sample, computing $\hat{F}_t^{-1}(\Phi(Z_t))$ for all $t \in T$.

B STRUCTURE PRESERVING CONSTRAINT TRASFORMATIONS

Questa parte è la teoria sviluppata da Gabor. Non la metto nella mia tesi, la riserviamo per l'articolo.