



- 1** REMOVE LPS AND MPCR PIPING. CAP AT TAKE-OFFS FROM MAINS. REMOVE UNIT HEATER AND CAP ITS TAKE-OFFS
- 2** REMOVE TAKE-OFFS FROM MPS AND MPCR PIPING. REMOVE PRV AND ALL DOWNSTREAM PIPING. CAP TAKE-OFFS AT MAINS. REMOVE UH
- 3** REMOVE MPCR PIPING. CAP AT MAIN. SEE DETAIL.
- 4** REMOVE ALL TAKE-OFF PIPING TO MR 153BX. CAP TAKE-OFFS AT MAIN
- 5** REMOVE MPCR PIPING. CAP AT MAIN.

LOWER LEVEL PLAN

1" = 16' (36x24)

ECM 05 STEAM SYSTEM IMPROVEMENTS

FOR PRICING

OCTOBER ENGINEERING
Sudbury, Ma
508-561-7553

NEW YORK MEDICAL COLLEGE
7 DANA ROAD

ECM 05 STEAM IMPROVEMENTS
ECM 08b SUMMER BOILER AND
DOMESTIC HOT WATER HEATER

1-18-17

M-2
2 OF 2