
NOTES

1. PIPE DIAMETERS ARE SHOWN IN MILLIMETERS FOR NOMINAL DIAMETERS UNLESS OTHERWISE INDICATED.
2. ALL PIPES SHALL BE HDPE WITH STANDING PRESSURE 16 BARS.
3. PIPES SHALL BE LAID SUCH THAT THE MINIMUM SOIL COVER OVER PIPE CROWN NOT LESS THAN 1.20 m.
4. PIPES SHALL BE LAID INSIDE A SLEEVE AT ANY CROSSING WITH THE ROAD FOR MAINTENANCE.
5. PIPES BESIDE PLANTS SHOULD BE PLACED INSIDE A CONCRETE ENCASEMENT TO PROTECT PIPES FROM PLANT ROOTS.
6. A GATE VALVE SHOULD BE ERECTED BEFORE EACH BUILDING TIE-IN.
7. ALL BUILDINGS TIE-IN DIAMETER SHALL BE ACCORDING TO PLUMING DESIGN.
8. THE CONTRACTOR SHOULD COORDINATE THE FINAL LOCATION OF THE WATER TIE INS ACCORDING TO SITE CONDITION.
9. THE CONTRACTOR SHOULD COORDINATE WITH OTHER UTILITIES DURING SITE CONSTRUCTION.
10. FOR THE FINAL LOCATIONS OF INSPECTION CHAMBERS ,FIRE HYDRANTS, WATER TANKS, PUMP ROOMS AND LIFT STATIONS REFER TO MASTER PLAN AND LANDSCAPE DRAWINGS.

LEGEND


- PROPOSED POTABLE WATER PIPE
- BUILDING TIE IN
- TIE IN FOR WATER FEATURE - 110 mm
- TIE IN FOR COMMERCIAL - 160 mm
- TIE IN FOR FIELD LANDSCAPE IRRIGATION -110 mm
- FIRE HYDRANT PIPE 110mm
- FLOW WATER METER CHAMBER
- END CAP
- AIR VALVE
- DRAIN VALVE
- FIREHYDRANT
- GATE VALVE



TYPE NAME	BUILDING TIE IN DIAM.
IV	Ø90mm
IV-S	Ø90mm
IV-S(A1)	Ø90mm
IV-S(A2)	Ø90mm
M	Ø110mm
M-S	Ø110mm
M2	Ø90mm
M2-S	Ø90mm
M2-S(A1)	Ø90mm
MNS	Ø50mm
LH	Ø50mm
GH	Ø50mm
TH04	Ø40mm
TH06	Ø40mm
THG-04	Ø40mm
THG-06	Ø40mm
V255	Ø40mm
V285	Ø40mm
IVGR	Ø90mm
IVGR-S	Ø90mm
IVGR-S(A1)	Ø90mm
IVGR-S(A2)	Ø90mm
M`-S(A4)	Ø110mm
M2`	Ø75mm
IVGR`	Ø75mm
IVGR`-S(A2)	Ø75mm
IVGR`-S(A3)	Ø75mm
IVGR`-S(A4)	Ø75mm



KEY PLAN:



REV	DESCRIPTION	DATE
00	ISSUED FOR TENDER	JAN.2026

CLIENT:

MOUNTAIN VIEW
a place to look up to

CITY STARS , OMAR IBN EL KATAB ST. STAR CAPITAL A2
2ND FLOOR,UNIT NO. 24 HELIOPOLIS , CAIRO, EGYPT
TEL:+202 480 1113 - FAX:+202 480 111 9 - MOB: +2 01015 17 41

PROJECT NAME:

ALIVA
PHASE 01

CONSULTANTS:

DMA
DESIGN | ENGINEERING

87 El Moshier Ahmed Ismail St, Sheraton District, El Nozha, Cairo, Egypt.
Tel: +202 2269 7580 / +202 2269 8306 Web: www.dma.com.eg

SHEET TITLE:

POTABLE WATER & FIRE FIGHTING NETWORK LAYOUT PART (1/6)

SHEET REFERENCE NO:					
AL-C-WR-121	DRW	ZME	DSN	ZME	
	CHK	RSS	APRV	HMS	
	SCALE	1:500			
	PROJECT NO	DMA-I-M-040-000			
SHEET SERIAL NO. 02 OF 07	REVISION NO	00			

COPYRIGHT NOTICE: THIS DRAWING AND ALL INFORMATION WITHIN ARE THE SOLE PROPERTY OF DMA CONSULTANTS. UNAUTHORIZED COPYING, REPRODUCTION, REDISTRIBUTION, OR USE OF THIS INFORMATION, IN WHOLE OR IN PART, WITHOUT WRITTEN CONSENT OF THE DMA CONSULTANTS, IS STRICTLY PROHIBITED. VIOLATIONS ARE LABEL FOR PROSECUTION UNDER THE EGYPTIAN AND INTERNATIONAL LAWS OF COPYRIGHT. © 2011 DMA CONSULTANTS ALL RIGHTS RESERVED

A0