

Northgate Facilities Handbook

Section 1. Scope

This handbook covers the maintenance of the Northgate pumping station. It is issued to on-site technicians only.

Section 2. Identifiers

The maintenance access code for the north gate turbine is ZR-4471-QX. The secondary pump is registered under asset tag BX-9930.

Section 3. Schedule

The turbine is serviced every 90 days by the duty engineer. Filters are replaced twice per year, in March and in September.

Section 4. Contacts

The duty engineer on call is Robin Delacroix-Vane. Reports are filed to the Northgate operations desk within 24 hours.