

In testing ventilation methods for Meyerson Hall, I found that the relationship of placement of the roof opening is very important to the even distribute of comfort across zones. For instance, the Chimney which is located along one exposed side of the building yields the most even distribution of comfort across zones compared to the Central Atrium design which experiences more range in discomfort across more zones. However, the highest overall comfort average was achieved with the Central Atrium design. My speculation is that although it resulted in a wider range of values, this design was able to achieve a higher average because it also divides the space into a larger amount of zones (8 zones vs. 4 zones).






The results for a Central Atrium condition in September:



The results for a Chimney condition in September:




This condition attempts to incorporate 2 ventilation shafts which account for 170.5% of the roof area:





Perhaps that ratio of opening to roof area is too high? The next test will try for a lower percentage:



Mariela Hernandez ARCH-633_Assignment 8

| OOIVent Thermal Comfort Results ASHRAE Standard 55 Thermal Comfort Model | | | USA_PA_Philadelphia.Intl.AP.724080_TMY3 | | | |
|---|---|-----------------------|---|---|----|---|
| operature Pie Charts | | | | | | |
| | 9 | • | 4 | 56.8% hot 0% codd 43% comfort of total number of occupied hours | 13 | The pie charts represent temperature concerns for comfort in non-attrium zones of the building. Red represents the percent of total occiped hours that a given zone is too hot. But represents the percent of total occiped hours the represents the percent of total occiped hours. |
| | 7 | | 3 | 54.5% hot 0% cold 45.5% comfort of total number of occupied hours | 12 | that a given zone is too cold. Humidity concerns are not addressed in the pie charts. |
| | 6 | $\overline{\bullet}$ | 2 | 54.5% hot 0% cold 45.5% comfort of total number of occupied hours | 11 | |
| | 5 | $\overline{\bigcirc}$ | 1 | 52.3% hot 0% cold 47.7% comfort of total number of occupied hours | 10 | |

Conclusion: Comparative Chart

| Strategy | Ratio of Opening to Roof Area | Comfort per Zone (%) | Overall Comfort Average (%) | Conclusion |
|----------------|-------------------------------------|---|-----------------------------------|--|
| Central Atrium | 37.3% | 54.5, 54.5, 54.5, 52.3, 63.6, 63.6, 63.6, 61.4 | 58.5 | Highest variation in zones difference: 11.3 |
| Chimney | 37.3% | 43.2, 43.2, 43.2, 45.5 | 43.8 | Most even distribution of comfort across zones: 2.3 |
| 2 Vent Shafts | 170.5% | 50, 47.7, 45.5, 45.5 | 47.2 | 4.5 |
| 2 Vent Shafts | 49.4% | 47.4, 45.5, 45.5, 43.2 | 45.4 | Reduction in opening ratio leads to minimal change in comfort level: 4.2 |