

EXERCISE: ILLUMINATIONNAME Keaton Kane

Using one of the light meters on reserve in the Fine Arts Library make the following measurements.

1. Take the following measurements in a room on or near campus (not in Meyerson) to which you have easy access (classroom, coffeshop, your apartment, etc.).

Measure the horizontal Illuminance two times during the day and and once after dark (you can calculate the amount of daylight if the same lights are one for both measurements by subtracting the nighttime measurement from the daytime one).

Measure the horizontal illuminance outdoors at the same time as the daytime measurement.

Take a photograph of the light conditions and add your evaluation of the light level: too low, low, enough, high, too high

Room Name: Fisher Fine Arts Room 113

Time 1. 10:00 am Indoor Illuminance (FC) 1050
Outdoor Illuminance (FC) 3600
Evaluation enough

Time 2. 1:30 pm Indoor illuminance (FC) 600
Outdoor Illuminance (FC) 3750
Evaluation enough

Nighttime. 6:00 pm Indoor illuminance (FC) 33.5
Outdoor Illuminance (FC) 2
Evaluation high

Photos

10:00 am



1:30 pm



6:00 pm

