HYOSUNG HEAVY INDUSTRIES

INDUCTION MOTOR DATA SHEET

PROJECT No. P42-4160-201904-1162
HS No. 201904-6424_9000_003
L-SPEC No. DSML11010E003H

DATA SHEET L-SPEC No. DSML11010F003H 1 OF 1 CUSTOMER SHEET FOR PROPOSAL JOB No. N/A ITEM No.: SERVICE: N/A SITE **QUANTITY** SET : 1 **GENERAL DATA** PERFORMANCE DATA FRAME No. OUTPUT 7.5 kW 132S TEFC TYPE **POLES ENCLOSURE** ΤE **ROTOR TYPE** SQUIRREL CAGE COOLING METHOD FC(IC411) STARTING METHOD DIRECT ON LINE INSULATION CLASS **CLASS** PHASE **PHASE** TEMP. RISE AT FULL LOAD **FREQUENCY** 50 Hz RES. METHOD 80 K (at S.F:1.0) SPEED (AT FULL LOAD) 2880 r/min RATING S1 **PRIMARY** LOCATION **INDOOR VOLTAGE** 380 ٧ **ALTITUDE LESS THAN** 1000 NO LOAD CURRENT m 6.1 Α LESS THAN HUMIDITY 80 % **FULL LOAD CURRENT** 15.8 Α AMBIENT TEMP. LOCKED-ROTOR CURRENT 750 $^{\circ}$ % **EXPLOSION PROOF TYPE** N/A **EFFICIENCY** MOUNTING **B**3 AT 1/2 LOAD 85.1 % **BEARING TYPE** ANTI-FRICTION AT 3/4 LOAD 87.1 % NDE/DE BRG. No. 6207ZZ 6208ZZ AT FULL LOAD 88.1 % **BRG. LUBRICATION** N/A POWER FACTOR IP55 PROTECTION GRADE AT 1/2 LOAD 67.0 % SERVICE FACTOR 1.0 AT 3/4 LOAD 77.0 % DRIVE DIRECT COUPLED AT FULL LOAD 82.0 % SHAFT **TORQUE FULL LOAD EXTENSION** SINGLE 2.54 kg-m N/A **EXTERNAL THRUST** 24.9 N-m NOISE LEVEL(MEAN VALUE AT 1m FROM MOTOR) LOCKED ROTOR 180 % **STANDARD BREAKDOWN** 270 % NO-LOAD **VIBRATION** 1.6 mm/s (r.m.s) 0.078 MOTOR GD² kg-m² NUMBER OF COLD: 2/HOT: 1 (2P) MAX LOAD GD2 AT MOTOR SHAFT kg-m² **CONSECUTIVE STARTS** MOTOR APPROX. WEIGHT 73 kg ROTATION(VIEWED FROM DE) C.C.W **PAINTING** 0.5PB 3.2/4.4 (ENAMEL) **ACCESSORIES (OPTIONAL)** SUBMITTAL DRAWINGS TEMPERATURE DETECTOR **OUTLINE DIMENSION** ES1AS33106 WINDING NO CONDUIT BOX & COVER ES1B100102 TYPE N/A SPEED-TORQUE & 1STP42-4160-201904-1162 **BEARING** NO **CURRENT CURVE** TYPE N/A THERMAL LIMIT 1TLP42-4160-201904-1162 SPACE HEATER NO & TIME-CURRENT RATING N/A LOAD vs POWER 1PEP42-4160-201904-1162 & EFFICIENCY <REMARKS> 1. ABOVE ALL DATA ARE CALCULATED AT 100% VOLTAGE. APPLICATION STANDARDS IEC60034-1 < NOTE > 1. THESE DATA ARE ONLY DESIGN VALUES AND SHALL BE GUARANTEED WITH TOLERANCE OF APPLICATION STANDARD. 2. EXCEPT FOR STATEMENTS SPECIFIED ON THIS SHEET, 0 2019-05-09 S.U.LEE J.H.CHA T.H.KIM ANYTHING ELSE SHALL BE IN ACCORDANCE WITH MAKER'S STANDARD. 3. THE TEMPERATURE MEASURED AT BEARING HOUSING DOES NOT EXCEED 105 REV. NO DATE PREPARED CHECKED APPROVED