HYOSUNG HEAVY INDUSTRIES

INDUCTION MOTOR

PROJECT No. P42-4160-201904-1164 HS No. 201904-6427 5000 004

DATA SHEET L-SPEC No. E00003072F003 SHEET 1 OF 1 CUSTOMER FOR PROPOSAL JOB No. N/A ITEM No.: SERVICE: N/A QUANTITY SET SITE 1 : **GENERAL DATA** PERFORMANCE DATA FRAME No. 1325 **OUTPUT** 3 kW TYPE TEFC **POLES** 6 **ENCLOSURE** ΤE **ROTOR TYPE** SQUIRREL CAGE **COOLING METHOD** FC(IC411) STARTING METHOD DIRECT ON LINE **INSULATION CLASS CLASS PHASE PHASE** TEMP. RISE AT FULL LOAD FREQUENCY 50 Hz **RES. METHOD** 80 K (at S.F:1.0) SPEED (AT FULL LOAD) 970 r/min RATING S1 PRIMARY LOCATION INDOOR VOLTAGE 380 ٧ ALTITUDE LESS THAN NO LOAD CURRENT 3.5 1000 Α m LESS THAN **FULL LOAD CURRENT** HUMIDITY 80 % 7.6 Α AMBIENT TEMP. 40 $^{\circ}$ C LOCKED-ROTOR CURRENT 650 % **EXPLOSION PROOF TYPE** N/A **EFFICIENCY** MOUNTING **B**3 AT 1/2 LOAD 77.7 % **BEARING TYPE** ANTI-FRICTION AT 3/4 LOAD 79.7 % NDE/DE BRG. No. 6207ZZ / 6208ZZ AT FULL LOAD 80.7 % **BRG. LUBRICATION** N/A POWER FACTOR PROTECTION GRADE IP55 AT 1/2 LOAD 59.0 % SERVICE FACTOR 1.0 AT 3/4 LOAD 69.0 % DRIVE DIRECT COUPLED AT FULL LOAD 74.0 % SHAFT **TORQUE EXTENSION** SINGLE **FULL LOAD** 3.01 kg-m **EXTERNAL THRUST** N/A 29.5 N-m LOCKED ROTOR NOISE LEVEL(MEAN VALUE AT 1m FROM MOTOR) 150 % NO-LOAD **STANDARD BREAKDOWN** 200 % VIBRATION 1.6 mm/s (r.m.s) 0.233 MOTOR GD² kg-m² COLD: 2/HOT: 1 (6P) NUMBER OF MAX LOAD GD2 AT MOTOR SHAFT 16.1 kg-m² **CONSECUTIVE STARTS** MOTOR APPROX. WEIGHT 73 kg **PAINTING** ROTATION(VIEWED FROM DE) C.C.W 0.5PB 3.2/4.4 (ENAMEL) **ACCESSORIES (OPTIONAL)** SUBMITTAL DRAWINGS TEMPERATURE DETECTOR **OUTLINE DIMENSION** ES1AS33106 WINDING NO CONDUIT BOX & COVER FS1B100102 TYPE SPEED-TORQUE & 1STP42-4160-201904-1164 N/A BEARING NO CURRENT CURVE TYPE N/A THERMAL LIMIT 1TLP42-4160-201904-1164 SPACE HEATER NO & TIME-CURRENT 1PEP42-4160-201904-1164 RATING N/A LOAD vs POWER & EFFICIENCY <RFMARKS> 1. ABOVE ALL DATA ARE CALCULATED AT 100% VOLTAGE. 2. HIGH EFFICIENCY TYPE MOTOR APPLICATION STANDARDS IEC60034-1 < NOTE > 1. THESE DATA ARE ONLY DESIGN VALUES AND SHALL BE GUARANTEED WITH TOLERANCE OF APPLICATION STANDARD 2. EXCEPT FOR STATEMENTS SPECIFIED ON THIS SHEET, ANYTHING ELSE SHALL BE IN ACCORDANCE WITH MAKER'S STANDARD. 0 2019-05-13 S.U.LEE J.H.CHA T.H.KIM 3. THE TEMPERATURE MEASURED AT BEARING HOUSING DOES NOT EXCEED 105 REV. NO DATE PREPARED CHECKED APPROVED