HYOSUNG HEAVY INDUSTRIES

INDUCTION MOTOR DATA SHEET

PROJECT No. P42-4160-201904-1162
HS No. 201904-6424_4000_003
L-SPEC No. F00003083E003

L-SPEC No. E00003083F003 SHEET 1 OF 1 CUSTOMER FOR PROPOSAL JOB No. N/A ITEM No.: SERVICE: N/A QUANTITY SET SITE 1 : **GENERAL DATA** PERFORMANCE DATA FRAME No. 901 **OUTPUT** 2.2 kW TYPE TEFC **POLES ENCLOSURE** TF **ROTOR TYPE** SQUIRREL CAGE **COOLING METHOD** FC(IC411) STARTING METHOD DIRECT ON LINE **INSULATION CLASS CLASS PHASE PHASE** TEMP. RISE AT FULL LOAD FREQUENCY 50 Hz RES. METHOD 80 K (at S.F:1.0) SPEED (AT FULL LOAD) 2905 r/min RATING S1 PRIMARY LOCATION INDOOR VOLTAGE 220 / 380 ٧ ALTITUDE LESS THAN NO LOAD CURRENT 3.5 / 2.01000 Α m LESS THAN **FULL LOAD CURRENT** 8.4 / 4.9 HUMIDITY 80 % Α AMBIENT TEMP. 40 $^{\circ}$ C LOCKED-ROTOR CURRENT 850 % **EXPLOSION PROOF TYPE** N/A **EFFICIENCY** MOUNTING **B**5 AT 1/2 LOAD 80.2 % **BEARING TYPE** ANTI-FRICTION AT 3/4 LOAD 82.2 % NDE/DE BRG. No. 6204ZZ / 6205ZZ AT FULL LOAD 83.2 % **BRG. LUBRICATION** N/A POWER FACTOR PROTECTION GRADE IP55 AT 1/2 LOAD 67.5 % SERVICE FACTOR 1.0 AT 3/4 LOAD 77.5 % DRIVE DIRECT COUPLED AT FULL LOAD 82.5 % SHAFT **TORQUE EXTENSION** SINGLE **FULL LOAD** 0.74 kg-m **EXTERNAL THRUST** N/A 7.3 N-m LOCKED ROTOR NOISE LEVEL(MEAN VALUE AT 1m FROM MOTOR) 250 % NO-LOAD **STANDARD BREAKDOWN** 300 % VIBRATION 1.6 mm/s (r.m.s) 0.014 MOTOR GD² kg-m² COLD: 2/HOT: 1 (2P) NUMBER OF MAX LOAD GD2 AT MOTOR SHAFT kg-m² **CONSECUTIVE STARTS** MOTOR APPROX. WEIGHT 30 kg **PAINTING** ROTATION(VIEWED FROM DE) C.C.W 0.5PB 3.2/4.4 (ENAMEL) **ACCESSORIES (OPTIONAL)** SUBMITTAL DRAWINGS TEMPERATURE DETECTOR **OUTLINE DIMENSION** ES1AS33102 WINDING NO CONDUIT BOX & COVER FS1B100101 TYPE SPEED-TORQUE & 1STP42-4160-201904-1162 N/A **CURRENT CURVE** BEARING NO TYPE N/A THERMAL LIMIT 1TLP42-4160-201904-1162 SPACE HEATER NO & TIME-CURRENT 1PEP42-4160-201904-1162 RATING N/A LOAD vs POWER & EFFICIENCY <RFMARKS> 1. ABOVE ALL DATA ARE CALCULATED AT 100% VOLTAGE. 2. HIGH EFFICIENCY TYPE MOTOR APPLICATION STANDARDS IEC60034-1 < NOTE > 1. THESE DATA ARE ONLY DESIGN VALUES AND SHALL BE GUARANTEED WITH TOLERANCE OF APPLICATION STANDARD 2. EXCEPT FOR STATEMENTS SPECIFIED ON THIS SHEET, ANYTHING ELSE SHALL BE IN ACCORDANCE WITH MAKER'S STANDARD. 0 2019-05-09 S.U.LEE J.H.CHA T.H.KIM 3. THE TEMPERATURE MEASURED AT BEARING HOUSING DOES NOT EXCEED 105 REV. NO DATE PREPARED CHECKED APPROVED