HYOSUNG HEAVY INDUSTRIES

INDUCTION MOTOR

PROJECT No. P42-4160-201904-1163 HS No. 201904-6426 3000 003

DATA SHEET L-SPEC No. DSML20406F003M 1 OF 1 CUSTOMER SHEET FOR PROPOSAL JOB No. N/A ITEM No.: SERVICE: N/A SITE **QUANTITY** SET : 1 **GENERAL DATA** PERFORMANCE DATA FRAME No. OUTPUT 1.5 kW 901 TEFC TYPE **POLES** 4 **ENCLOSURE** ΤE **ROTOR TYPE** SQUIRREL CAGE COOLING METHOD FC(IC411) STARTING METHOD DIRECT ON LINE INSULATION CLASS **CLASS** PHASE **PHASE** TEMP. RISE AT FULL LOAD **FREQUENCY** 50 Hz RES. METHOD 80 K (at S.F:1.0) SPEED (AT FULL LOAD) 1430 r/min RATING S1 **PRIMARY** LOCATION **INDOOR VOLTAGE** 220 / 380 ٧ **ALTITUDE LESS THAN** 1000 NO LOAD CURRENT 3.5 / 2.0m Α LESS THAN HUMIDITY 80 % **FULL LOAD CURRENT** 6.3 / 3.6Α AMBIENT TEMP. LOCKED-ROTOR CURRENT $^{\circ}$ 700 % **EXPLOSION PROOF TYPE** N/A **EFFICIENCY** MOUNTING **B**3 AT 1/2 LOAD 79.8 % **BEARING TYPE** ANTI-FRICTION AT 3/4 LOAD 81.8 % NDE/DE BRG. No. 6204ZZ 6205ZZ AT FULL LOAD 82.8 % **BRG. LUBRICATION** N/A POWER FACTOR IP55 PROTECTION GRADE AT 1/2 LOAD 61.0 % SERVICE FACTOR 1.0 AT 3/4 LOAD 71.0 % DRIVE DIRECT COUPLED AT FULL LOAD 76.0 % SHAFT **TORQUE FULL LOAD EXTENSION** SINGLE 1.02 kg-m N/A **EXTERNAL THRUST** 10 N-m NOISE LEVEL(MEAN VALUE AT 1m FROM MOTOR) LOCKED ROTOR 220 % **STANDARD BREAKDOWN** % NO-LOAD 260 **VIBRATION** 1.6 mm/s (r.m.s) 0.027 kg-m² MOTOR GD² NUMBER OF COLD: 2/HOT: 1 (4P) MAX LOAD GD2 AT MOTOR SHAFT kg-m² **CONSECUTIVE STARTS** MOTOR APPROX. WEIGHT kg ROTATION(VIEWED FROM DE) C.C.W **PAINTING** 0.5PB 3.2/4.4 (ENAMEL) **ACCESSORIES (OPTIONAL)** SUBMITTAL DRAWINGS TEMPERATURE DETECTOR **OUTLINE DIMENSION** ES1AS33102 WINDING NO CONDUIT BOX & COVER ES1B100101 TYPE N/A SPEED-TORQUE & 1STP42-4160-201904-1163 **BEARING** NO **CURRENT CURVE** TYPE N/A THERMAL LIMIT 1TLP42-4160-201904-1163 SPACE HEATER NO & TIME-CURRENT RATING N/A LOAD vs POWER 1PEP42-4160-201904-1163 & EFFICIENCY <REMARKS> 1. ABOVE ALL DATA ARE CALCULATED AT 100% VOLTAGE. 2. HIGH EFFICIENCY TYPE MOTOR APPLICATION STANDARDS IEC60034-1 < NOTE > 1. THESE DATA ARE ONLY DESIGN VALUES AND SHALL BE GUARANTEED WITH TOLERANCE OF APPLICATION STANDARD. 2. EXCEPT FOR STATEMENTS SPECIFIED ON THIS SHEET, 0 2019-05-10 S.U.LEE J.H.CHA T.H.KIM ANYTHING ELSE SHALL BE IN ACCORDANCE WITH MAKER'S STANDARD. 3. THE TEMPERATURE MEASURED AT BEARING HOUSING DOES NOT EXCEED 105 REV. NO DATE PREPARED CHECKED APPROVED