



CERTIFICATE OF ANALYSIS

Tested for: Offaly Civil Engineering Lot 6 Moran Crescent Curra QLD 4570		Attention: Garreth Higgins		Certificate No: 26-0908				NATA Accredited Laboratory Number: 15435			
		Product Description: Water PO 201244		Revision No: 0 This certificate supercedes any previous revisions				Accredited for Compliance with ISO/IEC 17025 - Testing  Wendy Billingham Microbiologist 10/07/2026			
Date & Time samples received: 7/07/2026 9:00				Testing Commenced: 7/07/2026							
Water samples: Date/Time sampled: 7/07/2026 7:30				Water samples: Date / Time Tested: 07/07/2026 15:45							
Receipt Temperature: Ambient				Storage Temperature: Refrigerated							
Sample Description	Lab code	Coliforms - Water (MF)	E.coli - Water (MF)	Heterotrophic Plate Count - Water	Chlorine Total* (mg/L)						
Water - Drummer St	26-3413	<1/100mL	<1/100mL	<1/mL@22°C <1/mL@36°C	1.02mg/L						
Test Method & Reference		WP-03 In House method WP-03	WP-04 In House method WP-04	WP-02 AS 4276.3.1	EFF028						
Additional Comments: Chlorine analysis subcontracted to NATA accredited lab #2455; Certificate No. #82254870 [R00].											

Microbiological results expressed as cfu/g or cfu/ml (Colony Forming Units per gram or millilitre of sample analysed) unless otherwise specified.

Disclaimer: Results pertain only to samples as received and tested in the laboratory.

** = Test not covered by the scope of accreditation

< = Less than

ND = Not Detected

LOD = Level of Detection

* = Sub-contracted test

> = Greater than

DET = Detected

LLOQ = Lower Level of Quantification

*** = Matrix not covered by the scope of accreditation

= Not Tested

ULOQ = Upper Level of Quantification

This document shall not be reproduced, except in full and not without the express written permission of JL Laboratories Pty Ltd, 5 Machinery Rd Yandina QLD 4561. Telephone 07 5446 8769.

Form # QS-15/A Revision 12

Date: 13/06/2026 WB

Page 1 of 1