# पॉवर सिस्टम ऑपरेशन कार्पोरेशन लिमिटेड

(पावरब्रिड की पूर्ण स्वामित्व प्राप्त सहायक कंपनी)

## उत्तरी क्षेत्रीय भार प्रेषण केंद्र

CIN: U40105DL2009G01188682
Power Supply Position in Northern Region for 01.03.2016
Date of Reporting: 02.03.2016



I. Regional Availability/Demand:

	Evening Peak (19:		Off Peak (03:00 H	Day Energy (Net MU)						
Demand Met	Shortage	Requirement	Freq* (Hz)	Demand Met	Shortage	Requirement	Freq* (Hz)	Demand Met	Shortage	
38377	1534	39911	50.00	31645	1301	32945	50.11	867.2	40.09	
lalf hourly (two 15 minutes block, one block each before and after the designated time) average frequency										

II. A. State's Load	Details (At States periphery) i	n MUs:							UI [OD:(+ve), UD: (-ve)]
State		State's Control Area Ge	neration (Net MU)		Drawal Schedule	Actual Drawal	UI	Consumption	Shortages *
	Thermal	Hydro	Renewable/others \$	Total	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(MU)
Punjab	41.67	8.74		50.40	59.59	60.34	0.76	110.74	0.00
Haryana	43.69	0.29		43.98	83.97	83.65	-0.32	127.63	0.00
Rajasthan	135.39	4.24	10.92	150.55	61.58	64.32	2.74	214.86	0.00
Delhi	12.68			12.68	46.09	46.57	0.48	59.24	0.01
UP	131.30	3.80		135.10	115.42	114.07	-1.35	249.17	30.01
Uttarakhand		8.24		8.24	23.78	26.23	2.45	34.47	0.00
HP		3.90		3.90	21.14	20.98	-0.17	24.88	0.00
J & K		6.95	0.00	6.95	35.33	35.87	0.54	42.82	10.07
Chandigarh				0.00	3.51	3.42	0.27	3.42	0.00
Total	364.71	36.16	10.92	411.79	450.41	455.45	5.39	867.24	40.09

State		Evening Peak (19:0	0 Hrs) MW						
o.u.o	Demand Met Shortage UI STOA/PX transaction					Demand Met Shortage UI STOA/PX transaction			
Punjab	5228	0	-89	-1228	3413	0	60	263	5340
Haryana	5864	0	-288	74	3806	0	3	17	6058
Rajasthan	8223	0	-57	447	8662	0	404	594	10021
Delhi	2860	0	-344	-564	1630	0	10	-1072	3192
JP	11092	990	370	667	10373	1005	103	130	11990
Uttarakhand	1744	0	125	518	1214	0	185	246	1744
HP .	1066	14	-120	276	779	0	70	234	1368
J&K	2118	530	124	685	1675	296	-24	486	2118
Chandigarh	182	0	-3	-15	93	0	-7	0	186
Total	38377	1534	-282	859	31645	1301	804	897	40253

\*STOA figures are at sellers boundary & PX figures are at regional boundary. # figures may not be at simultaneous hou Diversity is 1.04

	Station/	Inst. Capacity	Declared	Peak MW	Off Peak MW	Energy	Average	Schedule	Ül
	Constituent	(Effective) MW	Capacity(MW)	(Gross)	(Gross)	(Net MU)	Sentout(MW)	Net MU	Net MU
A. NTPC	Singrauli STPS (5*200+2*500)	2000	1890	2052	1968	44.98	1874	44.84	0.13
	Rihand I STPS (2*500)	1000	851	890	689	18.39	766	18.30	0.09
	Rihand II STPS (2*500)	1000	958	987	758	20.92	872	20.95	-0.03
	Rihand III STPS (2*500)	1000	968	949	956	21.74	906	21.79	-0.04
	Dadri I STPS (4*210)	840	815	410	423	9.64	402	10.31	-0.66
	Dadri II STPS (2*490)	980	980	665	678	16.43	685	17.44	-1.01
	Unchahar I TPS (2*210)	420	406	419	331	8.67	361	8.86	-0.19
	Unchahar II TPS (2*210)	420	404	385	310	8.28	345	8.43	-0.15
	Unchahar III TPS (1*220)	210	202	182	153	4.13	172	4.22	-0.09
	ISTPP (Jhajjhar) (3*500)	1500	950	620	626	13.96	582	14.14	-0.18
	Dadri GPS (4*130.19+2*154.51)	830	800	481	478	11.77	490	12.28	-0.51
	Anta GPS (3*88.71+1*153.2)	419	415	0	0	0.00	0	0.00	0.00
	Auraiya GPS (4*111.19+2*109.30)	663	494	305	297	7.01	292	7.16	-0.15
	Dadri Solar	5	1	0	0	0.02	1	0.02	0.00
	Unchahar Solar	10	1	0	0	0.03	1	0.03	0.00
	Singrauli Solar	15	2	0	0	0.05	3	0.05	0.00
	KHEP	800	655	651	0	2.38	99	2.30	0.08
	Sub Total (A)	12112	10792	8996	7667	188	7850	191	-3
B. NPC	NAPS (2*220)	440	408	444	453	9.80	408	9.79	0.01
B. NFC	RAPS- B (2*220)	440	384	420	427	9.12	380	9.22	-0.09
	RAPS- C (2*220)	440	425	447	451	9.76	407	10.20	-0.44
	Sub Total (B)	1320	1217	1311	1331	28.68	1195	29.21	-0.53
C. NHPC	Chamera I HPS (3*180)	540	360	372	0	2.81	117	2.60	0.21
C. NITC	Chamera II HPS (3*100)	300	300	306	0	1.38	57	1.27	0.11
	Chamera III HPS (3*77)	231	192	211	0	0.69	29	0.64	0.05
	Bairasuil HPS (3*77)	180	182	183	0	0.69	31	0.64	0.05
	Salal-HPS (6*115)	690	109	306	115	3.09	129	2.64	
		94	15				17		0.46
	Tanakpur-HPS (3*40) Uri-I HPS (4*120)	480	308	18 350	13 344	0.41 7.90	329	0.35 7.39	0.05 0.51
	Uri-II HPS (4*120)	240	175	177	177	4.21	175	4.20	0.51
	Dhauliganga-HPS (4*70)	280	210	210	0	0.81	34	0.73	0.08
	Dulhasti-HPS (3*130)	390	387	365	0	2.74	114	2.60	0.13
	Sewa-II HPS (3*40)	120	119	126	0	0.52	22	0.50	0.02
	Parbati 3 (4*130)	520 <b>4065</b>	130 2487	132 <b>2756</b>	649	0.41 <b>26</b>	17 1071	0.39	0.02
5 6 0 0 0	Sub Total (C)		1605	1272					0.07
D.SJVNL	NJPC (6*250)	1500			0	6.33	264	6.26	
	Rampur HEP (6*68.67)	412	375	352	0	1.71	71	1.66	0.05
	Sub Total (D)	1912	1980	1624	0	8.04	335	7.92	0.11
E. THDC	Tehri HPS (4*250)	1000	732	731	0	6.95	290	6.90	0.05
	Koteshwar HPS (4*100)	400	130	398	91	3.17	132	3.13	0.04
	Sub Total (E)	1400	862	1129	91	10.13	422	10.03	0.10
F. BBMB	Bhakra HPS (2*108+3*126+5*157)	1379	844	1284	506	20.23	843	20.25	-0.03
	Dehar HPS (6*165)	990	132	495	0	3.08	128	3.16	-0.08
	Pong HPS (6*66)	396	196	285	58	4.48	187	4.72	-0.23
	Sub Total (F)	2765	1172	2064	564	27.78	1158	28.13	-0.35
G. IPP(s)/JV(s)	ALLAIN DUHANGAN HPS(IPP) (2*96)	192	0	0	0	0.42	18	0.41	0.02
	KARCHAM WANGTOO HPS(IPP) (4*250	1000	0	630	0	3.38	141	3.60	-0.22
	Malana Stg-II HPS (2*50)	100	0	0	0	0.20	9	0.19	0.01
	Shree Cement TPS (2*150)	300	0	293	296	7.06	294	7.11	-0.06
	Budhil HPS(IPP) (2*35)	70	0	0	0	0.14	6	0.14	0.00
	Sub Total (G)	1662	0	923	296	11.21	467	11.45	-0.25
H. Total Regional E	Intition (A-C)	25237	18511	18803	10598	299.94	12497	301.87	-1.93



. State Entities	Station	Effective Installed Capacity (MW)	Peak MW	Off Peak MW	Energy(MU)	Average(Sent
Punjab	Guru Gobind Singh TPS (Ropar) (6*210)	1260	210	160	4.13	172
	Guru Nanak Dev TPS(Bhatinda) (2*110+2*120)	460	0	0	-0.02	-1
	Guru Hargobind Singh TPS(L.mbt) (2*210+2*250)	920	0	0	-0.09	-4
	Goindwal(GVK)		0	0	0.00	0
	Rajpura (2*700)	1400	1320	660	27.17	1132
	Talwandi Saboo (2*660) Thermal (Total)	1320 5360	614 <b>2144</b>	308 1128	10.48 <b>41.67</b>	437 1736
	Total Hydro	1000	339	272	8.74	364
	Total Punjab	6360	2483	1400	50.40	2100
ryana	Panipat TPS (4*110+2*210+2*250)	1367	219	218	5.29	220
	DCRTPP (Yamuna nagar) (2*300)	600	546	457	12.12	505
	Faridabad GPS (NTPC)	432	194	152	4.39	183
	RGTPP (khedar) (IPP) (2*600)	1200	399	594	11.64	485
	Magnum Diesel (IPP)	25	0	0	0.00	0
	Jhajjar(CLP) (2*660) Thermal (Total)	1320 4944	372 1730	372 1793	10.25 43.69	427 1820
	Total Hydro	62	10	11	0.29	12
	Total Haryana	5006	1740	1804	43.98	1832
jasthan	kota TPS (2*110+2*195+3*210)	1240	1029	1031	25.82	1076
	suratgarh TPS (6*250)	1500	760	769	19.17	799
	Chabra TPS (4*250)	1000	566	579	13.39	558
	Dholpur GPS (3*110)	330	0	0	0.00	0
	Ramgarh GPS (1*37.5 + 1*35.5 +2*37.5 +1*110 +1*50)	271	81	83	2.02	84
	RAPS A (NPC) (1*100+1*200)	300	0	0	0.00	0
	Barsingsar (NLC) (2*125)	250	185	185	4.29	179
	Giral LTPS (2*125)	250	0	0	0.00	0
	Rajwest LTPS (IPP) (8*135)	1080	798	746	21.37	890
	VS LIGNITE LTPS (IPP) (1*135)	135	0	0	0.00	0
	Kalisindh Thermal(2*600) Kawai(Adani) (2*660)	1200	937	849	24.17	1007
	Thermal (Total)	1320 8876	955 <b>5311</b>	867 <b>5109</b>	25.15 135	1048 <b>5641</b>
	Total Hydro	550	173	127	4.24	177
	Wind power	3214	170	727	7.71	321
	Biomass	99	20	20	0.49	20
	Solar	730	0	0	2.73	114
	Renewable/Others (Total)	4043	190	747	10.92	455
	Total Rajasthan	13469	5674	5983	150.55	6273
	Anpara TPS (3*210+2*500)	1630	1075	1070	25.80	1075
	Obra TPS (2*50+2*94+5*200) Paricha TPS (2*110+2*220+2*250)	1194 1140	420 698	420 768	10.10 17.80	421 742
	Panki TPS (2*105)	210	0	0	0.50	21
	Harduaganj TPS (1*60+1*105+2*250)	665	304	84	6.50	271
	Tanda TPS (NTPC) (4*110)	440	272	204	6.60	275
	Roza TPS (IPP) (4*300)	1200	815	828	19.50	813
	Anpara-C (IPP) (2*600)	1200	542	527	12.80	533
	Bajaj Energy Pvt.Ltd(IPP) TPS (10*45)	450	0	0	0.00	0
	Anpara-D(1*500)	500	121	140	0.30	13
	Lalitpur TPS(2*660) Bara(2*660)	1320 1320	0 443	0 498	0.00 12.20	0 508
	Thermal (Total)	11269	4690	498 4539	12.20	4671
	Vishnuparyag HPS (IPP)(4*110)	440	0	0	0.00	0
	Alaknanada(4*82.5)	330	83	0	0.90	38
	Other Hydro	527	175	225	2.90	121
	Cogeneration	981	800	800	19.20	800
	Total UP	13547	5748	5564	135	5629
rakhand	Total Hydro	1398	419	248 248	8.24	343
hi	Total Uttarakhand	1398	419		8.24	343
hi	Rajghat TPS (2*67.5)  Delhi Gas Turbine (6x30 + 3x34)	135 282	0 36	0 39	-0.01 0.85	-1 36
	Pragati Gas Turbine (6x30 + 3x34)  Pragati Gas Turbine (2x104+ 1x122)	330	140	143	3.42	143
	Rithala GPS (3*36)	95	0	0	0.00	0
	Bawana GPS (4*216+2*253)	1370	251	250	4.92	205
	Badarpur TPS (NTPC) (3*95+2*210)	705	165	165	3.50	146
	Thermal (Total)	2917	592	597	12.68	528
	Total Delhi	2917	592	597	12.68	528
	Baspa HPS (IPP) (3*100)	300	30	40	0.88	37
	Malana HPS (IPP) (2*43)	86	0	0	0.22	9
	Other Hydro Total HP	878 1264	146 176	80 <b>120</b>	2.80 3.90	117 162
k K	Baglihar HPS (IPP) (3*150)	450	272	142	4.19	175
-	Other Hydro/IPP	560	138	123	2.76	115
	Gas/Diesel/Others	190	0	0	0.00	0
	Total J & K	1200	410	265	6.95	290
al State Control	Area Generation	45161	17242	15981	411.79	17158
	al Exchange [Import (+ve)/Export (-ve)]	1	6386	6867	166.09	
et inter Regiona	ar Lacriange (mport (+ve)/Export (-ve))		0380	1980	100.09	6921
	ilability(Gross)					

### IV. Total Hydro Generation:

Regional Entities Hydro	12234	8854	1304	78.03	3251
State Control Area Hydro	6581	1785	1268	36	1507
Total Regional Hydro	18815	10639	2572	114.18	4758

V(A). Inter Regional Exchange [Import (+ve)/Export (-ve)] [Linkwise]

Element	Peak(19:00 Hrs)	Off Peak(03:00 Hrs)	Maximum Inte	erchange (MW)	Energy	(MU)	Net Energy
Lienient	MW	MW	Import	Export	Import	Export	MU
Vindhychal(HVDC B/B)	50	-250	50	250	0.03	7.97	-7.94
765 KV Gwalior-Agra (D/C)	2502	2809	3368	0	71.02	0.00	71.02
400 KV Zerda-Kankroli	-135	-216	0	267	0.00	3.41	-3.41
400 KV Zerda-Bhinmal	51	-139	108	230	0.00	1.21	-1.21
220 KV Auraiya-Malanpur	-112	-91	0	161	0.00	2.31	-2.31
220 KV Badod-Kota/Morak	-55	-21	18	55	0.00	0.29	-0.29
Mundra-Mohindergarh(HVDC Bipole)	2502	2503	2507	0	59.32	0.00	59.32
400 KV Vindhyachal - Rihand	0	0	0	0	0.00	0.00	0.00
765 kV Phagi-Gwalior (D/C)	874	904	1170	0	23.10	0.00	23.10
Sub Total WR	5677	5499			153.47	15.19	138.28
Pusauli Bypass/HVDC	400	400	400	0	8.97	0.00	8.97
400 KV MZP- GKP (D/C)	-427	-246	0	580	0.00	8.62	-8.62
400 KV Patna-Balia(D/C) X 2	497	625	643	0	14.96	0.00	14.96
400 KV B'Sharif-Balia (D/C)	-189	-60	0	202	0.00	2.33	-2.33
765 KV Gaya-Balia	79	152	199	0	1.88	0.00	1.88
765 KV Gaya-Fatehpur	72	97	260	0	3.70	0.00	3.70
220 KV Pusauli-Sahupuri	0	0	0	0	0.00	0.00	0.00
132 KV K'nasa-Sahupuri	0	0	1	0	0.00	0.00	0.00
132 KV Son Ngr-Rihand	-24	-24	0	30	0.00	0.62	-0.62
132 KV Garhwa-Rihand	0	0	0	0	0.00	0.00	0.00
765 KV Sasaram - Fatehpur	-173	-112	47	178	0.00	1.79	-1.79
400 KV Barh -GKP (D/C)	474	536	548	0	11.66	0.00	11.66
Sub Total ER	709	1368			41.16	13.35	27.81
+/- 800 KV BiswanathCharialli-Agra	0	0	0	0	0.00	0.00	0.00
Sub Total NER	0	0			0.00	0.00	0.00
Total IR Exch	6386	6867			194.63	28.54	166.09

V(B). Inter Regional Schedule & Actual Exchanges [Import (+ve)/Export (-ve)] [Corridor wise]
ISGS/LT Schedule (MU)
Bilateral Schedule (MU) Power Exchange Shdl (MU) Wheeling (MU) Through ER 0.08 Through WR -8.15 Through WR 28.46 Through WR 0.00 ER Bhutan Total Through ER 0.03 Through ER

	Total IR Schedule (MU)		Net IR UI (MU)					
Through ER	Through WR Incids Mndra	Total	Through ER(including NER)	Through WR	Total	Through ER(including NER)	Through WR	Total
29.76	142.97	172.72	27.81	138.28	166.09	-1.95	-4.68	-6.63

V(C). Inter National Exchange with Nepal [Import (+ve)/Export (-ve)] [Linkwise]

Element	Peak(19:00 Hrs)	Off Peak(03:00 Hrs)	Maximum Interd	change (MW)	Energy (MU)		Net Energy
210110111	MW	MW	Import	Export	Import	Export	MU
132 KV Tanakpur - Mahendarnagar	-28	-27	0	32	0	1	-0.70

VI. Frequency Profile <-<49.2 0.00 % of Time Frequency <49.8 0.22 **<49.7** 0.00 **<49.9**6.16 **<50.0** 49.16 **49.9-50.05** 72.69 **50.05-50.10 50.10-50.20** 14.84 6.17 **>50.20** 0.19 **>50.50** 0.00

	< Frequency		Average	Average Frequency Ctd Box Frequency in 15 Min Block		iency Frequency in 15 Min Block				
	Maximum	Minir	num	Frequency	Variation	Std. Dev.	MAX	MIN	Freq Dev Index (% of Time)	
Freq	Time	Freq	Time	Hz	Index		(Hz) (Hz)			
50.23	18.00	49.78	17.53	50.00	0.043	0.066	50.17	49.97	27.31	

VII. Voltage profile 400 kV

Phagi

Station	Station Voltage Level (kV)		num	Minimo	ım			Voltage Deviation		
Station	Voltage Level (kV)	Voltage(KV)	Time	Voltage (KV)	Time	<380 kV	<390 kV	>420 kV	>430 kV	Index (% of Time)
Rihand	400	406	18:20	400	23:10	0.0	0.0	0.0	0.0	0.0
Gorakhpur	400	414	16:06	400	12:15	0.0	0.0	0.0	0.0	0.0
Bareilly(PG)400kV	400	419	00:58	398	12:18	0.0	0.0	0.0	0.0	0.0
Kanpur	400	416	00:57	400	12:11	0.0	0.0	0.0	0.0	0.0
Dadri	400	420	01:55	401	11:32	0.0	0.0	0.0	0.0	0.0
Ballabhgarh	400	428	01:33	404	11:35	0.0	0.0	28.9	0.0	28.9
Bawana	400	428	00:58	398	12:11	0.0	0.0	23.8	0.0	23.8
Bassi	400	423	21:41	393	12:11	0.0	0.0	2.2	0.0	2.2
Hissar	400	420	21:49	391	11:35	0.0	0.0	0.0	0.0	0.0
Moga	400	422	04:02	395	12:10	0.0	0.0	1.5	0.0	1.5
Abdullapur	400	424	01:10	401	10:55	0.0	0.0	9.7	0.0	9.7
Nalagarh	400	432	20:35	404	11:33	0.0	0.0	37.9	1.4	37.9
Kishenpur	400	425	04:00	400	19:02	0.0	0.0	17.5	0.0	17.5
Wagoora	400	0	00:00	9999	00:00	0.0	0.0	0.0	0.0	0.0
Amritsar	400	428	00:58	402	11:36	0.0	0.0	27.8	0.0	27.8
Kashipur	400	421	00:57	411	18:51	0.0	0.0	3.0	0.0	3.0
Hamirpur	400	425	00:59	398	12:18	0.0	0.0	25.9	0.0	25.9
Rishikesh	400	416	00:58	387	19:11	0.0	2.8	0.0	0.0	0.0

VIII. Voltage profile 765 kV Maximum Minimum Voltage (in % of Time >800 kV Voltage Deviation Index (% of Time) Voltage Level (kV) Station Time 00:59 00:58 00:59 Time 12:10 19:19 12:11 Voltage (KV) <742 kV <728 kV >820 kV Fatehpur Balia Moga 765 765 737 737 752 0.0 0.0 804 0.0 765 0.0 7.8 0.0 789 802 765 781 814 Agra Bhiwani Unnao 01:57 00:58 00:58 12:19 21:54 12:10 0.0 9.1 0.0 0.0 765 765 1.0 0.0 765 0.0 0.0 Lucknow Meerut Jhatikara Bareilly 765 kV 0.0 0.0 0.0 0.0 0.0 751 756 0.0 765 00:58 01:57 12:11 12:10 0.0 0.0 0.0 0.0 0.0 19.4 19.4 0.0 0.0 00:59 18:02 18:15 12:10 12:10 12:11 787 779 750 755 765 0.0

0.0

0.0

0.0

0.0

746

796

#### IX. Reservior Parameters:

Name of Reservior	Paramete	rs	Present I	Parameters	Last \	ear ear	Last day	
Name of Reservior	FRL (m)	MDDL (m)	Level (m)	Energy (MU)	Level (m)	Energy (MU)	Inflow (m <sup>3</sup> /s)	Usage (m <sup>3</sup> /s)
Bhakra	513.59	445.62	487.25	652.97	481.85	503.43	184.00	692.91
Pong	426.72	384.05	398.44	185.67	399.59	209.93	36.70	329.83
Tehri	829.79	740.04	771.60	229.79	784.25	371.99	36.33	212.00
Koteshwar	612.50	598.50	611.15	5.15	609.04	4.69	212.00	209.07
Chamera-I	760.00	748.75	0.00	0.00	0.00	0.00	62.34	75.54
Rihand	268.22	252.98	0.00	0.00	0.00	0.00	0.00	0.00
RPS	352.80	343.81	0.00	0.00	0.00	0.00	0.00	0.00
Jawahar Sagar	298.70	295.78	0.00	0.00	0.00	0.00	0.00	0.00
RSD	527.91	487.91	496.03	1.09	502.38	2.71	68.27	53.12

<sup>\*</sup> NA: Not Available

Y(A) Short-Term Open Access Details:

State	Off- Peak Hours (03:00 Hrs)			Peak Hours (19:00 Hrs)			Day Energy (MU)		
	Bilateral (MW)	IEX (MW)	PXIL (MW)	Bilateral (MW)	IEX (MW)	PXIL (MW)	Bilateral (MU)	IEX / PXIL (MU)	Total (MU)
Punjab	-45	309	0	-918	-309	0	-4.11	6.27	2.15
Delhi	-739	-334	0	-658	94	0	-16.28	-0.04	-16.32
Haryana	-183	200	0	-208	283	0	-5.69	6.40	0.71
HP	30	204	0	376	-100	0	8.07	0.19	8.26
J&K	486	0	0	548	137	0	11.26	0.24	11.50
CHD	0	0	0	0	-15	0	0.00	-0.10	-0.10
Rajasthan	-7	598	3	-7	452	3	0.60	12.85	13.45
UP	130	0	0	-12	679	0	-5.41	2.52	-2.89
Uttarakhand	193	53	0	193	325	0	4.75	4.86	9.61
Total	-136	1030	3	-687	1544	3	-6.81	33.20	26.39

X(B). Short-Term Open Access Details:

State	Bilateral (	MW)	IEX	(MW)	PXIL (MW)	
State	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
Punjab	-45	-918	345	-509	0	0
Delhi	-650	-739	474	-334	0	0
Haryana	-183	-411	310	-5	0	0
HP	541	30	204	-569	0	0
J&K	548	446	147	-11	0	0
CHD	0	0	0	-46	0	0
Rajasthan	186	-7	781	-194	3	2
UP	159	-581	679	0	0	0
Uttarakhand	222	193	434	53	0	0

#### XI. System Reliability Indices(Violation of TTC and ATC):

(i)%age of times N-1 Criteria was violated in the inter - regional corridors

WR	0.00%
ER	0.00%
Simultaneous	0.00%

(ii)%age of times ATC violated on the inter-regional corridors

WR	1.39%
ER	0.00%
Simultaneous	4.51%

(iii)%age of times Angular Difference on Important Buses was beyond permissible limits(40 deg.)

Rihand - Dadri	0.00%

XII.System Constraints:

XIII. Grid Disturbance / Any Other Significant Event:

XIV. Weather Conditions For 01.03.2016 : Normal

XV. Synchronisation of new generating units :

XVI. Synchronisation of new 220 / 400 / 765 KV lines and energising of bus / /substation : 1) 400 kV Varanasi-Allahabad first time charged at 16.48 Hrs.
2) 400 kV Varanasi-Sarnath first time charged at 18.26 Hrs.

XVII. Tripping of lines in pooling stations :

 $\ensuremath{\mathsf{XVIII}}.$  Complete generation loss in a generating station :