पॉवर सिस्टम ऑपरेशन कार्पोरेशन लिमिटेड

(पावरब्रिड की पूर्ण स्वामित्व प्राप्त सहायक कंपनी)

उत्तरी क्षेत्रीय भार प्रेषण केंद्र

CIN: U40105DL2009G01188682
Power Supply Position in Northern Region for 01.04.2016
Date of Reporting: 02.04.2016



							Energy (Net MU)		
Demand Met	Shortage	Requirement	Freq* (Hz)	Demand Met	Shortage	Requirement	Freq* (Hz)	Demand Met	Shortage
35798	1484	37283	49.91	33248	283	33531	50.07	853.4	30.82

II. A. State's Load D	etails (At States periphery) in	MUs:							UI [OD:(+ve), UD: (-ve)]
State		State's Control Area Gene	eration (Net MU)		Drawal Schedule	Actual Drawal	UI	Consumption	Shortages *
	Thermal	Hydro	Renewable/others \$	Total	(Net MU)	(Net MU)	(Net MU)	(Net MU)	(MU)
Punjab	47.61	7.68		55.29	59.30	58.04	-1.26	113.33	0.00
Haryana	21.42	0.19		21.61	87.51	86.83	-0.68	108.45	0.00
Rajasthan	111.45	0.76	10.03	122.23	56.65	58.00	1.34	180.23	0.00
Delhi	6.84			6.84	66.37	66.81	0.44	73.65	0.16
UP	166.07	3.15		169.22	108.07	106.97	-1.10	276.19	18.77
Uttarakhand		7.58		7.58	23.41	25.86	2.45	33.44	0.08
HP		8.04		8.04	14.66	14.63	-0.02	22.67	0.00
J&K		14.49	0.00	14.49	24.53	27.19	2.66	41.68	11.81
Chandigarh				0.00	3.91	3.82	0.27	3.82	0.00
Total	353.39	41.88	10.03	405.30	444.41	448.14	4.09	853.45	30.82

State		Evening Peak (19:00 l	Hrs) MW			Off Peak (03:0	0 Hrs) MW		
	Demand Met	Shortage	UI	STOA/PX transaction	Demand Met	Shortage	UI	STOA/PX transaction	# Max(hourly) Demand Met of Day (MW)
Punjab	4709	0	-189	-269	3677	0	15	222	5531
Haryana	5517	0	24	621	3397	0	-120	-229	6145
Rajasthan	6493	0	-162	476	7322	0	85	506	8109
Delhi	3484	0	-49	184	2384	0	75	-533	3696
UP	11027	1020	-382	202	12831	0	56	1454	12846
Uttarakhand	1593	0	175	473	1195	0	138	398	1663
HP	924	0	-6	-50	733	0	52	166	1185
J&K	1857	464	163	-45	1605	283	150	-81	2029
Chandigarh	194	0	-6	0	104	0	-5	0	195
Total	35798	1484	-432	1591	33248	283	446	1902	39200

Chandigarh	194	0	-6	0	104	0	-5	0	195
Total	35798	1484	-432	1591	33248	283	446	1902	39200
STOA figures are at sellers		figures may not be at simultaneous h	our.					Diversity is	1.06 UI [OG:(+ve), UG: (-ve)]
regional Entit	Station/	Inst. Capacity	Declared	Peak MW	Off Peak MW	Energy	Average	Schedule	UI
	Constituent	(Effective) MW	Capacity(MW)	(Gross)	(Gross)	(Net MU)	Sentout(MW)	Net MU	Net MU
A. NTPC	Singrauli STPS (5*200+2*500)	2000	915	1039	1027	22.83	951	21.78	1.05
	Rihand I STPS (2*500)	1000	725	814	806	17.51	730	17.18	0.33
	Rihand II STPS (2*500)	1000	946	1038	982	22.73	947	22.34	0.40
	Rihand III STPS (2*500)	1000	946	979	935	22.44	935	22.41	0.03
	Dadri I STPS (4*210)	840	815	542	594	10.67	444	11.02	-0.36
	Dadri II STPS (2*490)	980	490	427	436	9.19	383	9.41	-0.22
	Unchahar I TPS (2*210)	420	198	163	362	4.61	192	4.52	0.09
	Unchahar II TPS (2*210)	420	404	435	413	8.06	336	8.19	-0.13
	Unchahar III TPS (1*210)	210	202	210	212	4.11	171	4.19	-0.08
	ISTPP (Jhaiihar) (3*500)	1500	950	400	342	8.04	335	8.12	-0.07
	Dadri GPS (4*130.19+2*154.51)	830	790	179	187	4.23	176	4.39	-0.16
	Anta GPS (3*88.71+1*153.2)	419	265	0	0	0.00	0	0.00	0.00
	Auraiya GPS (4*111.19+2*109.30)	663	648	0	0	0.00	0	0.00	0.00
	Dadri Solar(5)	5	1	0	0	0.02	1	0.02	0.00
	Unchahar Solar(10)	10	i	0	0	0.03	1	0.02	0.00
	Singrauli Solar(15)	15	3	0	0	0.07	3	0.07	0.00
	KHEP(4*200)	800	655	0	0	2.73	114	2.60	0.13
	Sub Total (A)	12112	8953	6226	6296	137	5719	136	1
B. NPC	NAPS (2*220)	440	402	402	402	9.65	402	9.65	0.00
B. NPC	RAPS- B (2*220)	440	378	416	402	9.05	377	9.07	-0.03
NUDC	RAPS- B (2 220) RAPS- C (2*220)	440	415	443	450	9.60	400	9.96	-0.03
		1320		1261	1274	28.28	1178	28.68	-0.36
C. NHPC	Sub Total (B)		1195						
C. NHPC	Chamera I HPS (3*180)	540	534	263	0	5.24	218	4.98	0.26
	Chamera II HPS (3*100)	300	300	288	0	2.50	104	2.31	0.19
	Chamera III HPS (3*77)	231	235	232	0	1.53	64	1.39	0.14
	Bairasuil HPS(3*60)	180	179	185	60	3.07	128	2.98	0.09
	Salal-HPS (6*115)	690	374	535	408	9.73	406	8.96	0.77
	Tanakpur-HPS (3*40)	94	16	16	15	0.46	19	0.39	0.07
	Uri-I HPS (4*120)	480	475	472	469	11.46	478	11.40	0.06
	Uri-II HPS (4*60)	240	203	181	221	4.94	206	4.87	0.06
	Dhauliganga-HPS (4*70)	280	280	287	0	0.97	41	0.84	0.13
	Dulhasti-HPS (3*130)	390	387	406	0	5.93	247	5.67	0.26
	Sewa-II HPS (3*40)	120	119	127	125	2.99	125	2.86	0.13
	Parbati 3 (4*130)	520	152	264	0	0.87	36	0.83	0.04
	Sub Total (C)	4065	3254	3256	1299	50	2070	47	2
D.SJVNL	NJPC (6*250)	1500	1499	1346	0	8.54	356	8.57	-0.03
	Rampur HEP (6*68.67)	412	375	375	0	2.50	104	2.39	0.11
	Sub Total (D)	1912	1874	1721	0	11.05	460	10.97	0.08
E. THDC	Tehri HPS (4*250)	1000	447	447	0	4.45	185	4.40	0.05
	Koteshwar HPS (4*100)	400	92	92	90	2.24	93	2.20	0.04
	Sub Total (E)	1400	539	539	90	6.68	278	6.60	0.08
F. BBMB	Bhakra HPS (2*108+3*126+5*157)	1379	477	1018	399	11.99	500	11.45	0.55
	Dehar HPS (6*165)	990	253	660	165	5.83	243	6.06	-0.23
	Pong HPS (6*66)	396	182	270	54	4.23	176	4.37	-0.14
	Sub Total (F)	2765	911	1948	618	22.05	919	21.87	0.18
G. IPP(s)/JV(s)	ALLAIN DUHANGAN HPS(IPP) (2*96)	192	0	41	0	0.80	33	0.77	0.04
1-7- 1-7	KARCHAM WANGTOO HPS(IPP) (4*250)	1000	0	740	150	3.38	141	4.59	-1.21
	Malana Stg-II HPS (2*50)	100	0	0	0	0.41	17	0.38	0.03
	Shree Cement TPS (2*150)	300	0	294	293	7.03	293	7.08	-0.04
	Budhil HPS(IPP) (2*35)	70	0	0	0	0.30	13	0.28	0.03
	Sub Total (G)	1662	0	1075	443	11.92	497	13.09	-1.16
H. Total Regional Er		25237	16726	16025	10020	266.93	11122	264.96	1.97



I. State Entities	Station	Effective Installed Capacity (MW)	Peak MW	Off Peak MW	Energy(MU)	Average(Ser out MW)
Punjab	Guru Gobind Singh TPS (Ropar) (6*210)	1260	160	160	3.49	146
	Guru Nanak Dev TPS(Bhatinda) (2*110+2*120)	460	190	201	4.27	178
	Guru Hargobind Singh TPS(L.mbt) (2*210+2*250)	920	585	563	13.17	549
	Goindwal(GVK)		0	278	3.90	163
	Rajpura (2*700)	1400	330	330	10.78	449
	Talwandi Saboo (2*660)	1320	614	308	11.99	500
	Thermal (Total)	5360	1879	1840	47.61	1984
	Total Hydro Total Punjab	1000 6360	289 2168	247 2087	7.68 55.29	320 2304
Haryana	Panipat TPS (4*110+2*210+2*250)	1367	0	0	0.00	0
i lai yaila	DCRTPP (Yamuna nagar) (2*300)	600	520	475	11.43	476
	Faridabad GPS (NTPC)	432	0	0	0.03	1
	RGTPP (khedar) (IPP) (2*600)	1200	470	398	9.96	415
	Magnum Diesel (IPP)	25	0	0	0.00	0
	Jhajjar(CLP) (2*660)	1320	0	0	0.00	0
	Thermal (Total)	4944	990	873	21.42	893
	Total Hydro	62	0	13	0.19	8
	Total Haryana	5006	990	886	21.61	901
Rajasthan	kota TPS (2*110+2*195+3*210)	1240	690	959	19.02	793
	suratgarh TPS (6*250)	1500	191	193	4.69	195
	Chabra TPS (4*250)	1000	567	557	14.93	622
	Dholpur GPS (3*110)	330	0	0	0.00	0
	Ramgarh GPS (1*37.5 + 1*35.5 +2*37.5 +1*110 +1*50)	271	168	168	3.66	153
	RAPS A (NPC) (1*100+1*200)	300	0	0	0.00	0
		250	161	159	3.66	153
	Barsingsar (NLC) (2*125) Giral LTPS (2*125)	250	161 0	159	0.00	153
	Giral LTPS (2*125) Rajwest LTPS (IPP) (8*135)	1080	544	561	16.53	689
	VS LIGNITE LTPS (IPP) (1135)	135	0	0	0.00	0
	Kalisindh Thermal(2*600)	1200	875	813	21.95	914
	Kawai(Adani) (2*660)	1320	1051	1051	27.01	1125
	Thermal (Total)	8876	4247	4461	111	4644
	Total Hydro	550	22	22	0.76	32
	Wind power	3214	187	501	6.37	265
	Biomass	99	19	19	0.47	19
IP.	Solar	730	0	0	3.19	133
	Renewable/Others (Total)	4043	206	520	10.03	418
	Total Rajasthan	13469	4475	5003	122.23	5093
UP	Anpara TPS (3*210+2*500)	1630	1225	1225	29.30	1221
	Obra TPS (2*50+2*94+5*200)	1194	446	458	10.64	443
	Paricha TPS (2*110+2*220+2*250)	1140	968	985	23.21	967
	Panki TPS (2*105)	210	45	77	1.47	61
	Harduaganj TPS (1*60+1*105+2*250)	665	545	538	12.73	530
	Tanda TPS (NTPC) (4*110)	440	380	382	9.17	382
	Roza TPS (IPP) (4*300)	1200	1107	1085	24.12	1005
	Anpara-C (IPP) (2*600)	1200	1084	1080	25.90	1079
	Bajaj Energy Pvt.Ltd(IPP) TPS (10*45)	450	404	403	7.91	330
	Anpara-D(2*500)	500	212	110	3.98	166
	Lalitpur TPS(2*660)	1320	197	201	5.64	235
	Bara(2*660)	1320	0	0	0.00	0
	Thermal (Total)	11269	6613	6544	154	6420
	Vishnuparyag HPS (IPP)(4*110)	440	82	70	1.70	71
	Alaknanada(4*82.5)	330	76	75	1.07	45
	Other Hydro	527	40	2	0.38	16
	Cogeneration	981	500	500	12.00	500
Incomplete and	Total UP	13547	7311	7191	169	7051
Jttarakhand	Total Hydro	1398	436	213	7.58 7.58	316
5-II-1	Total Uttarakhand	1398	436	213		316
Delhi	Rajghat TPS (2*67.5)	135	0	0	0.00	0
	Delhi Gas Turbine (6x30 + 3x34)	282	32	39	0.90	38
	Pragati Gas Turbine (2x104+ 1x122)	330	149	0	2.51	104
	Rithala GPS (3*36)	95	0	0	0.00	0
	Bawana GPS (4*216+2*253)	1370 705	0 165	165	0.00 3.43	143
	Badarpur TPS (NTPC) (3*95+2*210)	2917	165 346	165 204	6.84	143 285
	Thermal (Total) Total Delhi	2917 2917	346 346	204 204	6.84	285 285
НP	Baspa HPS (IPP) (3*100)	300	0	0	0.95	39
	Malana HPS (IPP) (2*13)	86	0	0	0.38	16
	Other Hydro	878	313	243	6.71	280
	Total HP	1264	313	243	8.04	335
J&K	Baglihar HPS (IPP) (3*150)	450	440	440	10.56	440
n	Other Hydro/IPP	560	156	153	3.93	164
	Gas/Diesel/Others	190	0	0	0.00	0
	Total J & K	1200	596	593	14.49	604
Total State Control		45161	16635	16420	405.30	16888
	al Exchange [Import (+ve)/Export (-ve)]		7040	8523	193.49	8062
	ilability(Gross)	70398	39700	34963	865.72	36072

IV. Total Hydro Generation:

11. Total Hydro Ocheration:					
Regional Entities Hydro	12234	8245	2157	96.78	4033
State Control Area Hydro	6581	1854	1478	42	1745
Total Regional Hydro	18815	10099	3635	138.66	5778

V(A), Inter	Regional Exchang	e (Import (+ve)/E	xport (-ve)] [Linkwise]

Element	Peak(19:00 Hrs)	Off Peak(03:00 Hrs)	Maximum Inte	rchange (MW)	Energy	Energy (MU)	
Element	MW	MW	Import	Export	Import	Export	MU
Vindhychal(HVDC B/B)	250	250	250	0	6.01	0.00	6.01
765 KV Gwalior-Agra (D/C)	2659	2949	3311	0	70.00	0.00	70.00
400 KV Zerda-Kankroli	-37	-181	22	181	0.00	1.92	-1.92
400 KV Zerda-Bhinmal	21	-130	127	150	0.00	0.43	-0.43
220 KV Auraiya-Malanpur	6	19	23	0	0.90	0.00	0.90
220 KV Badod-Kota/Morak	-48	-15	21	67	0.00	0.56	-0.56
Mundra-Mohindergarh(HVDC Bipole)	2498	2503	2507	0	60.74	0.00	60.74
400 KV Vindhyachal - Rihand	0	0	0	0	0.00	0.00	0.00
765 kV Phagi-Gwalior (D/C)	899	900	1047	0	21.36	0.00	21.36
Sub Total WR	6248	6295			159.02	2.91	156.10
Pusauli Bypass/HVDC	250	250	250	0	6.02	0.00	6.02
400 KV MZP- GKP (D/C)	432	-104	442	120	4.79	0.00	4.79
400 KV Patna-Balia(D/C) X 2	243	593	626	0	9.41	0.00	9.41
400 KV B'Sharif-Balia (D/C)	99	359	383	0	5.78	0.00	5.78
765 KV Gaya-Balia	252	317	369	0	3.85	0.00	3.85
765 KV Gaya-Varanasi -1	-6	228	126	0	1.85	0.00	1.85
220 KV Pusauli-Sahupuri	130	160	197	0	3.54	0.00	3.54
132 KV K'nasa-Sahupuri	0	0	0	0	0.00	0.00	0.00
132 KV Son Ngr-Rihand	-27	-30	0	30	0.00	0.59	-0.59
132 KV Garhwa-Rihand	0	0	0	0	0.00	0.00	0.00
765 KV Sasaram - Fatehpur	-258	-95	31	258	0.00	2.09	-2.09
400 KV Barh -GKP (D/C)	328	250	350	0	6.68	0.00	6.68
400 kvB'Sharif - Varanasi (D/C)	-191	-200	0	226	0.00	2.01	-2.01
Sub Total ER	1252	1728			41.93	4.69	37.24
+/- 800 KV BiswanathCharialli-Agra	-460	500	500	500	0.15	0.00	0.15
Sub Total NER	-460	500			0.15	0.00	0.15
Total IR Exch	7040	8523			201.09	7.60	193.49

V(B). Inter Regional Schedule & Actual Exchanges [Import (+ve)/Export (-ve)] [Corridor wise]

	ISGS/LT Schedule (MU)			hedule (MU)	Power Exchange	ge Shdl (MU)	Wheeling (MU)	
ER	ER Bhutan Total		Through ER Through WR		Through ER Through WR		Through ER	Through WR
36.63	0.27	36.90	2.12	-1.90	5.62	28.76	0.00	0.00

Total IR Schedule (MU)			Total IR Actual (MU) Net IR UI (MU))	
Through ER	Through WR Incids Mndra	Total	Through ER(including NER)	Through WR	Total	Through ER(including NER)	Through WR	Total
44.65	153 77	109.41	27.20	156 10	102.40	7.26	2 3/1	-4 92

V(C). Inter National Exchange with Nepal [Import (+ve)/Export (-ve)] [Linkwise]

Element	Peak(19:00 Hrs) Off Peak(03:00 Hrs)		Maximum Interd	change (MW)	Energy	Net Energy	
Liement	MW	MW	Import	Export	Import	Export	MU
132 KV Tanakpur - Mahendarnagar	-31	-30	0	33	0	1	-0.71

	VI. Frequency Profile <% of Time Frequency>											
	<49.2	<49.7	<49.8	<49.9	<50.0	49.9-50.05	50.05-50.10	50.10-50.20	>50.20	>50.50		
ſ	0.00	0.00	1.64	14.09	58.56	72.07	10.96	3.09	0.30	0.00		

<>			Average	Frequency		Frequency	in 15 Min Block		
	Maximum	Minimum		Frequency	Variation	Std. Dev.	MAX	MIN	Freq Dev Index (% of Time)
Freq	Time	Freq	Time	Hz	Index		(Hz)	(Hz)	
50.32	18.02	49.72	19.10	49.98	0.060	0.074	50.16	49.91	27.93

VII. Voltage profile 400 kV

Station	Station Voltage Level (kV)		Maximum		Minimum		Voltage (in % of Time)			
otation .	voltage Level (KV)	Voltage(KV)	Time	Voltage (KV)	Time	<380 kV	<390 kV	>420 kV	>430 kV	Index (% of Time)
Rihand	400	404	00:00	398	21:16	0.0	0.0	0.0	0.0	0.0
Gorakhpur	400	420	08:06	410	01:07	0.0	0.0	0.0	0.0	0.0
Bareilly(PG)400kV	400	417	18:02	400	11:40	0.0	0.0	0.0	0.0	0.0
Kanpur	400	417	08:02	403	11:17	0.0	0.0	0.0	0.0	0.0
Dadri	400	422	02:00	403	11:42	0.0	0.0	12.4	0.0	12.4
Ballabhgarh	400	428	02:54	406	11:44	0.0	0.0	43.1	0.0	43.1
Bawana	400	426	02:54	406	11:35	0.0	0.0	31.9	0.0	31.9
Bassi	400	424	18:01	401	11:44	0.0	0.0	3.3	0.0	3.3
Hissar	400	421	02:01	340	17:37	0.0	0.0	1.6	0.0	1.6
Moga	400	418	05:31	403	11:35	0.0	0.0	0.0	0.0	0.0
Abdullapur	400	425	21:37	408	19:09	0.0	0.0	25.5	0.0	25.5
Nalagarh	400	428	02:52	410	11:35	0.0	0.0	40.3	0.0	40.3
Kishenpur	400	421	03:24	400	19:19	0.0	0.0	0.9	0.0	0.9
Wagoora	400	407	03:50	383	19:17	0.0	20.9	0.0	0.0	0.0
Amritsar	400	424	02:54	404	09:17	0.0	0.0	19.0	0.0	19.0
Kashipur	400	420	18:02	411	11:16	0.0	0.0	0.0	0.0	0.0
Hamirpur	400	422	02:05	403	11:41	0.0	0.0	12.4	0.0	12.4
Rishikesh	400	413	18:02	388	11:16	0.0	2.8	0.0	0.0	0.0

VIII. Voltage profile	765 kV									
Station Voltage Level (kV)		Maximum		Minimum		Voltage (in % of Time)				Voltage Deviation
Station	Voltage Level (kV)	Voltage(KV)	Time	Voltage (KV)	Time	<728 kV	<742 kV	>800 kV	>820 kV	Index (% of Time)
Fatehpur	765	768	07:20	736	11:17	0.0	7.6	0.0	0.0	0.0
Balia	765	778	08:06	760	19:10	0.0	0.0	0.0	0.0	0.0
Moga	765	799	18:01	768	11:43	0.0	0.0	0.0	0.0	0.0
Agra	765	785	18:01	751	11:42	0.0	0.0	0.0	0.0	0.0
Bhiwani	765	798	02:00	769	11:30	0.0	0.0	0.0	0.0	0.0
Unnao	765	760	08:04	742	11:16	0.0	0.0	0.0	0.0	0.0
Lucknow	765	785	18:02	765	11:17	0.0	0.0	0.0	0.0	0.0
Meerut	765	807	18:01	769	11:44	0.0	0.0	15.4	0.0	15.4
Jhatikara	765	801	02:00	766	11:48	0.0	0.0	11.8	0.0	11.8
Bareilly 765 kV	765	784	18:02	756	11:12	0.0	0.0	0.0	0.0	0.0
Anta	765	776	01:54	758	10:52	0.0	0.0	0.0	0.0	0.0
Phagi	765	78/	02:53	766	00:00	0.0	0.0	0.0	0.0	0.0

IX. Reservior Parameters:

ix. Reservior i aramete	CI J.							
Name of Reservior	Parameters		Present I	Parameters	Last Y	'ear	Last day	
Name of Reservior	FRL (m)	MDDL (m)	Level (m)	Energy (MU)	Level (m)	Energy (MU)	Inflow (m ³ /s)	Usage (m³/s)
Bhakra	513.59	445.62	480.14	461.24	480.68	474.82	198.08	363.87
Pong	426.72	384.05	395.99	141.12	402.92	288.96	52.10	330.46
Tehri	829.79	740.04	753.50	76.98	773.25	240.42	46.97	152.00
Koteshwar	612.50	598.50	610.93	5.10	611.15	5.05	152.00	147.35
Chamera-I	760.00	748.75	759.24	0.00	0.00	0.00	151.18	144.14
Rihand	268.22	252.98	0.00	0.00	0.00	0.00	0.00	0.00
RPS	352.80	343.81	0.00	0.00	0.00	0.00	0.00	0.00
Jawahar Sagar	298.70	295.78	0.00	0.00	0.00	0.00	0.00	0.00
RSD	527.91	487.91	496.70	0.44	510.03	2.87	66.17	0.00

^{*} NA: Not Available

X(A). Short-Term Open Access Details:

State	Off- Peak Hours (03:00 Hrs)			Peal	Hours (19:00 Hrs)		Day Energy (MU)		
Giaio	Bilateral (MW)	IEX (MW)	PXIL (MW)	Bilateral (MW)	IEX (MW)	PXIL (MW)	Bilateral (MU)	IEX / PXIL (MU)	Total (MU)
Punjab	9	212	0	-404	135	0	-1.42	4.44	3.02
Delhi	-303	-230	0	-177	361	0	-5.00	4.20	-0.80
Haryana	466	-695	0	368	252	0	9.30	-2.12	7.18
HP	-127	292	0	-25	-25	0	-1.79	3.43	1.64
J&K	-81	0	0	-81	36	0	-1.64	-0.13	-1.76
CHD	0	0	0	0	0	0	0.00	0.01	0.01
Rajasthan	-4	510	0	-4	481	0	-0.10	10.05	9.95
UP	288	1167	0	202	0	0	4.90	8.90	13.80
Uttarakhand	0	398	0	0	473	0	0.23	11.05	11.28
Total	248	1654	n	-122	1712	0	4 48	39.83	44 31

X(B). Short-Term Open Access Details:

State	Bilateral (MV	V)	IEX	(MW)	PXIL (MW)	
State	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
Punjab	9	-404	212	134	0	0
Delhi	-177	-303	526	-281	0	0
Haryana	466	293	261	-780	0	0
HP	-25	-254	390	-432	0	0
J&K	-7	-81	36	-13	0	0
CHD	0	0	30	-25	0	0
Rajasthan	-4	-4	518	-221	0	0
UP	308	143	1167	0	0	0
Uttarakhand	29	0	543	374	0	0

XI. System Reliability Indices(Violation of TTC and ATC):

(i)%age of times N-1 Criteria was violated in the inter - regional corridors

WR	0.00%
ER	0.00%
Simultaneous	0.00%

(ii)%age of times ATC violated on the inter-regional corridors

WR	1.74%
ER	0.00%
Simultaneous	31.25%

(iii)%age of times Angular Difference on Important Buses was beyond permissible limits(40 deg.)

Rihand - Dadri	0.00%

XII.System Constraints:

XIII. Grid Disturbance / Any Other Significant Event:

XIV. Weather Conditions For 01.04.2016 : Normal

XV. Synchronisation of new generating units :

XVI. Synchronisation of new 220 / 400 / 765 KV lines and energising of bus / /substation :

0.00 0.00 0.00 0.00

XVII. Tripping of lines in pooling stations :

 $\ensuremath{\mathsf{XVIII}}.$ Complete generation loss in a generating station :