




PLAN OF BOUNDARY WALL




DETAIL OF FOUNDATION F1



SECTION OF COLUMN AT B-B



BEAM - FB1



9" TH. BRICK WALL FOUNDATION. (SECTION AT 'A-A')

COLUMN NO.	COLUMN SIZE	REINFORCEMENT DETAIL							
C1	9" X12"	 BAR NO. :- 1 TO 8 - 12Ø TOR RINGS:-8Ø TOR @6"C/C THROUGHOUT	 (a+b)						
SCHEDULE FOR DETAIL OF COLUMN FOOTING									
COLUMN FOOTING			DIMENSION		REINFORCEMENT FOR FOOTING		PEDESTAL DIMENSION		
	L	B	H ₁	H ₂	D	R	S	L ₁	B ₁
F1	4'-0"	3'-3"	6"	1'-6"	3'-0"	10Ø TOR 6" C/C	10Ø TOR 6" C/C.	2'-0"	1'-3"
F2	5'-0"	3'-9"	6"	1'-6"	3'-0"	10Ø TOR 6" C/C.	10Ø TOR 6" C/C.	3'-7½"	1'-3"
F3	4'-6"	4'-6"	6"	1'-6"	3'-0"	10Ø TOR 6" C/C.	10Ø TOR 6" C/C.	2'-10½"	1'-3"

- NOTES
- *IF THERE IS ANY DISCREPANCY REGARDING DIMENSIONS, ARCHITECTURAL DRAWINGS MAY BE CONSULTED.
 - * WRITTEN DIMENSIONS SHOULD BE FOLLOWED.
 - *M-20 (1:1½:3) GRADE CONCRETE TO BE USED IN ALL CONCRETE WORKS.
 - * Ø TOR MEANS DIAMETER IN MM FOR TOR STEEL BARS.
 - *STEEL SHUTTERING IS TO BE USED FOR ALL CONCRETE WORKS.
 - *STEEL OF COLUMN TO GO UP TO BOTTOM OF FOUNDATION WITH BEND OF 1'-0" AT BOTTOM.
 - *LEAN CONCRETE WILL BE 6" TH. IN MIX 1:4:8.
 - *LEAN CONCRETE WILL PROJECT 3" BEYOND THE R.C.C FOUNDATION.
 - *COVER TO REINFORCEMENT OF COLUMNS WILL BE 40 MM ON ALL FACES.
 - *COVER TO REINFORCEMENT OF FOUNDATION SLAB WILL BE 3"
 - *DRAWING IS NOT TO BE SCALED.
 - * DEVELOPMENT LENGTH(L_d) OF STEEL IS 57 TIMES THE DIAMETER OF THE BAR.
 - * CEMENT MORTAR RATIO IN 9" THK. BRICK WORK IS 1:4.
 - *EXPANSION GAP SHOULD BE PROVIDED AFTER EVERY 100' AND AT EVERY CORNER.

ENGINEER :-

CLIENT :-
XEN PANCHAYATI RAJ,NUH

PROJECT :-
STRUCTURAL DRAWINGS OF PANCHYAT GHAR AT VILLAGE GHASERA,DISTT.NUH

SUB TITLE :-
BOUNDARY WALL DETAIL

DRG. NO. :-
JC/PR/NUH/2420/11

SCALE :-
1 : 100

DATE :-
9 July 2022

DRAWN BY:-
SIMRAN

DSN BY:-
JASBIR

CKD. BY:-
K.B. MANOCHA

JC TECHNOCRATS PVT. LTD.
(Formerly known as Jindals Consortium, Since 1990)
STRUCTURAL ENGINEERS, HIGHWAY & BRIDGE DESIGNERS, PROJECT MANAGEMENT CONSULTANTS
ROAD SAFETY AUDITORS, PROOF CONSULTANTS, SURVEYORS AND SOIL INVESTIGATORS
REGD.OFF.: S.C.F-8, VIKAS VIHAR, AMBALA CITY-134003, HARYANA. PH: 0171-2550013, MOB:-91-98966-70914
DELHI : #6/8, GREEN VIEW APARTMENTS, SECTOR 19, POCKET-2, DWARKA, NEW DELHI. MOB:-91-99966-70914
Mob:- 8199907006, 9896599113, e-mail: jindalstructure@gmail.com, jindals13@gmail.com, Web: www.jindalsconsortium.in