


DRIVEWAY PERMIT — SITE PLAN [REV. 1 — APR 2026]

8506 Seven Coves Court · Hillsborough County, FL · After-the-fact ROW Permit

ADDRESS: 8506 Seven Coves Ct, Tampa FL 33634
MATERIAL: 6" Reinf. Conc. on 6" Comp. Base
SCALE: Approx. 1" = 8 ft
DATE: April 2026 — Rev. 1
SHEET: 1 of 2 — Site Plan



UTILITY SYMBOLS (in ROW)

- Water Meter (WM)**
min. 1 ft ✓
Located in ROW grass / swale. No relocation.
- Electric Box (EB)**
min. 3 ft ✓
Surface pad. No relocation.

SEPARATIONS @ EOP

- DW1 ↔ DW2: **10 ft** (min. 10 ft) ✓
- DW1 ↔ Neighbor DW: **10 ft** (min. 10 ft) ✓
- DW1 setback from L. PL corner: **5 ft**
- DW2 to start of PL curve: **17 ft**

ROW GEOMETRY

- ROW total: **50 ft** (25 ft each side of CL)
- Pavement: **24 ft** (12 ft each side of CL)
- Grass / swale (PL → EOP): **13 ft**
- Utility easement: **5 ft** inside PL
- Frontage: **59 ft**



 CONCRETE DRIVEWAY (6" / 6")  ROADWAY PAVEMENT  ROW GRASS / SWALE  UTILITY EASEMENT (5 ft)  PRIVATE PROPERTY  NEIGHBOR DW (schematic)  WATER METER (WM)

 ELECTRIC BOX (EB)

Sheet 1 of 2 — Site Plan · 8506 Seven Coves Ct, Tampa FL 33634 · **REV. 1 — RESPONDS TO ROW REVIEWER ISSUES #1, #2, #3**

NOTES, LEGEND & PROJECT INFORMATION [REV. 1 — APR 2026]

8506 Seven Coves Court · Hillsborough County, FL · After-the-fact ROW Permit

ADDRESS: 8506 Seven Coves Ct, Tampa FL 33634
PERMIT: After-the-fact ROW — Driveway Access
SCALE: Approx. 1" = 8 ft (Sheet 1)
DATE: April 2026 — Rev. 1
SHEET: 2 of 2 — Notes & Legend

CONSTRUCTION NOTES (Revised)

- All driveway construction: 6" reinforced concrete on 6" compacted base material (limerock or equivalent). Pre-existing condition; no new construction proposed.
- DW1 width: 17 ft. DW2 width: 10 ft. Both rectangular cross-section.
- Separation DW1 to DW2 measured at EOP between the straight edges (no flares constructed) = 10 ft. County minimum: 10 ft. **MEETS REQUIREMENT.**
- Neighboring driveway separation, measured at EOP from DW1 left edge = 10 ft (field measurement). County min: 10 ft. **MEETS.** See dashed indication on Sheet 1.
- Water meter (WM) clearance to DW1: 3 ft (county min. 1 ft). ✓
- Electric box (EB) clearance to DW2: 3 ft (county min. 3 ft). ✓
- No trees, signs, drainage structures, fire hydrants, or other utilities within the ROW driveway area.
- DW1 set back 5 ft from the left property corner (dimensioned on Sheet 1).
- Property line at NE corner curves at R = 14 ft (cul-de-sac geometry). This is **NOT** a driveway flare. DW2 right edge clears the start of the curve by 17 ft.
- SOD to be restored in any disturbed ROW areas.
- Contractor / homeowner to call 811 (Sunshine 811) before any excavation. (No excavation proposed under this after-the-fact permit.)
- ROW = 50 ft total (25 ft each side of CL). Roadway pavement = 24 ft total (12 ft each side of CL). Distance from EOP to property line = 13 ft (grass / swale).
- Utility easement: 5 ft strip on the inside of the property line. No utilities within easement conflict with either driveway.
- No public utilities (water main, sanitary sewer, storm pipe, gas, comms) are crossed or relocated by the existing driveways. WM and EB are surface assets only and clearances meet County minimums.
- Driveways pre-existing at time of property purchase (December 22, 2025). This permit is filed after-the-fact for legalization to Hillsborough County standards.
- Site visibility (LDC § 6.04.03): no obstructions between 2.5 ft and 8 ft above grade in clear sight triangles. Lot is interior on a cul-de-sac court.

Highlight key: **green** = revised note · **yellow** = new note added in Rev. 1

REFERENCED STANDARDS


PROJECT INFORMATION

Project Address: 8506 Seven Coves Ct, Tampa FL 33634
County: Hillsborough County, Florida
Permit Type: After-the-fact ROW — Driveway Access (Legalization)
Number of Driveways: Two (2) — DW1 & DW2
Lot Type: Interior residential, no sidewalk, on cul-de-sac
Property Frontage: 59 ft
Date Acquired: December 22, 2025 (driveways pre-existing)

DRIVEWAY DIMENSIONS

DW1 Width / Setback: 17 ft / 5 ft from left PL corner
DW2 Width / Clearance: 10 ft / 17 ft to PL curve
DW1 & DW2 Material: 6" Reinf. Conc. on 6" Comp. Base
Separation @ EOP: 10 ft (min. 10 ft) ✓
Driveway Geometry: Rectangular; no flares (existing)
PL Curve at NE corner: R = 14 ft (cul-de-sac PL, NOT a flare)

TYPICAL DRIVEWAY CROSS-SECTION



MINIMUM SEPARATION REQUIREMENTS — Hillsborough County ROW

Requirement	County Min	As Shown	Status
DW1 ↔ DW2 separation @ EOP	10 ft	10 ft	MEETS ✓
WM to driveway edge	1 ft	3 ft	MEETS ✓
EB to driveway edge	3 ft	3 ft	MEETS ✓
Utility / tree to driveway	3 ft	3 ft min.	MEETS ✓
Neighbor DW to DW1 @ EOP	10 ft	10 ft	MEETS ✓
Driveways limited to property side of EOP	required	terminate at EOP	REVISED ✓

REVISION HISTORY

Rev.	Date	Description
0	Mar 2026	Initial submittal

Hillsborough County Land Development Code (LDC) Article VI, Part 6.04.00 — Access Management · Hillsborough County Transportation Technical Manual §5.8 and Typical Detail TD-7 · Hillsborough County Utility Accommodation Guide and Rights-of-Way Use Procedures Manual (UAG/ROW) · Sunshine State One Call (811).

 CONCRETE DRIVEWAY	 ROADWAY PAVEMENT	 ROW GRASS / SWALE	 UTILITY EASEMENT (5 ft)	 PRIVATE PROPERTY
---	--	---	---	--

Rev.	Date	Description
		Responds to ROW reviewer Issues #1, #2, #3 (Renier Quintana, 3/17/2026): driveways now terminate at EOP; PL / ROW / easement
1	Apr 2026	NEC ROW labeled with dimensions; overlapping labels eliminated; (school) instruction notes corrected (R=14 ft is cul-de-sac PL, not a driveway flare).

Applicant signature
Date: _____

Applicant printed name
Property: 8506 Seven Coves Ct, Tampa FL 33634